

July 30, 2024

Town of Niagara-on-the-Lake Community & Development Services 1593 Four Mile Creek Road P.O. Box 100 Virgil, ON LoS 1To

Servicing Brief

1822 Niagara Stone Road, Niagara-on-the-Lake

To Whom it May Concern:

LandSmith Engineering & Consulting Ltd. have been retained by Fabian Reis of Ferox Winery to complete a Servicing Brief for the subject lands located at the above address in support of the proposed change of use for the existing buildings on-site. The site area is 5.96-hectares, and the existing Harvest Barn and Grey Barn buildings are proposed to be turned into a microbrewery and farm distillery, complete with multi-use hospitality and retail areas.

1.0 Water Service Assessment

The Ontario Building Code has been utilized to calculate the expected maximum hydraulic load and associated flow rate for the proposed changes in use for the existing buildings with the Fixture Unit Method, per OBC Table 7.6.3.2.A. These calculations have been based on the Site Plan provided by NPG Planning Solutions which is attached to this brief for reference purposes.

The existing Harvest Barn contains one staff washroom (toilet and sink), 2 commercial sinks, and one hand wash station (sink). The proposed changes for this building will include the addition of one commercial sink, 3 public washrooms, and one additional staff washroom. Table 1 on the following page summarizes the fixtures and associated hydraulic load for the Harvest Barn building.





	Fixture Exis		sting	Proposed	
Fixture	Units (FU)	Quantity	Hydraulic Load (FU)	Quantity	Hydraulic Load (FU)
Water Closet	2.2	1	2.2	5	11
Sink	1.4	2	2.8	6	8.4
Commercial Sink	4.0	2	8	3	12
Total Fixture Units		13	-	31.4	

Table 1: Harvest Barn Existing and Proposed Fixtures and Hydraulic Load (*Ref. OBC Table 7.6.3.2.A*)

The existing Grey Barn contains two public washrooms (toilet and sink). The proposed changes for this building will include the addition of one small kitchenette with one handwashing sink. Table 2 below summarizes the fixtures and associated hydraulic load for the Grey Barn building.

Fixtu		Existing		Proposed	
Fixture	Units (FU)	Quantity	Hydraulic Load (FU)	Quantity	Hydraulic Load (FU)
Water Closet	2.2	2	4.4	2	4.4
Sink	1.4	2	2.8	3	4.2
Total Fixture Units			7.2	-	8.6

Table 2: Grey Barn Existing and Proposed Fixtures and Hydraulic Load (*Ref. OBC Table 7.6.3.2.A*)

Based on the fixture units method, the buildings on site after the proposed change of use renovations will have a total of 40 fixture units. This is equivalent to a maximum hydraulic load of 3.03 L/s. The supporting calculations describing how this value was determined have been attached to this brief for reference purposes.

The existing buildings are serviced from a 25mm diameter copper pipe connected to the 200mm diameter watermain along East & West Line. The inspectors report which details this connection is attached to this brief for reference purposes. Due to the increase in fixtures with the proposed changes to the buildings on site, the water service line should be upsized to a 31.75mm diameter (1½ inch) pipe. This upsizing is documented on the *Sizing of Water Service Pipe* form attached to this brief for reference purposes. The existing 200mm diameter watermain can support this proposed upsize in domestic demand. As per Town Engineering Standards, the proposed water service pipe shall be Type "K" soft copper and shall conform to ASTM B88.

Based on the fact that the total building footprint size on site will remain unchanged after the proposed changes in use, the fire demands for the site will remain unchanged as well. Therefore, the





existing hydrants adjacent to the site can accommodate the fire flow demands. As illustrated on Town drawings No. 41236 – P4 and P5 attached to this brief for reference purposes, the hydrants adjacent to the east of the site connect to the 150mm diameter watermain along Niagara Stone Road and the hydrants adjacent to the north of the site connect to the 200mm diameter watermain along East & West Line.

2.0 Wastewater Assessment

Based on the Ontario Building Code the calculation for expected generation of sanitary effluent based on the proposed changes in use for the existing buildings is as follows:

Hospitality & Retail Areas:

As seen on the Site Plan, there will be a total of 282 square metres of Hospitality & Retail areas within the existing Harvest Barn and Grey Barn buildings. There will be a total of 5 water closets in these areas. As per OBC Table 8.2.1.3.B – Sewage System Design Flows, the demand for retail areas is 5 $L/day/m^2$, and 1,230 L/day per water closet. Using this criteria, the expected sanitary flow for the retail areas will be:

Hospitality & Retail Area Flow =
$$(282 \text{ m}^2 \text{ x 5 L/day/m}^2) + (5 \text{ x 1,230 L/day})$$

= 7,560 L/day = 0.088 L/s

Food Service Operation Areas:

As seen on the Site Plan, there will be a total of 757 square metres of Food Service Operations areas within the existing Harvest Barn and Grey Barn buildings. This includes cooler and freezer rooms, loading areas, and distilling/grape processing areas. There will be 2 staff water closets in these areas. As per OBC Table 8.2.1.3.B – Sewage System Design Flows, the demand for food operation areas is 190 L/day per 9.25m² of floor area, and 950 L/day per water closet. Using this criteria, the expected sanitary flow for the food operation areas will be:

Food Service Operations Area Flow =
$$((190 \text{ L/day/9.25m}^2) \times 757 \text{ m}^2) + (2 \times 950 \text{ L/day})$$

= $17,449 \text{ L/day} = 0.202 \text{ L/s}$

Total Wastewater Generation = 0.088 + 0.202 = 0.290 L/s Peaking Factor = 4.5 (Babbit Formula)

Estimated Peak Instantaneous Flow = 0.290 x 4.5 = 1.305 L/s





The existing sanitary service to the site is 150mm in diameter and is illustrated on Town drawing No. 0043PP1, which is attached to this brief for reference purposes. At a slope of 1.0% the capacity of the service connection is 15.22 L/s which is sufficient for the proposed domestic flows from the site.

Given the proposed development does not include the addition of any new structures on site, and the change of use only increases the number of fixtures, the increased sanitary flows from the subject lands are expected to easily be accommodated by the downstream sanitary infrastructure. The downstream system flows to the Sanitary Pumping Station (SPS) at municipal address 1974 Niagara Stone Road which has an operational capacity of 20.7 L/s and can accommodate the peak flows from the site.





3.0 Conclusions

Based on the analysis provided within this report we conclude that:

- 1. In order to accommodate the proposed increase in fixtures for the site, the existing 25mm diameter water service should be upsized to a 31.75mm diameter pipe. The existing 200mm diameter watermain along East & West Line can support this upsize in service.
- 2. Since the building footprint size will remain unchanged with the proposed change in use for the site, the fire flow demands for the site will not increase and can be accommodated by the existing adjacent hydrants.
- 3. The existing 150mm diameter sanitary service lateral can be re-used and can accommodate for the sanitary flows from the buildings.

We trust that the recommendations and analysis contained within the preceding Servicing Brief are satisfactory for the purposes of the Town. Should you have any questions please do not hesitate to contact the undersigned.

Respectfully submitted,

Indrew Smith

Andrew Smith, P. Eng.

Principal & Director

LandSmith Engineering & Consulting Ltd.

289-309-3632

andrew@landsmithec.com

COPY:

Fabian Reis, Ferox Winery (<u>fabian@ferox.ca</u>)

Jesse Ausptiz, NPG Planning Solutions (<u>jauspitz@npgsolutions.ca</u>)

A. P. SMITH 100193971

2024-07-30

ONTARIO





Attachments:

Site Plan by NPG Planning Solutions


Domestic Water Demand Calculations


Sizing of Water Service Pipe Form

Water Service Inspector's Report: 1822 Niagara Stone Road

Niagara Stone Road Watermain Plan & Profile: Town Drawings No. 41236-P4, P5

Niagara Stone Road Sanitary Sewer Plan & Profile: Town Drawing No. 0043PP1





KEY MAP

BLK 14 TP PL 85 NIAGARA EXCEPT PT 1, 2, 3 HWY1108 & HWY364; NIAGARA-ON-THE-LAKE

MUNICIPAL ADDRESS: 1822 NIAGARA STONE ROAD NIAGARA ON THE LAKE, ONTARIO

6.0 HA

0.05%

REQUIRED

REVEST BARN (DISCOUNTED @ 50%) 123.0 SQ.M 1,324.0 SQ.M EY BARN & LEAN-TO (DISCOUNTED @ 50%) 18.0 SQ.M 193.8 SQ.M EOPOSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ.M	NING:	RURA	L (A)			
PROPERTY A: 6.0 HA 14.8 AC IT FRONTAGE: (NIAGARA STONE ROAD) 465.0 M 14.8 AC IT FRONTAGE: (NIAGARA STONE ROAD) 465.0 M 14.8 AC IT FRONTAGE: (NIAGARA STONE ROAD) 465.0 M 14.8 AC IT FRONTAGE: (NIAGARA STONE ROAD) 465.0 M 18934.0 SQL IT ROAD SQL IT		%	METRIC		IMPERIAL	
STEP	T AREA: (APPROX)					
SOLIDING COVERAGE: STATE SOLIDING COVERAGE: STATE SOLIDING COVERAGE: STATE SOLIDING COVERAGE: STATE SOLIDING COVERAGE SOLIDING COLOR SOLIDING COLOR SOLIDING COVERAGE SOLIDING COLOR	PROPERTY A:		6.0	HA	14.8	AC
REVEST BARN 830.0 SQ.M 8934.0 SQ.M 2249.7 SQ. 10POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1722.2 SQ. 10POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 12905.9 SQ. 10POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 246.0 SQ.M 12905.9 SQ. 10POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 36.0 SQ.M 387.5 SQ. 10POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ. 10POSED ASSOCIATED USES (OFDU)	T FRONTAGE: (NIAGARA STONE ROAD)		465.0	М		
209.0 SQ.M 2249.7 SQ.I 1000 SQ.M 1722.2 SQ.I 1199.0 SQ.M 1722.2 SQ.I 1199.0 SQ.M 1722.2 SQ.I 1199.0 SQ.M 1722.2 SQ.I 1199.0 SQ.M 12905.9 SQ.I 129	ILDING COVERAGE:					
1000 SQ.M 1722.2 SQ.M 1000 SQ.M 1722.2 SQ.M 1000 SQ.M 12905.9 SQ.M 1000 SQ.	RVEST BARN		830.0	SQ.M	8934.0	SQ.FT
1199.0 SQ.M 12905.9 SQ.M 12905	EY BARN & LEAN-TO		209.0	SQ.M	2249.7	SQ.FT
ROSS LEASABLE FLOOR AREA: REVEST BARN 246.0 SQ.M 2647.9 SQ. 36.0 SQ.M 387.5 SQ. 360POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ. 1-FARM DIVERSIFIED USES (OFDU)	OPOSED ASSOCIATED STRUCTURES (SEASONAL TENT)		160.0	SQ.M	1722.2	SQ.FT
ARVEST BARN 246.0 SQ.M 2647.9 SQ. 1246.0 SQ.M 387.5 SQ. 125 BARN & LEAN-TO 36.0 SQ.M 387.5 SQ. 125 BARN SQUARED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ. 125 BARN DIVERSIFIED USES (OFDU) 125 BARN (DISCOUNTED @ 50%) 123.0 SQ.M 1,324.0 SQ.M 126 BARN & LEAN-TO (DISCOUNTED @ 50%) 18.0 SQ.M 193.8 SQ.M 127 BARN & LEAN-TO (DISCOUNTED @ 50%) 160.0 SQ.M 1,722.3 SQ.M 127 BARN & LEAN-TO (DISCOUNTED @ 50%) 160.0 SQ.M 1,722.3 SQ.M 127 BARN & LEAN-TO (DISCOUNTED @ 50%) 160.0 SQ.M 1,722.3 SQ.M 127 BARN & LEAN-TO (DISCOUNTED @ 50%) 160.0 SQ.M 1,722.3 SQ.M 128 BARN & LEAN-TO (DISCOUNTED @ 50%) 160.0 SQ.M 1,722.3 SQ.M 128 BARN & LEAN-TO (DISCOUNTED @ 50%) 160.0 SQ.M 1,722.3 SQ.M 128 BARN & LEAN-TO (DISCOUNTED @ 50%) 160.0 SQ.M 1,722.3 SQ.M	TAL COVERAGE AGEA:		1199.0	SQ.M	12905.9	SQ.FT
36.0 SQ.M 387.5 SQ. 36.0 SQ.M 387.5 SQ. 36.0 SQ.M 1,722.3 SQ. 37.4 Gross Leasable floor area: 442.0 Sq.M 4757.6 SQ. 38.0 Sq.M 4757.6 Sq. 48.0 Sq.M 48.0 Sq. 48.0 Sq.M 48.0 Sq. 48.0 Sq.M	OSS LEASABLE FLOOR AREA:					
### 1,722.3 SQ.IDPOSED ASSOCIATED STRUCTURES (SEASONAL TENT)	RVEST BARN		246.0	SQ.M	2647.9	SQ.FT
ATAL GROSS LEASABLE FLOOR AREA: 442.0 SQ.M 4757.6 SQ.M	EY BARN & LEAN-TO		36.0	SQ.M	387.5	SQ.FT
I-FARM DIVERSIFIED USES (OFDU) ARVEST BARN (DISCOUNTED @ 50%) EY BARN & LEAN-TO (DISCOUNTED @ 50%) EOPOSED ASSOCIATED STRUCTURES (SEASONAL TENT) 123.0 SQ.M 1,324.0 SQ.M 1,324.0 SQ.M 1,722.3 SQ.M 1,722.3 SQ.M	OPOSED ASSOCIATED STRUCTURES (SEASONAL TENT)		160.0	SQ.M	1,722.3	SQ.FT
REY BARN & LEAN-TO (DISCOUNTED @ 50%) 18.0 SQ.M 193.8 SQ.I 10POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ.I	TAL GROSS LEASABLE FLOOR AREA:		442.0	SQ.M	4757.6	SQ.FT
REY BARN & LEAN-TO (DISCOUNTED @ 50%) 18.0 SQ.M 193.8 SQ.I 100POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ.I	-FARM DIVERSIFIED USES (OFDU)				-	
REY BARN & LEAN-TO (DISCOUNTED @ 50%) 18.0 SQ.M 193.8 SQ.I 100POSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ.I	RVEST BARN (DISCOUNTED @ 50%)		123.0	SQ.M	1.324.0	SQ.FT
OPOSED ASSOCIATED STRUCTURES (SEASONAL TENT) 160.0 SQ.M 1,722.3 SQ.	•					
THE ADEA (TOTAL)	•					SQ.FT
DO ANEA (101AE) 301.0 30.01 3,240.0 30.	DU AREA (TOTAL)		301.0	SQ.M	3,240.0	SQ.FT

Storage / Non-Gross Leasable Floor Area

REQUIREMENT

1 PER 18.5 SQ.M

1 PER EMPLOYEE

Gross Leasable Floor Area

1822 NIAGARA STONE ROAD

As Shown 04-12,2024 231150

THIS DRAWING SHALL ONLY BE USED IN CIRCUMSTANCES FOR WHICH IT WAS ORIGINALLY PREPARED AND FOR WHICH NPG PLANNING SOLUTIONS INC. WAS RETAINED.

NPG PLANNING SOLUTIONS INC. DOES NOT TAKE RESPONSIBILITY FOR THE ACCURACY OF THE LOCATIONAL INFORMATION OR OTHER MAPPED FEATURES FROM SECONDARY SOURCES SHOWN ON THIS DRAWING. THE INFORMATION ISSUED MAY BE CONFIDENTIAL AND MUST NOT BE USED OTHER THAN BY THE INTENDED RECIPIENT UNLESS AUTHORIZED BY NPG PLANNING SOLUTIONS INC. NPG PLANNING SOLUTIONS INC. ACCEPTS NO LIABILITY OR RESPONSIBILITY FOR ANY LOSS OR DAMAGE SUFFERED BY THE RECIPIENT ARISING OUT OF, OR IN CONNECTION WITH, THE USE OR MISUSE OF THE INFORMATION ISSUED.

ALL DRAWINGS ARE THE PROPERTY OF NPG PLANNING SOLUTIONS INC. AND MAY NOT BE ALTERED WITHOUT WRITTEN PERMISSION FROM NPG PLANNING SOLUTIONS INC.

DO NOT SCALE THE DRAWING.



Date: 2024-07-26



DOMESTIC WATER USEAGE REQUIREMENTS

Project: 1822 Niagara Stone Road, Niagara-on-the-Lake Method: Fixture Unit Method, Per OBC Table 7.6.3.2.A

Fixtures: The number of fixtures was estimated based on the Site Plan provided

by NPG Planning Solutions dated April 12, 2024.

<u>Amount</u>	Fixture Type	Fixture Units Per	<u>Total</u>
7	Water Closet	2.2	15.4
9	Sink	1.4	12.6
3	Commercial Sink	4.0	12
	Total:		40

1 - Reference Table 7.6.3.2.A, Ontario Building Code

Hydraulic Load: Fixture units are then transferred to Hydaulic Load based on Ontario Building Code Table 7.4.10.5.

Column 1	Column 2	Column 3	Column 4
Fixture Units in service	Max Drainage Rate (Gal/m)		
	Col. 1	Col. 1 × 10	Col. 1 × 100
100	53	174	900
90	51	164	835
80	49 47	153	750
70		140	680
60	44	128	600
50	41	115	520
40	38	102	435
30	33	88	350
20	27	72	262
10	21	53	174

Maximum hydraulic load is estimated to be 38 Imperial Gallons / Minute

40 Fixture Units = 38 Imp Gal/min = 3.03 Lps

The estimated maximum hydraulic load for the proposed buildings is 3.03 Liters per second.

Sizing of Water Service Pipe for Buildings Containing More than One Dwelling Unit

Size and capacity of potable water system pipe shall be designed in accordance with 7.6.3.1, of Division B, of the Ontario Building Code (OBC). Where both hot and cold water is supplied to fixtures in residential buildings containing more than one unit, the water system may be sized in accordance with the tables in Part 1 and Part 2 of this form, provided, the minimum water pressure at the entry to the building is 200 kPa, the total maximum length of the water system is 90 m, and the hydraulic loads for maximum separate demands on water distribution system piping are not less than 100% of the total hydraulic load of the fixture units given in Tables 7.6.3.2.A, 7.6.3.2.B, 7.6.3.2.C and 7.6.3.2.D, of Division B, of the OBC for private use.

Address	Date

PART 1 - Hydraulic Load (Fixture Unit Calculation)

Fixture or Device	Fixture Units	Quantity	Total Hydraulic Load (Fixture Units x Quantity)
Bathroom Group with 6 LPF or less flush tank*	3.6		
Rough-in Bathroom Group with 6 LPF or less flush tank*	3.6		
Clothes washer	1.4		
Dishwasher (domestic)	1.4		
Hose bibb (1/2")	2.5		
Lavatory	0.7		
Shower head	1.4		
Shower, spray, multi-head, fixture unit per head	1.4		
Sink, bar	1		
Sink, kitchen	1.4		
Sink, laundry	1.4		
Water Closet (6 LPF or less with flush tank)	2.2		
Other: Commercial Sink			
Total Fixture Units			

(Fixture Units from Table 7.6.3.2.A, of Division B of the OBC)

PART 2 - Sizing of Water Service Pipe

0:	1	Water Velocity (m/s)
Size of Water	2.4 (copper piping, cold water)	Other Pipe Material*:
Pipe	Hydra	aulic Load (Fixture Units)
1/2"	Up to 7	
3/4"	7.1 to 16	
1"	16.1 to 31	
11/4"	31.1 to 57	

(Above information obtained from Table 7.6.3.4, of Division B of the OBC)


PART 3 - Design of Water Service Pipe

Total Hydraulic Load (fixture units):	Water Meter Size
Water Service Pipe size Existing (inches) & Proposed (inches)	3/4" Water Service Pipe = 5/8" (16 mm) Water Meter 1" Water Service Pipe = 3/4" (21 mm) Water Meter 11/4" Water Service Pipe = 1" (25 mm) Water Meter
Designer Information	·

Designer information		
Name	BCIN	Signature

^{*} Bathroom group consists of 1 water closet, 1 basin (lavatory), and 1 bathtub or 1 shower.

^{*} If a water velocity of other than 2.4 m/s is proposed, provide documentation showing maximum permitted water velocity with maximum hydraulic loads for each water pipe size as recommended by the pipe and fitting manufacturer.



	Route #:
R	Comp. Acct. #: R11304 (6)1 # 267702001205901 # 262702001205900 1822 NIAGADA STANE RA
	LOT #:
(OWNER: HARVEST BARN DATE INSTALLED: AUGUST 20, 2003
	SERVICE SIZE: 25 mm & TYPE 'K'
	METER SIZE:
	METER SERIAL #:
	E.C.R. #:
(,	CHAMBER: N0 ANODE: 12 LB

