



On The Lake Developments Inc.

# NOISE IMPACT STUDY

Proposed Mixed-Use Development

**1544 & 1546 Four Mile Creek Road  
Town of Niagara-on-the-Lake**

December 2025  
25253



**LEA Consulting Ltd.**  
625 Cochrane Drive, 5<sup>th</sup> Floor  
Markham, ON, L3R 9R9 Canada  
T | 905 470 0015 F | 905 470 0030  
WWW.LEA.CA

December 18, 2025

**Reference Number:** 25253 - 1544 & 1546 Four Mile  
Creek Rd, Niagara-on-the-Lake  
(Noise)

**On The Lake Developments Inc.**  
976 Four Mile Creek Road,  
Niagara-on-the-Lake, ON L0S 1J0  
Attn: Stephen Aghaei, Associate  
Email: [stephen@timegroup.ca](mailto:stephen@timegroup.ca)

**RE: Noise Impact Study  
Proposed Residential and Commercial Development  
1544 & 1546 Four Mile Creek Road, Town of Niagara-on-the-Lake**

Dear Mr. Aghaei:

LEA Consulting Ltd. is pleased to present the findings of this Noise Impact Study (NIS) for the proposed residential and commercial development located at the municipal address 1544 & 1546 Four Mile Creek Road, in the Town of Niagara-on-the-Lake.

The report concludes that no noise mitigation measures are recommended or need to be implemented for the subject site.


Should you have any questions regarding this NIS, please do not hesitate to contact us.

Yours truly,

**LEA CONSULTING LTD.**

  
Daniel Eduardo Adarve Villanueva, P. Eng.  
Project Manager  
Noise and Vibration Engineer



  
Ian Dinsmore  
Noise and Vibration Technologist

Encl.

## Revision History

| Rev. No. | Description  | Author       | Reviewed By                      | Date              |
|----------|--------------|--------------|----------------------------------|-------------------|
| 1        | Draft Report | Ian Dinsmore | Daniel Eduardo Adarve Villanueva | October 23, 2025  |
| 2        | Final Report | Ian Dinsmore | Daniel Eduardo Adarve Villanueva | December 10, 2025 |
|          |              |              |                                  |                   |

## Distribution List

| No. of Copies | Association / Company         | Note |
|---------------|-------------------------------|------|
| 1             | On The Lake Developments Inc. | PDF  |
|               |                               |      |

## Disclaimer

*This Report represents the work of LEA Consulting Ltd ("LEA") solely for the client identified above and is to be used exclusively for the purpose set out in the Report. This Report may not be relied upon for detailed implementation, or any other purpose not specifically identified within this Report. The material in this Report reflects the judgment of LEA based on the information available to them at the time of preparation. Unless manifested incorrectly, LEA assumes information provided by others is accurate. Changed conditions or information occurring or becoming known after the date of this report could affect the results and conclusions presented. Unless otherwise required by law or regulation, this Report shall not be shared with any third party without the written consent of LEA. This Document is confidential and prepared solely for the use of On The Lake Developments Inc. Neither LEA, its sub-consultants nor their respective employees assume any liability for any reason, including, but not limited to, negligence, to any party other than On The Lake Developments Inc. for any information or representation herein. This report permits the Town of Niagara-on-the-Lake to make reliance on the findings and conclusions presented in the report.*

## TABLE OF CONTENTS

|          |   |           |
|----------|---|-----------|
| <b>1</b> | <b>Introduction .....</b>                                       | <b>2</b>  |
| <b>2</b> | <b>Noise Sources .....</b>                                      | <b>2</b>  |
| 2.1      | <i>Transportation Noise Sources.....</i>                        | 2         |
| 2.1.1    | Road Traffic .....  | 2         |
| 2.1.2    | Rail Sources .....  | 2         |
| 2.1.3    | Air Traffic.....  | 2         |
| 2.2      | <i>Stationary Noise Sources.....</i>                            | 2         |
| <b>3</b> | <b>Noise Criteria .....</b>                                     | <b>3</b>  |
| 3.1      | <i>Transportation Noise .....</i>                               | 3         |
| 3.1.1    | Indoors.....  | 3         |
| 3.1.2    | Outdoors .....  | 4         |
| 3.2      | <i>Stationary Noise.....</i>                                    | 4         |
| <b>4</b> | <b>Noise Impact Assessment.....</b>                             | <b>5</b>  |
| 4.1      | <i>Transportation Noise Assessment.....</i>                     | 5         |
| 4.1.1    | Road Traffic Data .....   | 5         |
| 4.1.2    | Transportation Noise Predictions.....                           | 6         |
| 4.2      | <i>Stationary Noise Assessment.....</i>                         | 7         |
| 4.2.1    | Environment to Subject Site (External Noise Sources) .....      | 7         |
| 4.2.2    | Subject Site to Environment (Internal Noise Sources) .....      | 8         |
| 4.2.3    | Stationary Noise Data .....                                     | 9         |
| 4.2.4    | Niagara-on-the-Lake Municipal Truck Yard Activities .....       | 10        |
| 4.2.5    | Stationary Noise Predictions.....                               | 11        |
| <b>5</b> | <b>Noise Abatement Requirements .....</b>                       | <b>12</b> |
| 5.1      | <i>Indoor Living Areas and AC/Ventilation Requirements.....</i> | 12        |
| 5.1.1    | Building Façade Constructions .....                             | 12        |
| 5.1.2    | Ventilation Requirements.....                                   | 13        |
| <b>6</b> | <b>Conclusions &amp; Recommendations .....</b>                  | <b>14</b> |
| <b>7</b> | <b>Warning Clauses.....</b>                                     | <b>15</b> |
| <b>8</b> | <b>References .....</b>   | <b>16</b> |

## LIST OF TABLES AND FIGURES

|   |    |
|---|----|
| Table 1: MECP Sound Level Limits for Indoor Spaces .....  | 3  |
| Table 2: MECP Ventilation Requirements.....   | 4  |
| Table 3: MECP Sound Level Limits for Outdoor Living Area.....   | 4  |
| Table 4: MECP Sound Level Limits (1-hour Equivalent) for Stationary Noise Sources in Class 2 Area.....  | 4  |
| Table 5: Summary of Traffic Data .....  | 5  |
| Table 6: Predicted (Unattenuated) Transportation Sound Levels (Plane of Window).....  | 6  |
| Table 7: Receptor Details for Stationary Noise Assessment .....   | 8  |
| Table 8: Receptor Details for Stationary Noise Assessment – Subject Area .....  | 8  |
| Table 9: Summary of Sound Level Exclusion Limits .....  | 9  |
| Table 8: HVAC RTUs Octave Band Sound Power Data .....   | 9  |
| Table 11: Niagara-on-the-Lake Municipal Truck Yard Activities Octave Band Sound Power Data.....   | 11 |
| Table 12: Predicted Stationary Noise Impact Levels.....   | 11 |
| Table 13: Predicted Stationary Noise Impact Levels (Emergency Generator).....   | 12 |
|   |    |
| Figure 1: Key Plan showing Site Location and Area   |    |
| Figure 2: Transportation Noise Receptor Locations – Site Plan   |    |
| Figure 3: Receptor Locations and Unmitigated Noise Impact Contours at 4.5 m height, Daytime (7:00 – 19:00), Environment to Subject Site (External Noise Sources)  |    |
| Figure 4: Receptor Locations and Unmitigated Noise Impact Contours at 4.5 m height, Daytime (07:00 – 19:00), Subject Site to Environment (Internal Noise Sources) |    |
| Figure 5: Receptor Locations and Noise Impact Contours at 4.5 m height, Daytime (07:00 – 19:00), Generator Testing and Maintenance Operations                     |    |

## APPENDICES

|                   |                                    |
|-------------------|------------------------------------|
| <b>APPENDIX A</b> | <b>COPY OF THE SITE PLAN</b>       |
| <b>APPENDIX B</b> | <b>TRAFFIC DATA</b>                |
| <b>APPENDIX C</b> | <b>DETAILED STAMSON ANALYSIS</b>   |
| <b>APPENDIX D</b> | <b>CADNA/A SAMPLE CALCULATIONS</b> |

## SUMMARY

LEA Consulting Ltd. (LEA) has been retained by On The Lake Developments Inc. to prepare a Noise Impact Study (NIS) in support of the proposed residential, commercial and office development located at 1544 & 1546 Four Mile Creek Road in the Town of Niagara-on-the-Lake. This study examined the future noise environment in the development area and evaluated its impact potential on future noise-sensitive receptors. Transportation noise assessment was accomplished based on the Ontario Road Noise Analysis Method for Environment and Transportation (ORNAMENT) using the Ontario Ministry of the Environment, Conservation and Parks (MECP) STAMSON noise prediction software. The stationary sound level predictions were modelled using the computer software Cadna/A, which incorporates the MECP-approved ISO 9613-2 method of prediction. Based on the analysis, the noise impact from the environment on the proposed development is within the applicable MECP limits. Mitigative measures are not required to meet the MECP limits.

### Transportation Noise Sources – Outdoor:

- ▶ No mitigation measures are required for OLA points of reception affected by road noise sources.

### Transportation Noise Sources – Indoor:

- ▶ OBC-compliant exterior window and wall construction are sufficient for the mixed-use development on all façades of the proposed residential and commercial/office buildings;
- ▶ The office units on the northerly, easterly and southerly façades of the proposed development must be provided with forced-air heating with the provision for future air-conditioning and should include Warning Clause Type 'C' in its Agreements of Purchase/Sale or Lease/Rental agreements. However, it is anticipated that the development will provide a central air conditioning system; thus, the forced-air heating with the provision for future air-conditioning is expected to be met; and
- ▶ Should any of the plans or information used in the completion of this report change, a detailed review should be completed by an acoustical consultant to ensure the sound level limits are met.

### Stationary Noise Sources:

- ▶ No mitigation measures are required for points of reception affected by stationary noise sources; and
- ▶ No mitigation measures are required for points of reception affected by the emergency generator.

# 1 INTRODUCTION

LEA Consulting Ltd. (LEA) has been retained by On The Lake Developments Inc. to prepare a Noise Impact Study (NIS) in support of the proposed residential, commercial and office development located at 1544 & 1546 Four Mile Creek Road in the Town of Niagara-on-the-Lake.

The proposed development has an approximate total Gross Floor Area (GFA) of 14,418 m<sup>2</sup> and is currently occupied by two (2) single-detached dwellings. The proposed development consists of a five (5) storey residential building with a GFA of 6,433 m<sup>2</sup>, a two (2) storey commercial/office building with a GFA of 7,985 m<sup>2</sup>, and surface-level parking spaces, which include one (1) level of below-grade parking.

The subject site is located on the western side of Four Mile Creek Road, north of Line 2 Road. The surrounding land is mixed-use, including residential buildings to the south and east, commercial buildings and sports facilities to the north, and commercial, industrial, and residential buildings to the west.

This study examined the existing and future noise environment in the development area and evaluated its potential impact on future noise-sensitive receptors. This report investigates the noise control measures that are required in order for the development to meet the noise guidelines of the Ontario Ministry of the Environment, Conservation and Parks (MECP) and to satisfy the requirements of the Town of Niagara-on-the-Lake. This noise report is based on the methodology and approach outlined in the MECP guideline NPC-300 “*Stationary and Transportation Sources – Approval and Planning*” (August 2013).

**Figure 1** provides a key plan showing the location of the proposed development.

This report is based on the site plan prepared by Icke Brochu Architects Inc., dated December 5<sup>th</sup>, 2025. A copy of the site plan is shown in **Appendix A**.

## 2 NOISE SOURCES

### 2.1 TRANSPORTATION NOISE SOURCES

#### 2.1.1 Road Traffic

Vehicular traffic along Four Mile Creek Road and Niagara Stone Road are the dominant sources of transportation noise that could impact the subject site. Due to the low vehicular traffic on Line 2 Road, it was deemed acoustically insignificant and will no longer be included in this study.

#### 2.1.2 Rail Sources

This development is not impacted by rail noise sources.

#### 2.1.3 Air Traffic

The development is not impacted by aircraft noise sources.

### 2.2 STATIONARY NOISE SOURCES

As indicated in the client-provided architectural plans, the Heating, Ventilation, and Air Conditioning (HVAC) Rooftop Units (RTUs) systems related to the proposed development will not all be contained inside a

mechanical penthouse. Twelve (12) HVAC units and one (1) emergency generator will sit on the rooftop, surrounded by a two (2) metre high barrier. Thus, the subject site will include stationary noise sources that could impact the nearby noise-sensitive areas or itself.

Our preliminary review indicated that the site may be impacted by noise generated from the rooftop Heating, Ventilation, and Air Conditioning (HVAC) units related to the existing buildings surrounding the subject site. In addition, the site may be impacted by the Niagara-on-the-Lake Municipal Works Yard operations of the front loader and dump trucks. These have been identified as the dominant potential sources of stationary noise that could impact the noise-sensitive areas of the proposed development. Accordingly, a stationary noise assessment was also conducted.

It is also noted that Whirlpool Jet Boat Tours (7 Henegan Road) is a commercial site located approximately a hundred and fifty (150) metres west of the Subject Site that may have operations that could affect the proposed development. Given the type of onsite business operations and infrequent activity, its potential impact on the assessed receptors can be considered acoustically negligible and does not warrant a further detailed noise assessment. The remaining facilities to the west of the Subject Site are also commercial and industrial sites, and additional noise modelling details will also be excluded from the noise assessment due to acoustically low, infrequent activity. However, the study identified and included HVAC RTUs located on these commercial and industrial facilities.

## 3 NOISE CRITERIA

### 3.1 TRANSPORTATION NOISE

#### 3.1.1 Indoors

The indoor noise level impact due to road traffic was examined as per the noise criteria outlined in the MECP guidelines. The indoor sound level limit due to road traffic for a living or dining room area during the daytime (07:00-23:00) and nighttime (23:00-07:00) hours are a  $L_{eq-16hr}$  and  $L_{eq-8hr}$  of 45 dBA, respectively. The indoor sound level limit due to road traffic for a bedroom during the daytime is a  $L_{eq-16hr}$  of 45 dBA and during the nighttime hours is an  $L_{eq-8hr}$  of 40 dBA. To satisfy the limits set out by the MECP guidelines, the MECP has provided a basis for the type of windows, doors, and exterior walls that will be required based on projected outdoor noise levels.

The required limits as per NPC-300 guidelines are summarised in **Table 1**. Moreover, the ventilation requirements from transportation noise sources as per NPC-300 guidelines are presented in **Table 2**.

Table 1: MECP Sound Level Limits for Indoor Spaces

| Type of Space                          | Time Period   | Sound Level Limits                 |
|--|---------------|------------------------------------|
|  |               | Road                               |
| Living/Dining, Den Areas of Residences | 07:00 – 23:00 | $L_{eq(16\text{ hours})}$ : 45 dBA |
|  | 23:00 – 07:00 | $L_{eq(8\text{ hours})}$ : 45 dBA  |
| Sleeping quarters                      | 07:00 – 23:00 | $L_{eq(16\text{ hours})}$ : 45 dBA |
|  | 23:00 – 07:00 | $L_{eq(8\text{ hours})}$ : 40 dBA  |

Table 2: MECP Ventilation Requirements

| Plane of Window Sound Level ( $L_{eq}$ ) | Ventilation Requirement   | Warning Clause Requirement |
|--|---|----------------------------|
| <b>Daytime (07:00 to 23:00)</b>          |   |                            |
| ≤55 dBA                                  | None  | None                       |
| 55 ≤65 dBA                               | Forced air heating with provisions for the installation of central air conditioning | Recommended                |
| > 65 dBA                                 | Central air conditioning  | Required                   |
| <b>Nighttime (23:00 to 07:00)</b>        |   |                            |
| ≤50 dBA                                  | None  | None                       |
| 50 ≤60 dBA                               | Forced air heating with provisions for the installation of central air conditioning | Recommended                |
| > 60 dBA                                 | Central air conditioning  | Required                   |

### 3.1.2 Outdoors

Guidelines set out by the MECP recommend that equivalent noise levels (i.e.,  $L_{eq-16hr}$ ) in outdoor living areas should not exceed 55 dBA. If the predicted  $L_{eq-16hr}$  is greater than 60 dBA, noise control measures should be implemented to reduce the level to 55 dBA. If it is not technically, economically, or administratively feasible to achieve a level of 55 dBA, noise levels between 55 dBA and 60 dBA may be acceptable, provided that the future occupants of the dwellings are made aware of the potential noise problems through a warning clause. The required limits are summarised in **Table 3**.

Table 3: MECP Sound Level Limits for Outdoor Living Area

| Type of Space             | Time Period   | Sound Level Limits  |   |
|---------------------------|---------------|---|---|
|                           |               | Road  | Rail  |
| Outdoor Living Area (OLA) | 07:00 – 23:00 | $L_{eq}$ (16 hours): 55 dBA (may consider noise control measures) | $L_{eq}$ (16 hours): 60 dBA (noise control measures are required) |

## 3.2 STATIONARY NOISE

The noise assessment criteria for stationary noise are based on the Ministry of the Environment, Conservation and Parks (MECP) Publication NPC-300 “*Environmental Noise Guideline, Stationary and Transportation Sources - Approval and Planning*” dated 2013.

In accordance with the MECP Guideline NPC-300, the surrounding area is considered to be located in a Class 2 acoustical environment. In a Class 2 area, the background sound levels during the daytime (07:00 to 19:00) periods are dominated by the activities of people; usually, road traffic often referred to as “urban hum”. However, the background sound levels in a Class 2 area during the evening (19:00 to 23:00) and nighttime (23:00 to 07:00) hours are defined by the natural environment and infrequent human activities. The sound level limits for stationary noise sources are summarised in **Table 4** below.

Table 4: MECP Sound Level Limits (1-hour Equivalent) for Stationary Noise Sources in Class 2 Area

| Time Period                 | Time of Day             | Class 2 Area - Sound Level Limits <sup>1</sup><br>$L_{eq-1hr}$ (dBA) |
|-----------------------------|-------------------------|--|
| Outdoor Points of Reception | 07:00 – 19:00 (Daytime) | 50   |
|                             | 19:00 – 23:00 (Evening) | 45   |

| Time Period                                  | Time of Day             | Class 2 Area - Sound Level Limits <sup>1</sup> |
|--|-------------------------|--|
|  |                         | $L_{eq-1hr}$ (dBA)                             |
| Plane of Window of<br>Noise Sensitive Spaces | 07:00 – 19:00 (Daytime) | 50   |
|  | 19:00 – 23:00 (Evening) | 50   |
|  | 23:00-07:00 (Nighttime) | 45   |

(1) or the minimum existing hourly background level  $L_{eq}$ , whichever is higher

The MECP sound level limit is determined by the exclusion limit listed above in **Table 4** or the minimum hourly equivalent background sound level, whichever is higher.

## 4 NOISE IMPACT ASSESSMENT

### 4.1 TRANSPORTATION NOISE ASSESSMENT

As noted in **Section 2.1.1**, the study area's dominant transportation traffic noise source is traffic noise generated by Niagara Stone Road and Four Mile Creek Road. Niagara Stone Road is located to the north of the subject site with a posted speed limit of 50 km/h. Four Mile Creek Road is located to the east of the subject site with a posted speed limit of 50 km/h to the north of Line 2 Road and 60 km/h to the south of Line 2 Road.

Noise level calculations were performed in accordance with the methodology outlined in MECP guidelines, including the Ontario Road Noise Analysis Method for Environment and Transportation (ORNAMENT).

#### 4.1.1 Road Traffic Data

LEA personnel collected traffic data related to Niagara Stone Road and Four Mile Creek Road on Tuesday, December 17, 2024. Traffic data was also collected at Four Mile Creek Road, Arena Road, Four Mile Creek Road and Line 2 Road. The highest traffic volumes at Niagara Stone Road and Four Mile Creek Road were used in the analysis. As requested by the Township, this data was escalated to the year 2044, a twenty (20) year horizon for regional roads, with a yearly growth rate of 2%.

The medium/heavy truck percentages were calculated using turning movement counts dated December 17, 2024, for the Niagara Stone Road and Four Mile Creek Road intersection during the weekday AM and PM peak periods, respectively. All buses were considered to be medium trucks, while the heavy/medium truck split within the "trucks" classification was determined based on the "*Ministry of Transportation Ontario (MTO) Environmental Guide for Noise*", dated February 2022. The day/night traffic volume splits were assumed to be ninety (90) per cent in the day and ten (10) per cent at night. All roadways were modelled as one (1) segment for the purpose of STAMSON transportation analysis. Sound level distance adjustments were applied to receptors wherever applicable.

Road traffic noise predictions were based on the road traffic data outlined in **Table 5**. Road traffic data is included in **Appendix B**.

Table 5: Summary of Traffic Data

| Traffic Data         | Future AADT | Day/Night Ratio    | Percentage of Medium Trucks | Percentage of Heavy Trucks | Posted Speed Limit |
|----------------------|-------------|--------------------|-----------------------------|----------------------------|--------------------|
| Niagara Stone Road   | 15,677      | 90/10 <sup>1</sup> | 0.33%                       | 0.52%                      | 50 km/h            |
| Four Mile Creek Road | 7,563       | 90/10 <sup>1</sup> | 0.96%                       | 1.53%                      | 50 & 60 km/h       |

(1) Assumed

#### 4.1.2 Transportation Noise Predictions

Noise impact assessments on the proposed development were performed with consideration of the predicted future volume of traffic. Daytime and nighttime impacts from transportation noise were investigated. Distance adjustment corrections were applied wherever applicable.

As noted in **Section 1**, the proposed development consists of a four (4) storey residential building with one (1) level of below-grade parking spaces and a two (2) storey commercial/office building. The latest site plan identified three (3) areas that can be considered an Outdoor Living Area (OLA) that may be negatively impacted by road traffic. The residential patio is located between the commercial and residential building near the parking lot, the rooftop pool and the 3<sup>rd</sup> and 4<sup>th</sup> floor balconies on the west façade of the residential building, which are greater than four (4) metres in depth. Therefore, OLA receptors were considered for the proposed development.

It should be noted that a balcony/terrace that is less than four (4) meters in depth and commercial use patios are not considered an OLA in accordance with the MECP NPC-300 noise guidelines. It is also noted that there is a playground located at-grade to the north of the residential development, however, the play area will be used for gymnasium activities and not for the quiet enjoyment of the outdoors. Therefore, an OLA receptor was not included for the playground. The locations of the façade receptors are shown in **Figure 2**.

**Table 6** shows the unattenuated daytime and nighttime predicted  $L_{eq}$ 's due to road traffic at the noise-sensitive receptors within the proposed development. Nighttime  $L_{eq}$ 's are only required for sleeping quarters; therefore, the commercial and office receptors do not include nighttime noise level values. Receptors near Line 2 Road were modelled with two (2) segments for Four Mile Creek Road due to the change in posted speed on Four Mile Creek Road to the south of Line 2 Road. Façade receptors are labelled as R01 to R10 in **Figure 2**. Detailed sound-level calculations are provided in **Appendix C**.

Table 6: Predicted (Unattenuated) Transportation Sound Levels (Plane of Window)

| Receptor | Receptor Height (m) | Description                                   | Source                        | Distance (m) | Overall $L_{eq}$ (dBA) Day | Overall $L_{eq}$ (dBA) Night |
|----------|---------------------|---|-------------------------------|--------------|----------------------------|------------------------------|
| R01      | 13.05 <sup>1</sup>  | Residential Building North Façade             | Niagara Stone Road            | 280          | 55                         | 49                           |
|          |                     |   | Four Mile Creek Road          | 51           |                            |                              |
| R02      | 13.05 <sup>1</sup>  | Residential Building West Façade North Corner | Niagara Stone Road            | 284          | 48                         | 41                           |
| R03      | 13.05 <sup>1</sup>  | Residential Building South Façade             | Four Mile Creek Road          | 72           | 52                         | 44                           |
|          |                     |   | Four Mile Creek Road (60km/h) | 123          |                            |                              |
| R04      | 7.00 <sup>2</sup>   | Office Building North Façade East Corner      | Niagara Stone Road            | 280          | 60                         | -                            |
|          |                     |   | Four Mile Creek Road          | 15           |                            |                              |
| R05      | 7.00 <sup>2</sup>   | Office Building West Façade                   | Four Mile Creek Road          | 25           | 54                         | -                            |
|          |                     |   | Four Mile Creek Road (60km/h) | 73           |                            |                              |
| R06      | 7.00 <sup>2</sup>   | Office Building South Façade                  | Four Mile Creek Road          | 14           | 60                         | -                            |
|          |                     |   | Four Mile Creek Road (60km/h) | 68           |                            |                              |

| Receptor | Receptor Height (m) | Description   | Source                        | Distance (m) | Overall $L_{eq}$ (dBA) Day | Overall $L_{eq}$ (dBA) Night |
|----------|---------------------|---|-------------------------------|--------------|----------------------------|------------------------------|
| R07      | 7.00 <sup>2</sup>   | Office Building East North Corner Façade                | Niagara Stone Road            | 304          | 63                         | -                            |
|          |                     |   | Four Mile Creek Road          | 12           |                            |                              |
|          |                     |   | Four Mile Creek Road (60km/h) | 144          |                            |                              |
| R08      | 7.00 <sup>2</sup>   | Office Building East Façade South Corner                | Niagara Stone Road            | 385          | 63                         | -                            |
|          |                     |   | Four Mile Creek Road          | 11           |                            |                              |
|          |                     |   | Four Mile Creek Road (60km/h) | 76           |                            |                              |
| R09      | 7.00 <sup>2</sup>   | Office Building North Façade West Corner                | Niagara Stone Road            | 281          | 56                         | -                            |
|          |                     |   | Four Mile Creek Road          | 29           |                            |                              |
| R10      | 13.05 <sup>1</sup>  | Residential Building West Façade South Corner           | Niagara Stone Road            | 350          | 47                         | 41                           |
| OLA01    | 13.05 <sup>1</sup>  | Residential Building 4 <sup>th</sup> Floor West Balcony | Niagara Stone Road            | 286          | 47                         | -                            |
| OLA02    | 1.5                 | At-Grade Residential Patio                              | Niagara Stone Road            | 320          | 51                         | -                            |
|          |                     |   | Four Mile Creek Road          | 44           |                            |                              |
|          |                     |   | Four Mile Creek Road (60km/h) | 83           |                            |                              |
| OLA03    | 17.65 <sup>3</sup>  | Rooftop Pool  | Niagara Stone Road            | 320          | 48                         | -                            |
|          |                     |   | Four Mile Creek Road          | 44           |                            |                              |

(1) Based on the residential building Level 4 elevation of 11.55 metres plus receptor height of 1.5 metres.

(2) Based on the office building level 2 elevation of 5.5 metres plus receptor height of 1.5 metres.

(3) Based on the Residential building rooftop elevation of 16.15 metres plus receptor height of 1.5 metres.

## 4.2 STATIONARY NOISE ASSESSMENT

The stationary noise assessment is based on the ISO 9613-2 standard: “Acoustics-Attenuation of sound during propagation outdoors – Part 2: General method of calculation” (1996). Sound levels due to sources of stationary sound were calculated using the Cadna/A computer software, Version 2020.

### 4.2.1 Environment to Subject Site (External Noise Sources)

Based on our review of aerial photography of the area, the noise generated from the rooftop HVAC RTUs related to the existing mixed-use buildings in the proximity of the subject site may have an adverse impact on the noise-sensitive spaces within the site, and a stationary noise assessment is required.

Sound levels were modelled for the worst-case daytime and nighttime hour at the noise-sensitive receptors wherever noise exposure was considered maximum. Locations of the critical noise receptors are shown in **Figure 3**. The details related to the receptor locations and heights used in the assessment are summarised in **Table 7**. The directivity of noise emission for applicable noise sources was considered. Sample calculations are available in **Appendix D**.

Table 7: Receptor Details for Stationary Noise Assessment

| Receptor | Description   | Receptor Elevation (m) |
|----------|---|------------------------|
| RP01     | Residential Building North Façade                       | 13.05 <sup>1</sup>     |
| RP02     | Residential Building West Façade                        | 13.05 <sup>1</sup>     |
| RP03     | Residential Building South Façade                       | 13.05 <sup>1</sup>     |
| RP04     | Office Building North Façade                            | 7.00 <sup>2</sup>      |
| RP05     | Office Building West Façade                             | 7.00 <sup>2</sup>      |
| RP06     | Office Building South Façade                            | 7.00 <sup>2</sup>      |
| RP07     | Office Building East Façade                             | 7.00 <sup>2</sup>      |
| RP08     | Residential Building 4 <sup>th</sup> Floor West Balcony | 13.15 <sup>1</sup>     |
| RP09     | At-Grade Residential Patio                              | 1.50                   |
| RP10     | Rooftop Pool  | 17.65 <sup>3</sup>     |

(1) Based on the residential building Level 4 elevation of 11.55 metres plus receptor height of 1.5 metres.

(2) Based on the office building level 2 elevation of 5.5 metres plus receptor height of 1.5 metres.

(3) Based on the Residential building rooftop elevation of 16.15 metres plus receptor height of 1.5 metres.

No additional stationary noise sources were identified. Further details regarding the above-noted stationary noise sources are provided below.

#### 4.2.2 Subject Site to Environment (Internal Noise Sources)

As stated before, in **Section 2.2**, the HVAC RTUs systems related to the proposed development will not all be contained inside a mechanical penthouse/room and will sit on the rooftop. Twelve (12) HVAC units and one (1) emergency generator will sit on the rooftop, surrounded by a two (2) metre high barrier. Thus, the subject site will include stationary noise sources that could impact the nearby noise-sensitive areas.

No additional stationary noise sources were identified. Further details regarding the above-noted stationary noise sources are provided below in **Section 4.2.3**.

There are existing residential uses located in each direction of the Subject Site. Locations of the subject area's critical noise receptors are shown in **Figure 4**. The details related to the receptor locations and heights used in the assessment are summarised in **Table 7**.

Table 8: Receptor Details for Stationary Noise Assessment – Subject Area

| Receptor | Description                            | Receptor Elevation (m) |
|----------|--|------------------------|
| RP11     | Existing 1 Storey Residential Dwelling | 1.5                    |
| RP12     | Existing 1 Storey Residential Dwelling | 1.5                    |
| RP13     | Existing 1 Storey Residential Dwelling | 1.5                    |
| RP14     | Potential 4 Storey Mixed-Use Building  | 1.5                    |

As stated in **Section 3.2**, the surrounding area is considered to be located in a Class 2 acoustical environment. In a Class 2 area, the background sound levels during the daytime (07:00 to 19:00) periods are dominated by the activities of people; usually, road traffic often referred to as “urban hum”. However, the background sound levels in a Class 2 area during the evening (19:00 to 23:00) and nighttime (23:00 to 07:00) hours are defined

by the natural environment and infrequent human activities.

The MECP exclusion limits for each receptor are summarised in **Table 9** below:

Table 9: Summary of Sound Level Exclusion Limits

| Receptor     | Daytime (07:00-23:00) | Nighttime (23:00-07:00) |
|--------------|-----------------------|-------------------------|
| RP01 to RP14 | 50 dBA                | 45 dBA                  |

The MECP sound level limit is determined by the exclusion limit listed above or the minimum hourly equivalent background sound level, whichever is higher.

#### 4.2.3 Stationary Noise Data

As mentioned in **Section 2.2** of this report, the impact of RTUs mounted on the rooftop of the existing buildings in proximity to the subject site, as well as the HVAC RTUs and emergency generator that will sit on top of the rooftop within the subject site were investigated.

Through the provided mechanical plans, LEA was able to acquire the exact model number for the proposed development RTUs and emergency generator. Reference sound power data related to the HVACs mounted on the rooftop of the subject site were obtained from the manufacturer.

Reference sound power data related to the HVAC mounted on the rooftop of the existing buildings surrounding the subject site were obtained from the manufacturer. As LEA was unable to obtain the exact model number of the existing RTUs, the RTU reference data was conservatively selected based on the RTUs with the largest tonnage, given the number of observed fans. For example, an RTU with three (3) fans and a medium footprint was observed in the existing residential building to the east of the proposed development, and one of the smaller RTUs with three (3) fans for a building with that GFA is thirty (30) tons. Thus, a thirty (30) ton RTU was selected to model sound levels at the existing residential building. For the purposes of the noise assessment, conservatively, the duty cycles for all the rooftop mechanical equipment, including HVAC RTUs related to the surrounding buildings, were assumed to be a hundred (100) per cent during daytime hours (07:00-19:00) and evening hours (19:00-23:00) and fifty (50) per cent during the nighttime hours (23:00-07:00). The sound data inputs utilised for this noise modelling assessment are shown in **Table 10**.

Table 10: HVAC RTUs Octave Band Sound Power Data

| Source ID   | Description     | Octave Band Linear Sound Power Level (dB) |        |        |         |         |         |         | Overall Sound Power Level (dBA) |
|---|-----------------|---|--------|--------|---------|---------|---------|---------|---------------------------------|
|   |                 | 125 Hz                                    | 250 Hz | 500 Hz | 1000 Hz | 2000 Hz | 4000 Hz | 8000 Hz |                                 |
| S09, S12, S16, S17, S22, S23, S29, S30, S38                   | HVAC RTU 10 Ton | 92  | 88     | 87     | 83      | 79      | 72      | 67      | 88                              |
| S05-S08, S10, S11, S15, S18-S21, S26, S27, S31, S32, S34, S35 | HVAC RTU 15 Ton | 96  | 93     | 90     | 89      | 84      | 77      | 71      | 93                              |
| S14, S24, S25, S28, S36                                       | HVAC RTU 20 Ton | 77  | 81     | 87     | 89      | 86      | 80      | 67      | 92                              |
| S13   | HVAC RTU 25 Ton | 91  | 89     | 86     | 82      | 79      | 76      | 72      | 88                              |
| S01-S04   | HVAC RTU 30 Ton | 90  | 88     | 86     | 82      | 80      | 77      | 73      | 88                              |
| S33   | HVAC RTU 50 Ton | 94  | 92     | 90     | 87      | 84      | 80      | 75      | 92                              |

| Source ID | Description         | Octave Band Linear Sound Power Level (dB) |        |        |         |         |         |         | Overall Sound Power Level (dBA) |
|-----------|---------------------|---|--------|--------|---------|---------|---------|---------|---------------------------------|
|           |                     | 125 Hz                                    | 250 Hz | 500 Hz | 1000 Hz | 2000 Hz | 4000 Hz | 8000 Hz |                                 |
| S37, S39  | Cooling Tower       | 86  | 80     | 83     | 76      | 74      | 73      | 62      | 83                              |
| S44-S55   | Heating/Cooling RTU | 79  | 78     | 78     | 77      | 72      | 69      | 62      | 81                              |
| S56       | Emergency Generator | 72  | 60     | 67     | 55      | 49      | 41      | 38      | 90                              |

#### 4.2.4 Niagara-on-the-Lake Municipal Truck Yard Activities

As mentioned in **Section 2.2** of this report, the impact of the NOTL Municipal Truck Yard in proximity to the subject site was investigated.

Through communication with NOTL staff, it was determined that trucks operate between 7:00 a.m. to 4:00 p.m. and that trucks will not operate during nighttime hours, outside of an emergency. It was outlined that on a worse-case day, they will have up to twenty-four (24) truck passbys. Based on that information, conservatively, three (3) fifteen (15) ton dump trucks and one (1) five (5) ton dump truck passby were modelled on the truck route to/from the site outlined by NOTL staff. Thus, truck activity noise was modelled using the subsequent volumes:

- ▶ Three (3) inbound and outbound fifteen (15) ton dump trucks per hour during the daytime hour at the main yard and loading area; and
- ▶ One (1) inbound and outbound five (5) ton dump truck per hour during the daytime hour at the main yard and loading area.

LEA personnel conducted a site visit on September 5<sup>th</sup>, 2025, to collect sound power data of the typical works within the yard. Truck passbys and the typical work cycle of the loading and unloading of dirt, gravel and large rock with a front loader, a fifteen (15) ton dump truck and a five (5) ton dump truck were measured to get the values show in **Table 11**. The worst-case measurements were used to model each type of aggregate that is typically loaded on-site. Conservatively, it was modelled to have loading activity happen for the entire worst-case hour. Thus, loading activity was modelled using the following parameters:

- ▶ One (1) fifteen (15) ton dump truck loading large rock for twenty (20) minutes during the daytime hour at loading area;
- ▶ One (1) fifteen (15) ton dump truck loading gravel for twenty (20) minutes during the daytime hour at loading area;
- ▶ One (1) fifteen (15) ton dump truck loading dirt for twenty (20) minutes during the daytime hour at loading area; and
- ▶ One (1) five (5) ton dump truck loading large rock for twenty (20) minutes during the daytime hour at loading area.

During the site visit, it was noted that there are two (2) ISO containers located on the south side of the yard, which will break line-of-sight between the Subject Site and some of the truck activities within the yard. These ISO containers were measured at the standard size of 2.59 metres and were included in the assessment.

Table 11: Niagara-on-the-Lake Municipal Truck Yard Activities Octave Band Sound Power Data

| Source ID | Description                                    | Octave Band Linear Sound Power Level (dB) |        |        |         |         |         |         | Overall Sound Power Level (dBA) |
|-----------|--|---|--------|--------|---------|---------|---------|---------|---------------------------------|
|           |  | 125 Hz                                    | 250 Hz | 500 Hz | 1000 Hz | 2000 Hz | 4000 Hz | 8000 Hz |                                 |
| L01, L02  | 15-Ton Dump Truck Pass-by                      | 103                                       | 101    | 101    | 98      | 95      | 89      | 81      | 103                             |
| L03, L04  | 5-Ton Dump Truck Pass-by                       | 92  | 89     | 90     | 90      | 86      | 83      | 72      | 94                              |
| S40       | 15-Ton Dump Truck Loading/Unloading Dirt       | 96  | 93     | 94     | 92      | 88      | 84      | 82      | 103                             |
| S41       | 15-Ton Dump Truck Loading/Unloading Gravel     | 97  | 98     | 100    | 97      | 94      | 91      | 86      | 106                             |
| S42       | 15-Ton Dump Truck Loading/Unloading Large Rock | 103                                       | 100    | 102    | 100     | 98      | 93      | 86      | 109                             |
| S43       | 5-Ton Dump Truck Loading/Unloading Dirt        | 100                                       | 99     | 99     | 98      | 95      | 88      | 79      | 107                             |

#### 4.2.5 Stationary Noise Predictions

Sound levels were modelled for the worst-case daytime and nighttime hour at the noise-sensitive receptors wherever noise exposure was considered maximum. Locations of the critical noise receptors are shown in **Figure 3**. The predicted sound levels at the noise-sensitive receptors due to stationary noise emanating from the environment are summarised in **Table 12**. The directivity of noise emission for applicable noise sources was considered. Sample calculations are available in **Appendix D**.

Table 12: Predicted Stationary Noise Impact Levels

| Receptor | Period                  | Predicted Sound Level ( $L_{eq\ 1\ hour}$ , dBA) | Sound Level Limit ( $L_{eq\ 1\ hour}$ , dBA) | Exceeds Sound Level Limit? |
|----------|-------------------------|--|--|----------------------------|
| RP01     | Daytime (07:00-23:00)   | 48   | 50   | NO                         |
|          | Nighttime (23:00-07:00) | 36   | 45   | NO                         |
| RP02     | Daytime (07:00-23:00)   | 34   | 50   | NO                         |
|          | Nighttime (23:00-07:00) | 31   | 45   | NO                         |
| RP03     | Daytime (07:00-23:00)   | 32   | 50   | NO                         |
|          | Nighttime (23:00-07:00) | 29   | 45   | NO                         |
| RP04     | Daytime (07:00-23:00)   | 50   | 50   | NO                         |
|          | Nighttime (23:00-07:00) | 37   | 45   | NO                         |
| RP05     | Daytime (07:00-23:00)   | 32   | 50   | NO                         |
|          | Nighttime (23:00-07:00) | 28   | 45   | NO                         |
| RP06     | Daytime (07:00-23:00)   | 33   | 50   | NO                         |
|          | Nighttime (23:00-07:00) | 28   | 45   | NO                         |
| RP07     | Daytime (07:00-23:00)   | 50   | 50   | NO                         |
|          | Nighttime (23:00-07:00) | 37   | 45   | NO                         |
| RP08     | Daytime (07:00-19:00)   | 39   | 50   | NO                         |
|          | Evening (19:00-23:00)   | 37   | 45   | NO                         |

| Receptor | Period                | Predicted Sound Level<br>( $L_{eq}$ 1 hour, dBA) | Sound Level Limit<br>( $L_{eq}$ 1 hour, dBA) | Exceeds Sound<br>Level Limit? |
|----------|-----------------------|--|--|-------------------------------|
| RP09     | Daytime (07:00-19:00) | 34   | 50   | NO                            |
|          | Evening (19:00-23:00) | 32   | 45   | NO                            |
| RP10     | Daytime (07:00-19:00) | 39   | 50   | NO                            |
|          | Evening (19:00-23:00) | 34   | 45   | NO                            |
| RP11     | Daytime (07:00-19:00) | 20   | 50   | NO                            |
|          | Evening (19:00-23:00) | 17   | 45   | NO                            |
| RP12     | Daytime (07:00-19:00) | 20   | 50   | NO                            |
|          | Evening (19:00-23:00) | 17   | 45   | NO                            |
| RP13     | Daytime (07:00-19:00) | 19   | 50   | NO                            |
|          | Evening (19:00-23:00) | 16   | 45   | NO                            |
| RP14     | Daytime (07:00-19:00) | 20   | 50   | NO                            |
|          | Evening (19:00-23:00) | 17   | 45   | NO                            |

Table 13: Predicted Stationary Noise Impact Levels (Emergency Generator)

| Receptor | Period                | Predicted Sound Level<br>( $L_{eq}$ 1 hour, dBA) | Sound Level Limit<br>( $L_{eq}$ 1 hour, dBA) | Exceeds Sound<br>Level Limit? |
|----------|-----------------------|--|--|-------------------------------|
| RP11     | Daytime (07:00-23:00) | 37   | 55   | NO                            |
| RP12     | Daytime (07:00-23:00) | 39   | 55   | NO                            |
| RP13     | Daytime (07:00-23:00) | 38   | 55   | NO                            |
| RP14     | Daytime (07:00-23:00) | 38   | 55   | NO                            |

**Figure 3** illustrates the predicted environment to site sound level contours at seven (7) meters in the proximity of the subject site's noise-sensitive receptors for the daytime period. **Figure 4** shows the predicted site to environment sound level contours at 1.5 meters in the proximity of nearby noise-sensitive areas. **Figure 5** shows the predicted emergency generator sound level contours at 1.5 meters in the proximity of nearby noise-sensitive areas. Based on the figures, stationary sound levels are expected to be below the MECP sound level limits. Thus, mitigation measures are not required for stationary noise sources.

## 5 NOISE ABATEMENT REQUIREMENTS

### 5.1 INDOOR LIVING AREAS AND AC/VENTILATION REQUIREMENTS

Indoor sound levels have been examined with respect to MECP Guidelines, as summarised in **Section 3.1.1** of this report. The recommendations discussed below should be verified upon the final detailed review of the architectural design of the proposed development.

#### 5.1.1 Building Façade Constructions

According to NPC-300 guideline:

*"If the nighttime sound level outside the bedroom or living/dining room windows exceeds 60 dBA or the daytime sound level outside the bedroom or living/dining area windows exceeds 65 dBA, building components including windows, walls and doors, where applicable, should be designed so that the indoor sound levels comply with the sound level limits."*

Based on the predicted outdoor façade sound levels shown in **Table 6** and the statement above from NPC-300 guideline, window and wall upgrades for all façades are not required to meet the MECP indoor sound level limits shown in **Table 1**.

The exterior window and wall STC values show that the following are required to mitigate road traffic sound levels to the MECP and Town of Niagara-on-the-Lake indoor sound level criteria:

- ▶ OBC-compliant exterior window and wall construction are sufficient for the mixed-use development on all façades of the proposed residential and commercial/office buildings.

### 5.1.2 Ventilation Requirements

Based on the unattenuated noise levels shown in **Table 6** and the ventilation requirements in **Table 2**, the façades do require warning clauses for future occupants in their Agreements of Purchase/Sale.

- ▶ The office units on the northerly, easterly and southerly façades of the proposed development must be provided with forced-air heating with the provision for future air-conditioning and should include Warning Clause Type 'C' in its Agreements of Purchase/Sale or Lease/Rental agreements. However, it is anticipated that the development will provide a central air conditioning system; thus, the forced-air heating with the provision for future air-conditioning is expected to be met.

## 6 CONCLUSIONS & RECOMMENDATIONS

According to the NPC-300 noise guidelines, the implementation of all required noise control measures should be verified by a qualified Acoustical Consultant. All relevant builder's plans should be certified by an Acoustic Consultant as being in conformance with the recommendations of the approved Noise Impact Study. Further, prior to the final inspection and release for occupancy, the recommended noise control measures within the subject site should be inspected by an Acoustic Consultant. The intent is to ensure that the recommendations and builder's plans are compliant with the approved Noise Impact Study.

Based on the analysis, the impact from the environment on the proposed development is within the applicable MECP limits. The following is a summary of our noise analysis:

- ▶ No mitigation measures are required for points of reception affected by stationary noise sources;
- ▶ No mitigation measures are required for points of reception affected by the emergency generator;
- ▶ No mitigation measures are required for OLA points of reception affected by road noise sources;
- ▶ OBC-compliant exterior window and wall construction are sufficient for the mixed-use development on all façades of the proposed residential and commercial/office buildings;
- ▶ The office units on the northerly, easterly and southerly façades of the proposed development must be provided with forced-air heating with the provision for future air-conditioning and should include Warning Clause Type 'C' in its Agreements of Purchase/Sale or Lease/Rental agreements. However, it is anticipated that the development will provide a central air conditioning system; thus, the forced-air heating with the provision for future air-conditioning is expected to be met; and
- ▶ Should any of the plans or information used in the completion of this report change, a detailed review should be completed by an acoustical consultant to ensure the sound level limits are met.

## 7 WARNING CLAUSES

The following warning clause should be included in all offers of purchase and sale relating to:

- ▶ The office units on the northerly, easterly and southerly façades of the proposed development;


Warning Clause Type C:

*"This dwelling unit has been designed with the provision for adding central air conditioning at the occupant's discretion. Installation of central air conditioning by the occupant in low and medium density developments will allow windows and exterior doors to remain closed, thereby ensuring that the indoor sound levels are within the sound levels limits of the Town of Niagara-on-the-Lake and the Ministry of the Environment, Conservation and Parks."*


## 8 REFERENCES

1. ORNAMENT – "Ontario Road Noise Analysis Method for Environmental and Transportation", Ontario Ministry of the Environment, October 1989.
2. International Standard, ISO 9613-2, "Acoustics - Attenuation of Sound During Propagation Outdoors – Part 2: General Method of Calculation", Dec 1996.
3. "Noise Guideline, Stationary and Transportation Sources – Approval and Planning, Publication NPC-300", Ontario Ministry of the Environment, Aug 2013.



|  |  |  |                   |
|--|--|--|-------------------|
| <br>LEA Consulting Ltd. | <b>Project ID:</b> 25253<br>Scale: NTS<br>Drawn by: ID<br>Reviewed by: DEA/JD<br>Date: Jan 10, 2025<br>Revision: 1 | <b>Project Name</b><br>1544 & 1546 Four Mile Creek Road, Niagara-on-the-Lake NIS | <h1>Figure 1</h1> |
|  | <b>Figure Title</b><br>Key Plan Showing Site Location and Area   |  |                   |







Project ID: 25253  
 Scale: NTS  
 Drawn by: ID  
 Reviewed by: DEA/JD  
 Date: October 22, 2025  
 Revision: 2


Project Name  
 1544 & 1546 Four Mile Creek Road, Niagara-on-the-Lake NIS


Figure Title  
 Receptor Locations and Unmitigated Noise Impact Contours at 7 m height,  
 Daytime (7:00 – 19:00), Environment to Subject Site (External Noise Sources)

**Figure 3**



|  |  |  |                 |
|--|--|--|-----------------|
| <br>LEA Consulting Ltd. | Project ID: 25253  | Project Name<br>1544 & 1546 Four Mile Creek Road, Niagara-on-the-Lake NIS  | <b>Figure 4</b> |
|  | Scale: NTS<br>Drawn by: ID<br>Reviewed by: DEA/JD<br>Date: October 22, 2025<br>Revision: 2 | <b>Figure Title</b><br>Receptor Locations and Unmitigated Noise Impact Contours at 1.5 m height,<br>Daytime (7:00 – 19:00), Subject Site to Environment (Internal Noise Sources) |                 |



|  |  |   |                 |
|--|--|---|-----------------|
| <br>LEA Consulting Ltd. | Project ID: 25253  | Project Name<br>1544 & 1546 Four Mile Creek Road, Niagara-on-the-Lake NIS   | <b>Figure 5</b> |
|  | Scale: NTS<br>Drawn by: ID<br>Reviewed by: DEA/JD<br>Date: October 22, 2025<br>Revision: 2 | Figure Title<br>Receptor Locations and Unmitigated Noise Impact Contours at 1.5 m height,<br>Daytime (7:00 – 19:00), Generator Testing and Maintenance Operations |                 |



# APPENDIX A

**COPY OF THE SITE PLAN**



### 14. SETBACKS

|                       | REQUIRED | PROVIDED   |
|-----------------------|----------|--|
| NORTH (INTERIOR YARD) | NIL      | 11.995m  |
| SOUTH (INTERIOR YARD) | 4.5m     | 20.995m  |
| EAST                  | 0m       | 0.3m   |
| WEST                  | 7.5m     | 0m BELOW GRADE<br>0m AT GRADE<br>1.1m 2ND STOREY & ABOVE |

### 15. BUILDING HEIGHT

|  |                      |
|--|----------------------|
| PROPOSED RESIDENTIAL BUILDING HEIGHT:<br>(OVERALL HEIGHT MEASURED FROM EST. GRADE OF 92.00m TO TOP OF AMENITY ROOF)      | * 5 STOREY (21.280m) |
| PROPOSED COMMERCIAL & OFFICE BUILDING HEIGHT:<br>(OVERALL HEIGHT MEASURED FROM EST. GRADE OF 92.00m TO TOP OF MAIN ROOF) | 2 STOREY (10.000m)   |

\* 5TH FLOOR CONSISTS OF AMENITY AND MECHANICAL ONLY WITH NO RESIDENTIAL UNITS

### 1. ZONING

ZONING: [Blank]

### 2. SITE AREA

|                   | SQ. FEET (ft²) | SQ. METER (m²) | ACRES (ac) | HECTARES (ha) |
|-------------------|----------------|----------------|------------|---------------|
| DEVELOPABLE AREA  | 83,022ft²      | 7,713m²        | 1.906 ac   | 0.771 ha      |
| ROAD              | 23,950ft²      | 2,225m²        | 0.550 ac   | 0.223 ha      |
| CONSERVATION AREA | 8,077ft²       | 750.4m²        | 0.185 ac   | 0.075 ha      |
| TOTAL             | 115,049ft²     | 10,688.4m²     | 2.64 ac    | 1.07 ha       |

### 3. UNIT MIX

|              | STUDIO | 1B | 1B+D | 2B | 2B+D | 3B/3B+D | TOTAL |
|--------------|--------|----|------|----|------|---------|-------|
| GROUND FLOOR | -      | 3  | 1    | 5  | -    | -       | 9     |
| 2ND FLOOR    | -      | 4  | -    | 4  | -    | -       | 8     |
| 3RD FLOOR    | -      | 4  | -    | 4  | -    | -       | 8     |
| 4TH FLOOR    | -      | -  | -    | 4  | -    | 2       | 6     |
| TOTAL        | -      | 11 | 1    | 17 | -    | 2       | 31    |

\* OF WHICH 15% ARE BARRIER FREE

### 4. GROSS FLOOR AREA

\* GROSS FLOOR AREA - MEANS THE SUM TOTAL OF THE GROSS-HORIZONTAL AREA OF ALL FLOORS OF ALL BUILDINGS OR STRUCTURES ON A LOT, MEASURED FROM THE INTERIOR FACES OF THE EXTERIOR WALLS OR FROM THE CENTER LINE OF THE COMMON WALL SEPARATING TWO BUILDINGS, AND THE SPECIAL FLOOR AREA OF A BUILDING OR STRUCTURE SHALL ALSO INCLUDE:

- BASEMENT FLOOR AREA WHERE THE BASEMENT CEILING HEIGHT IS 2.1m OR MORE, UNLESS OTHERWISE SPECIFIED;
- AT-RISER SPACE HAVING HEADROOM OF 2.1m OR MORE FOR ALL LEVELS THAT ARE USED FOR MECHANICAL EQUIPMENT;
- INTERIOR BALCONIES AND MEZANINES;
- ENCLOSED PORCHES AND DECKED TERRACES;
- ELEVATOR SHAFTS AND STAIRWELLS AT EACH FLOOR, AND FLOOR AREA USED FOR MECHANICAL EQUIPMENT;
- GROUND FLOOR AREA DEVOTED TO RECREATION USES IN THE MAIN BUILDING.

|                            | NO. RLS x SQ METER (m²) | SQ METER (m²) | SQ FEET (ft²) |
|----------------------------|-------------------------|---------------|---------------|
| RESIDENTIAL                |                         |               |               |
| P1 UNDERGROUND             |                         | 2,191m²       |               |
| GROUND FLOOR               |                         | 1,008m²       |               |
| 2ND FLOOR                  |                         | 873m²         |               |
| 3RD-4TH FLOOR              | 2 FLRS x 873m²          | 1,746m²       |               |
| 5TH FLOOR (AMENITY & MECH) |                         | *617m²        |               |
| TOTAL                      |                         | *6,433m²      | 45%           |
| 69,244ft²                  |                         |               |               |
| COMMERCIAL & OFFICE        |                         |               |               |
| P1 UNDERGROUND             |                         | 4,178m²       |               |
| GROUND FLOOR               |                         | 1,800m²       |               |
| COMMERCIAL                 |                         | 761m²         |               |
| RESTAURANT                 |                         | 745m²         |               |
| SERVICE SPACE              |                         | 294m²         |               |
| 2ND FLOOR (OFFICE)         |                         | 1,800m²       |               |
| ROOFTOP MECH               |                         | 209m²         |               |
| TOTAL                      |                         | 7,985m²       | 55%           |
| 85,950ft²                  |                         |               |               |
| TOTAL                      |                         | 14,418m²      |               |
| 155,194ft²                 |                         |               |               |

\* OF WHICH 170m² IS INDOOR AMENITY AND 450m² IS OUTDOOR AMENITY TERRACE

### 5. LEASABLE AREA SQ METER m²

|               | UNIT    | PATIO             | TOTAL   |
|---------------|---------|-------------------|---------|
| COMMERCIAL    |         |                   |         |
| RESTAURANT    | 720m²   | 234m² (PATIO 1&2) | 963m²   |
| RETAIL UNIT 1 | 392m²   | 117m² (PATIO 3)   | 509m²   |
| RETAIL UNIT 2 | 344m²   | -                 | 344m²   |
| OFFICE        | 1,568m² | -                 | 1,568m² |
| TOTAL         | 3,022m² | 351m²             | 3,373m² |

### 6. RESIDENTIAL NET DENSITY

|  |                              |            |
|--|------------------------------|------------|
| RESIDENTIAL UNIT / TOTAL SITE AREA (EXCLUDING ROADS AND CONSERVATION AREA) | 31 UNITS / 0.771ha (7.713m²) | 41 UNIT/ha |
|--|------------------------------|------------|

### 7. PARKING

|                         | 80 (11/9m²) | 40 (11/8.5m²) | 56 (11/28m²) | 12 (11/30m²) | 31 (11/5P/U) | 219* |
|-------------------------|-------------|---------------|--------------|--------------|--------------|------|
| TOTAL PARKING REQUIRED: |             |               |              |              |              |      |
| RESTAURANT              |             |               |              |              |              |      |
| COMMERCIAL              |             |               |              |              |              |      |
| OFFICE                  |             |               |              |              |              |      |
| PATIO                   |             |               |              |              |              |      |
| VISITOR                 |             |               |              |              |              |      |
| RESIDENTIAL             |             |               |              |              |              |      |
| TOTAL                   |             |               |              |              |              | 219* |
| SURFACE                 | 75          | 0             | 0            | 14           | 2            | 0    |
| P1 UNDERGROUND          | 5           | 40            | 56           | 0            | 5            | 150  |
| TOTAL PROVIDED          | 80          | 40            | 56           | 14           | 7            | 150  |

\* OF WHICH 7 ARE REQUIRED AND PROVIDED TO BE BARRIER-FREE (CITY BY-LAW REQUIREMENTS) \*\*\* OF WHICH ARE 19 OPTIONAL EV CHARGERS  
\*\* OF WHICH 2 ARE COMPACT SPACES (2.6m x 5.0m) & MOTORCYCLE PARKING SPACES (3 RESIDENTIAL & 5 COMMERCIAL) (1.2m x 3.0m)

### 8. LOCKER STORAGE

|                |                    |
|----------------|--------------------|
| P1 UNDERGROUND | 31 (1 LOCKER/UNIT) |
|----------------|--------------------|

### 9. BICYCLE PARKING

|                                 | 15 (21/100m²) | 4 (1/200m²) | 7 (1/250m²) | 8 (2/100m²) | 33 |
|---------------------------------|---------------|-------------|-------------|-------------|----|
| TOTAL BICYCLE PARKING REQUIRED: |               |             |             |             |    |
| RESTAURANT                      |               |             |             |             |    |
| COMMERCIAL                      |               |             |             |             |    |
| OFFICE                          |               |             |             |             |    |
| PATIO                           |               |             |             |             |    |
| VISITOR                         |               |             |             |             |    |
| RESIDENTIAL                     |               |             |             |             |    |
| TOTAL                           |               |             |             |             | 33 |
| SURFACE                         | 20            | 8           | 0           | 14          | 0  |
| P1 UNDERGROUND                  | 0             | 0           | 7           | 0           | 17 |
| TOTAL PROVIDED                  | 20            | 8           | 7           | 14          | 17 |

### 10. INDOOR & OUTDOOR AREA

RESIDENTIAL AMENITY SPACE: 1144m² (11440sqft)  
RESIDENTIAL AMENITY SPACE: 1928m² (19280sqft) + 136(3840sqft) (860m²)

|                              | SQ METER (m²) | SQ FEET (ft²) |
|------------------------------|---------------|---------------|
| RESIDENTIAL                  |               |               |
| INDOOR AMENITY               | 170m²         |               |
| OUTDOOR AMENITY TERRACE      | 450m²         |               |
| GROUND FLOOR                 | 18m²          |               |
| ROOFTOP AMENITY              | 42m²          |               |
| PLAYGROUND                   | 73m²          |               |
| PLAZA                        | 1144m²        |               |
| RESIDENTIAL BALCONIES/PATIOS | 87m²          |               |
| TOTAL AMENITY SPACE PROVIDED | 1,684m²       | 18,126ft²     |
| COMMERCIAL                   |               |               |
| OUTDOOR PATIO 1              | 39m²          |               |
| OUTDOOR PATIO 2              | 195m²         |               |
| OUTDOOR PATIO 3              | 117m²         |               |
| TOTAL                        | 351m²         | 3,778ft²      |

### 11. COVERAGE

|                   | SQ. METER (m²) | SQ. FEET (ft²) | %    |
|-------------------|----------------|----------------|------|
| BUILDING          | 3,065m²        |                | 29%  |
| RESIDENTIAL       | 1,258m²        |                | 12%  |
| COMMERCIAL/OFFICE | 1,807m²        |                | 17%  |
| LANDSCAPED AREAS  | 3,599.4m²      |                | 33%  |
| PAVED AREAS       | 4,024m²        |                | 38%  |
| DRIVEWAY AREAS    | 2,257m²        |                | 21%  |
| PARKING AREAS     | 1,747m²        |                | 17%  |
| TOTAL             | 10,688.4m²     |                | 100% |





### SURVEY INFORMATION

PLAN OF SURVEY: PART OF TOWNSHIP LOT 112 & PART OF ROAD ALLOWANCE BETWEEN TOWNSHIP LOTS 111 & 112 IN THE TOWNSHIP OF NIAGARA-ON-THE-LAKE REGIONAL MUNICIPALITY OF NIAGARA  
(DATE: FEB 18, 2025)

NOTES:  
DISTANCES, ELEVATION AND CO-ORDINATES SHOWN ON THIS PLAN ARE IN METERS AND CAN BE CONVERTED TO FEET BY DIVIDING BY 0.3048  
ELEVATIONS ARE GEODESIC ORIGIN (CGVD 1928, 78) AND ARE DERIVED FROM REAL TIME NETWORK (RTN) OBSERVATIONS AND NATURAL RESOURCES CANADA'S GEODID MODEL HT2.0  
REVISED TO SHOW REMOVED BERM & CURBS ON EAST SIDE OF FOUR MILE CREEK ROAD & NEW DRIVELINE AS MARKED OUT  
THIS PLAN WAS PREPARED FOR REZEN HOLDING CORPORATION AND THE UNDERSIGNED ASSUMES NO RESPONSIBILITY FOR USE BY OTHER PARTIES.

SURVEYOR CONTACT INFORMATION: **BARICH GRENKIE SURVEYING LTD.**  
301 HWY NO.8 (2ND FLOOR) - STONEY CREEK, ON L8C 1E5  
TEL: (905) 462-6747



### GENERAL NOTES

- LOADING SPACE AND STAGING PAD TO BE LEVEL (+/-2%) AND CONSTRUCTED OF MINIMUM 200mm REINFORCED CONCRETE. MINIMUM 6.1m UNCLIMBED VERTICAL CLEARANCE REQUIRED
- ACCESS DRIVEWAYS TO BE USED BY COLLECTION VEHICLES TO HAVE A MINIMUM VERTICAL CLEARANCE OF 4.4m THROUGHOUT
- ANY DRIVEWAY OR COLLECTION AREA REQUIRING A COLLECTION VEHICLE TO DRIVE ONTO OR OVER A SUPPORTED STRUCTURE TO BE RATED TO SAFELY SUPPORT THE REQUIRED LOADS.

### 12. LOT FRONTAGE

|                                      |        |
|--------------------------------------|--------|
| LOT FRONTAGE (FOUR MILE CREEK DRIVE) | 88.84m |
|--------------------------------------|--------|

### 13. LOADING AREA

|                           |   |
|---------------------------|---|
| LOADING AREAS (3.6m x 9m) | 2 |
|---------------------------|---|

THIS DRAWING AS AN INSTRUMENT OF SERVICE IS PROVIDED BY AND IS THE PROPERTY OF ICE BROCHU ARCHITECTS INC. THE CONTRACTOR SHALL VERIFY AND ACCEPT RESPONSIBILITY FOR ALL DIMENSIONS AND CONDITIONS ON SITE AND SHALL NOTIFY ICE BROCHU ARCHITECTS INC. OF ANY VARIATIONS FROM THE SUPPLIED INFORMATION. ICE BROCHU ARCHITECTS INC. IS NOT RESPONSIBLE FOR THE ACCURACY OF THE CONSULTANT INFORMATION. REFER TO APPROPRIATE SURVEY, STRUCTURAL, MECHANICAL, ELECTRICAL, LANDSCAPE, ETC. CONSULTANT DRAWINGS BEFORE PROCEEDING WITH THE WORK. CONSTRUCTION MUST CONFORM TO ALL APPLICABLE CODES AND REQUIREMENTS OF AUTHORITIES HAVING JURISDICTION. THE ARCHITECTURAL SYMBOLS ARE FOR GRAPHIC REPRESENTATION ONLY.  
THIS DRAWING IS NOT TO BE SCALED.

THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION PURPOSES UNLESS COUNTER SIGNED BY THE ARCHITECT.

ANDRE BROCHU  
DPL\_ARCH, OAA MRAC

DATE

DATE: MARCH, 2025  
Scale: 1:300  
Project No: 23.11  
Plot Date: December 09, 2025

Drawn By: PL/YL  
Reviewed By: AB

Drawing Title: **SITE PLAN**

ICE BROCHU ARCHITECTS INC.  
517 Wellington St W., Suite 201, Toronto, Ontario, M5V 1G1  
1.647.288.1800 | ibarchitects.net

2 DEC 5, 2025 RE-ISSUED FOR REZONING AND OPA AB  
1 APRIL 10, 2025 ISSUED FOR REZONING AB

NO. DATE ISSUE BY

Issued

1544 & 1546  
**FOUR MILE CREEK RD  
RESIDENTIAL DEVELOPMENT**

FOUR MILE CREEK NIAGARA-ON-THE-LAKE, ONTARIO

Drawing Title: **SITE PLAN**

Date: MARCH, 2025 Drawn By: PL/YL  
Scale: 1:300 Reviewed By: AB  
Project No: 23.11 Drawing No: A102  
Plot Date: December 09, 2025




# APPENDIX B

## TRAFFIC DATA



Turning Movement Count - Four Mile Creek Road & Niagara Stone Road


| Start Time   | Four Mile Creek Road Southbound |       |       |       |      | Niagara Stone Road Westbound |        |       |       |        | Four Mile Creek Road Northbound |            |        |       |       | Niagara Stone Road Eastbound |      |            |        |       | Grand Total |       |       |      |            |       |
|--------------|---------------------------------|-------|-------|-------|------|------------------------------|--------|-------|-------|--------|---------------------------------|------------|--------|-------|-------|------------------------------|------|------------|--------|-------|-------------|-------|-------|------|------------|-------|
|              | U-Turn                          | Left  | Thru  | Right | Peds | App. Total                   | U-Turn | Left  | Thru  | Right  | Peds                            | App. Total | U-Turn | Left  | Thru  | Right                        | Peds | App. Total | U-Turn | Left  |             | Thru  | Right | Peds | App. Total |       |
| 7:00         | 0                               | 0     | 6     | 5     | 1    | 11                           | 0      | 4     | 25    | 1      | 0                               | 30         | 0      | 2     | 7     | 5                            | 0    | 14         | 0      | 3     | 33          | 2     | 0     | 35   | 91         |       |
| 7:15         | 0                               | 2     | 8     | 3     | 0    | 13                           | 0      | 11    | 33    | 4      | 0                               | 48         | 0      | 4     | 10    | 21                           | 0    | 35         | 0      | 5     | 41          | 4     | 0     | 50   | 146        |       |
| 7:30         | 0                               | 4     | 9     | 5     | 0    | 18                           | 0      | 15    | 33    | 1      | 0                               | 49         | 0      | 6     | 11    | 31                           | 0    | 48         | 0      | 3     | 50          | 14    | 0     | 67   | 182        |       |
| 7:45         | 0                               | 2     | 11    | 4     | 0    | 17                           | 0      | 11    | 34    | 2      | 1                               | 47         | 0      | 13    | 11    | 33                           | 1    | 57         | 0      | 5     | 63          | 5     | 0     | 73   | 194        |       |
| Hourly Total | 0                               | 8     | 34    | 17    | 1    | 59                           | 0      | 41    | 125   | 8      | 1                               | 174        | 0      | 25    | 39    | 90                           | 1    | 154        | 0      | 16    | 187         | 25    | 0     | 228  | 615        |       |
| 8:00         | 0                               | 2     | 10    | 5     | 0    | 17                           | 0      | 9     | 42    | 0      | 0                               | 51         | 0      | 9     | 7     | 18                           | 0    | 34         | 0      | 4     | 49          | 6     | 0     | 59   | 161        |       |
| 8:15         | 0                               | 3     | 9     | 6     | 0    | 18                           | 0      | 12    | 49    | 4      | 0                               | 65         | 0      | 13    | 10    | 16                           | 0    | 39         | 0      | 3     | 71          | 17    | 0     | 91   | 213        |       |
| 8:30         | 0                               | 5     | 10    | 8     | 0    | 23                           | 0      | 15    | 51    | 3      | 2                               | 69         | 0      | 9     | 7     | 19                           | 0    | 35         | 0      | 2     | 64          | 11    | 0     | 77   | 204        |       |
| 8:45         | 0                               | 3     | 11    | 7     | 0    | 21                           | 0      | 20    | 56    | 0      | 0                               | 86         | 0      | 14    | 11    | 35                           | 0    | 60         | 0      | 7     | 72          | 9     | 0     | 88   | 255        |       |
| Hourly Total | 0                               | 13    | 40    | 26    | 0    | 79                           | 0      | 56    | 208   | 7      | 2                               | 271        | 0      | 45    | 35    | 88                           | 0    | 168        | 0      | 16    | 256         | 43    | 0     | 315  | 813        |       |
| 9:00         | 0                               | 1     | 6     | 11    | 2    | 18                           | 0      | 21    | 59    | 1      | 0                               | 81         | 0      | 11    | 11    | 33                           | 0    | 55         | 0      | 10    | 72          | 16    | 0     | 98   | 252        |       |
| 9:15         | 0                               | 8     | 14    | 6     | 0    | 28                           | 0      | 17    | 59    | 1      | 0                               | 77         | 0      | 15    | 6     | 38                           | 0    | 59         | 0      | 4     | 71          | 10    | 0     | 85   | 249        |       |
| Hourly Total | 0                               | 9     | 20    | 17    | 2    | 46                           | 0      | 38    | 118   | 2      | 0                               | 158        | 0      | 26    | 17    | 71                           | 0    | 114        | 0      | 14    | 143         | 26    | 0     | 183  | 501        |       |
| * Break *    |                                 |       |       |       |      |                              |        |       |       |        |                                 |            |        |       |       |                              |      |            |        |       |             |       |       |      |            |       |
| 16:00        | 0                               | 6     | 15    | 11    | 0    | 32                           | 0      | 31    | 105   | 6      | 0                               | 142        | 0      | 28    | 26    | 35                           | 1    | 89         | 0      | 6     | 92          | 12    | 1     | 110  | 373        |       |
| 16:15        | 0                               | 3     | 8     | 12    | 0    | 23                           | 0      | 38    | 160   | 2      | 0                               | 200        | 0      | 12    | 11    | 25                           | 0    | 48         | 0      | 5     | 78          | 19    | 0     | 102  | 373        |       |
| 16:30        | 0                               | 9     | 16    | 8     | 0    | 33                           | 0      | 22    | 114   | 2      | 0                               | 138        | 0      | 26    | 21    | 41                           | 0    | 88         | 0      | 4     | 73          | 20    | 0     | 97   | 356        |       |
| 16:45        | 0                               | 8     | 12    | 4     | 1    | 24                           | 0      | 22    | 91    | 4      | 0                               | 117        | 0      | 8     | 22    | 22                           | 0    | 52         | 0      | 10    | 66          | 17    | 0     | 93   | 286        |       |
| Hourly Total | 0                               | 26    | 51    | 35    | 1    | 112                          | 0      | 113   | 470   | 14     | 0                               | 507        | 0      | 74    | 80    | 133                          | 1    | 277        | 0      | 25    | 309         | 68    | 1     | 402  | 1388       |       |
| 17:00        | 0                               | 4     | 21    | 6     | 0    | 31                           | 0      | 40    | 108   | 5      | 1                               | 153        | 0      | 19    | 9     | 26                           | 0    | 54         | 0      | 11    | 66          | 15    | 0     | 92   | 330        |       |
| 17:15        | 0                               | 5     | 16    | 8     | 2    | 29                           | 0      | 34    | 103   | 2      | 1                               | 139        | 0      | 14    | 13    | 27                           | 0    | 54         | 0      | 7     | 71          | 10    | 0     | 88   | 310        |       |
| 17:30        | 0                               | 6     | 8     | 1     | 0    | 15                           | 0      | 26    | 86    | 4      | 1                               | 116        | 0      | 7     | 9     | 21                           | 1    | 37         | 0      | 2     | 57          | 10    | 0     | 69   | 237        |       |
| 17:45        | 0                               | 0     | 9     | 5     | 3    | 14                           | 0      | 21    | 55    | 0      | 0                               | 77         | 0      | 7     | 19    | 14                           | 0    | 50         | 0      | 5     | 54          | 7     | 0     | 66   | 207        |       |
| Hourly Total | 0                               | 15    | 54    | 20    | 5    | 89                           | 0      | 121   | 352   | 12     | 3                               | 485        | 0      | 47    | 50    | 98                           | 1    | 195        | 0      | 25    | 248         | 42    | 0     | 315  | 1084       |       |
| 18:00        | 0                               | 2     | 4     | 10    | 1    | 16                           | 0      | 22    | 56    | 6      | 0                               | 84         | 0      | 6     | 11    | 21                           | 0    | 38         | 0      | 4     | 52          | 14    | 0     | 70   | 208        |       |
| 18:15        | 0                               | 5     | 4     | 3     | 1    | 12                           | 0      | 13    | 45    | 2      | 0                               | 60         | 0      | 11    | 4     | 26                           | 0    | 41         | 0      | 0     | 33          | 9     | 0     | 42   | 155        |       |
| Hourly Total | 0                               | 7     | 8     | 13    | 2    | 28                           | 0      | 35    | 101   | 8      | 0                               | 144        | 0      | 17    | 15    | 47                           | 0    | 79         | 0      | 4     | 85          | 24    | 0     | 112  | 388        |       |
| Grand Total  | 0                               | 79    | 207   | 118   | 11   | 413                          | 0      | 404   | 1374  | 51     | 6                               | 1929       | 0      | 224   | 216   | 517                          | 3    | 987        | 0      | 100   | 1218        | 227   | 1     | 1555 | 4784       |       |
| Approach %   | 0.0%                            | 18.9% | 50.1% | 31.0% | -    | -                            | 0.0%   | 22.1% | 75.1% | 2.8%   | -                               | -          | 0.0%   | 23.7% | 23.9% | 52.4%                        | -    | 20.6%      | 0.0%   | 6.4%  | 79.0%       | 14.6% | -     | -    | -          |       |
| Total %      | 0.0%                            | 1.6%  | 4.3%  | 2.7%  | -    | -                            | 0.0%   | 8.4%  | 28.7% | 1.1%   | -                               | -          | 0.0%   | 4.5%  | 4.9%  | 10.8%                        | -    | 2.6%       | 0.0%   | 2.1%  | 25.7%       | 4.7%  | -     | -    | 32.5%      |       |
| Lights       | 0                               | 76    | 197   | 120   | -    | 393                          | 0      | 398   | 1347  | 51     | -                               | 1796       | 0      | 226   | 222   | 506                          | -    | 954        | 0      | 95    | 1199        | 216   | -     | -    | 1510       | 4653  |
| % Lights     | -                               | 97.4% | 95.2% | 93.8% | -    | 95.2%                        | -      | 98.5% | 98.0% | 100.0% | -                               | 98.2%      | -      | 96.6% | 94.1% | 97.9%                        | -    | 96.7%      | -      | 95.0% | 97.6%       | 95.2% | -     | -    | 97.1%      | 97.3% |
| Buses        | 0                               | 3     | 4     | -     | 7    | -                            | 1      | 11    | 0     | -      | 12                              | -          | 2      | 2     | 3     | -                            | 7    | -          | 1      | 8     | 4           | -     | -     | -    | 13         | 39    |
| % Buses      | 0.0%                            | 0.0%  | 1.4%  | 3.1%  | 1.7% | -                            | 0.2%   | 0.8%  | 0.0%  | -      | 0.7%                            | -          | 0.9%   | 0.8%  | 0.6%  | -                            | 0.7% | -          | 1.0%   | 0.7%  | 1.8%        | -     | -     | -    | 0.8%       | 0.8%  |
| Trucks       | 2                               | 7     | 4     | -     | 13   | -                            | 5      | 16    | 0     | -      | 21                              | -          | 6      | 12    | 8     | -                            | 26   | -          | 4      | 21    | 7           | -     | -     | -    | 32         | 92    |
| % Trucks     | 2.6%                            | 3.4%  | -     | -     | 3.1% | -                            | 1.2%   | 1.2%  | 0.0%  | -      | 1.1%                            | -          | 2.6%   | 5.1%  | 1.5%  | -                            | 2.6% | -          | 4.0%   | 1.7%  | 3.1%        | -     | -     | -    | 2.1%       | 1.9%  |
| Bicycles     | -                               | -     | -     | -     | 0    | -                            | -      | -     | -     | 0      | 0                               | -          | -      | -     | -     | -                            | 0    | 0          | -      | -     | -           | -     | -     | -    | 0          | 0     |
| Pedestrians  | -                               | -     | -     | -     | 11   | -                            | -      | -     | -     | 6      | -                               | -          | -      | -     | -     | -                            | 3    | -          | -      | -     | -           | -     | -     | -    | 1          | 21    |






AM Peak Hour - Four Mile Creek Road & Niagara Stone Road

| Start Time          | Four Mile Creek Road Southbound |           |           |           |          | Niagara Stone Road Westbound |          |           |            |          | Four Mile Creek Road Northbound |            |          |           |           | Niagara Stone Road Eastbound |          |            |          |           | Grand Total |           |          |            |            |   |
|---------------------|---------------------------------|-----------|-----------|-----------|----------|------------------------------|----------|-----------|------------|----------|---------------------------------|------------|----------|-----------|-----------|------------------------------|----------|------------|----------|-----------|-------------|-----------|----------|------------|------------|---|
|                     | U-Turn                          | Left      | Thru      | Right     | Peds     | App. Total                   | U-Turn   | Left      | Thru       | Right    | Peds                            | App. Total | U-Turn   | Left      | Thru      | Right                        | Peds     | App. Total | U-Turn   | Left      |             | Thru      | Right    | Peds       | App. Total |   |
| 8:30                | 0                               | 5         | 10        | 8         | 0        | 23                           | 0        | 15        | 54         | 3        | 2                               | 69         | 0        | 9         | 7         | 19                           | 0        | 35         | 0        | 2         | 54          | 11        | 0        | 77         | 204        |   |
| 8:45                | 0                               | 3         | 11        | 7         | 0        | 21                           | 0        | 20        | 66         | 0        | 0                               | 86         | 0        | 14        | 11        | 35                           | 0        | 60         | 0        | 7         | 72          | 9         | 0        | 88         | 355        |   |
| 9:00                | 0                               | 1         | 6         | 11        | 2        | 18                           | 0        | 21        | 59         | 1        | 0                               | 81         | 0        | 12        | 11        | 33                           | 0        | 55         | 0        | 10        | 72          | 16        | 0        | 98         | 252        |   |
| 9:15                | 0                               | 8         | 14        | 6         | 0        | 28                           | 0        | 17        | 59         | 1        | 0                               | 77         | 0        | 15        | 6         | 38                           | 0        | 59         | 0        | 4         | 71          | 10        | 0        | 85         | 249        |   |
| <b>Hourly Total</b> | <b>0</b>                        | <b>17</b> | <b>41</b> | <b>32</b> | <b>2</b> | <b>90</b>                    | <b>0</b> | <b>73</b> | <b>235</b> | <b>5</b> | <b>2</b>                        | <b>313</b> | <b>0</b> | <b>49</b> | <b>35</b> | <b>125</b>                   | <b>0</b> | <b>209</b> | <b>0</b> | <b>23</b> | <b>279</b>  | <b>46</b> | <b>0</b> | <b>348</b> | <b>960</b> |   |
| Approach %          | 0.0%                            | 18.9%     | 45.6%     | 35.6%     | -        | -                            | 0.0%     | 23.3%     | 75.1%      | 1.6%     | -                               | -          | 0.0%     | 23.4%     | 16.7%     | 59.8%                        | -        | -          | 0.0%     | 6.6%      | 80.2%       | 13.2%     | -        | -          | -          |   |
| Total %             | 0.0%                            | 1.8%      | 4.3%      | 3.3%      | -        | 9.4%                         | 0.0%     | 7.6%      | 24.5%      | 0.5%     | -                               | 32.6%      | 0.0%     | 5.1%      | 3.6%      | 13.0%                        | -        | 21.8%      | 0.0%     | 2.4%      | 29.1%       | 4.8%      | -        | 36.3%      | -          |   |
| PHF                 | 0                               | 0.53      | 0.73      | 0.73      | -        | 0.8                          | 0        | 0.87      | 0.89       | 0.42     | -                               | 0.91       | 0        | 0.82      | 0.8       | 0.82                         | -        | 0.87       | 0        | 0.58      | 0.97        | 0.72      | -        | 0.89       | 0.94       |   |
| Lights              | 0                               | 15        | 40        | 27        | -        | 82                           | 0        | 69        | 228        | 5        | -                               | 302        | 0        | 45        | 30        | 121                          | -        | 196        | 0        | 21        | 267         | 44        | -        | 332        | 912        |   |
| % Trucks            | -                               | 88.2%     | 97.6%     | 84.4%     | -        | 91.1%                        | -        | 84.5%     | 97.0%      | 100.0%   | -                               | 96.5%      | -        | 91.8%     | 85.7%     | 96.8%                        | -        | 92.8%      | -        | 91.3%     | 95.7%       | 95.7%     | -        | 95.4%      | 95.0%      |   |
| % Buses             | -                               | 0         | 0         | 2         | -        | 0                            | -        | 0         | 4          | 0        | -                               | 4          | -        | 0         | 2         | 0                            | -        | 0          | -        | 0         | 2           | 0         | -        | 4          | 12         |   |
| % Trucks + Buses    | -                               | 0.0%      | 0.0%      | 6.3%      | -        | 2.2%                         | -        | 0.0%      | 1.7%       | 0.0%     | -                               | 1.3%       | -        | 2.0%      | 2.9%      | 0.0%                         | -        | 1.6%       | -        | 0.0%      | 0.7%        | 4.3%      | -        | 1.1%       | 1.3%       |   |
| Trucks              | 2                               | 1         | 3         | 3         | -        | 6                            | -        | 4         | 3          | 0        | -                               | 7          | -        | 3         | 4         | 4                            | -        | 11         | -        | 2         | 10          | 0         | -        | 12         | 36         |   |
| % Trucks            | 11.8%                           | 2.4%      | 9.4%      | -         | 6.7%     | -                            | 5.5%     | -         | 1.8%       | 0.0%     | -                               | 2.2%       | -        | 6.1%      | 11.4%     | 3.2%                         | -        | 5.3%       | -        | 8.7%      | 3.6%        | 0.0%      | -        | 3.4%       | 3.8%       |   |
| Bicycles            | -                               | -         | -         | -         | -        | 0                            | -        | -         | -          | -        | -                               | 0          | -        | -         | -         | -                            | -        | -          | -        | -         | -           | -         | -        | -          | 0          | 0 |
| Pedestrians         | -                               | -         | -         | -         | 2        | -                            | -        | -         | -          | 2        | -                               | -          | -        | -         | -         | -                            | -        | -          | -        | -         | -           | -         | -        | -          | 4          |   |



PM Peak Hour - Four Mile Creek Road & Niagara Stone Road

| Start Time   | Four Mile Creek Road Southbound |       |        |       |      |            | Niagara Stone Road Westbound |        |       |        |      |            | Four Mile Creek Road Northbound |       |       |        |      |            | Niagara Stone Road Eastbound |        |        |       |      |            | Grand Total |
|--------------|---------------------------------|-------|--------|-------|------|------------|------------------------------|--------|-------|--------|------|------------|---------------------------------|-------|-------|--------|------|------------|------------------------------|--------|--------|-------|------|------------|-------------|
|              | U-Turn                          | Left  | Thru   | Right | Peds | App. Total | U-Turn                       | Left   | Thru  | Right  | Peds | App. Total | U-Turn                          | Left  | Thru  | Right  | Peds | App. Total | U-Turn                       | Left   | Thru   | Right | Peds | App. Total |             |
| 16:00        | 0                               | 6     | 15     | 11    | 0    | 32         | 0                            | 31     | 105   | 6      | 0    | 142        | 0                               | 26    | 26    | 35     | 1    | 89         | 0                            | 6      | 92     | 12    | 1    | 110        | 373         |
| 16:15        | 0                               | 9     | 8      | 12    | 0    | 29         | 0                            | 38     | 190   | 7      | 0    | 200        | 0                               | 12    | 11    | 25     | 0    | 48         | 0                            | 5      | 78     | 19    | 0    | 102        | 373         |
| 16:30        | 0                               | 9     | 16     | 8     | 0    | 33         | 0                            | 22     | 114   | 7      | 0    | 138        | 0                               | 26    | 21    | 41     | 0    | 88         | 0                            | 4      | 73     | 20    | 0    | 97         | 356         |
| 16:45        | 0                               | 5     | 12     | 4     | 1    | 24         | 0                            | 22     | 91    | 4      | 0    | 117        | 0                               | 8     | 22    | 22     | 0    | 52         | 0                            | 10     | 66     | 17    | 0    | 93         | 386         |
| Hourly Total | 0                               | 26    | 51     | 35    | 1    | 112        | 0                            | 113    | 470   | 14     | 0    | 597        | 0                               | 74    | 80    | 123    | 1    | 277        | 0                            | 25     | 309    | 68    | 1    | 402        | 1388        |
| Approach %   | 0.0%                            | 23.2% | 45.5%  | 31.3% |      |            | 0.0%                         | 18.9%  | 78.7% | 2.3%   |      |            | 0.0%                            | 26.7% | 78.9% | 44.4%  |      |            | 0.0%                         | 6.2%   | 76.9%  | 16.9% |      |            |             |
| Total %      | 0.0%                            | 1.9%  | 3.7%   | 2.5%  |      | 8.3%       | 0.0%                         | 11.8%  | 49.0% | 1.0%   |      | 43.0%      | 0.0%                            | 7.7%  | 8.3%  | 12.8%  |      | 20.0%      | 0.0%                         | 2.6%   | 32.2%  | 7.1%  |      | 29.0%      |             |
| Peak         | 0                               | 0.22  | 0.8    | 0.73  |      | 0.85       | 0                            | 0.74   | 0.73  | 0.58   |      | 0.75       | 0                               | 0.66  | 0.73  | 0.75   |      | 0.78       | 0                            | 0.63   | 0.84   | 0.85  |      | 0.91       | 0.93        |
| Lights       | 0                               | 26    | 49     | 35    |      | 110        | 0                            | 113    | 461   | 14     |      | 588        | 0                               | 73    | 74    | 123    |      | 270        | 0                            | 25     | 309    | 64    |      | 388        | 1366        |
| % Lights     | 100.0%                          | 96.1% | 100.0% | 98.2% |      | 98.2%      |                              | 100.0% | 98.1% | 100.0% |      | 98.5%      |                                 | 98.6% | 92.5% | 100.0% |      | 97.5%      |                              | 100.0% | 100.0% | 94.1% |      | 99.0%      | 98.4%       |
| Busess       | 0                               | 0     | 0      | 0     |      | 0          |                              | 0      | 3     | 0      |      | 3          |                                 | 0     | 1     | 0      |      | 0          |                              | 0      | 0      | 0     |      | 1          | 5           |
| % Buses      | 0.0%                            | 0.0%  | 0.0%   | 0.0%  |      | 0.0%       |                              | 0.0%   | 0.6%  | 0.0%   |      | 0.5%       |                                 | 0.0%  | 1.3%  | 0.0%   |      | 0.4%       |                              | 0.0%   | 0.0%   | 1.5%  |      | 0.2%       | 0.4%        |
| Trucks       | 0                               | 1     | 0      | 0     |      | 1          |                              | 6      | 0     | 0      |      | 6          |                                 | 5     | 0     | 0      |      | 5          |                              | 0      | 0      | 3     |      | 3          | 16          |
| % Trucks     | 0.0%                            | 2.0%  | 0.0%   | 0.0%  |      | 0.9%       |                              | 0.0%   | 1.3%  | 0.0%   |      | 1.0%       |                                 | 1.4%  | 6.3%  | 0.0%   |      | 2.2%       |                              | 0.0%   | 0.0%   | 4.4%  |      | 0.7%       | 1.2%        |
| Bicycles     | -                               | -     | -      | -     |      | 0          |                              | -      | -     | 0      |      | 0          |                                 | -     | -     | -      |      | 0          |                              | -      | -      | -     |      | 0          | 0           |
| Pedestrians  | -                               | -     | -      | -     | 1    |            | -                            | -      | -     | 0      |      | 0          |                                 | -     | -     | -      |      | 0          |                              | -      | -      | -     |      | 0          | 1           |





# APPENDIX C

## DETAILED STAMSON ANALYSIS



```

-----
-----
-90    10    0.00  61.55    0.00  -5.31  -2.55    0.00    0.00
0.00  53.69
-----
-----

```

TOTAL Leq FROM ALL SOURCES (DAY): 55.29  
(NIGHT): 48.80

Segment Leq : 53.69 dBA

Total Leq All Segments: 55.29 dBA

Results segment # 1: NiagaraStone (night)

Source height = 0.85 m

ROAD (0.00 + 43.64 + 0.00) = 43.64 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
-90    90    0.00  56.35    0.00 -12.71    0.00    0.00    0.00
0.00  43.64
-----
-----

```

Segment Leq : 43.64 dBA

Results segment # 2: FMC Road (night)

Source height = 1.12 m

ROAD (0.00 + 47.22 + 0.00) = 47.22 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
-90    10    0.00  55.09    0.00  -5.31  -2.55    0.00    0.00
0.00  47.22
-----
-----

```

Segment Leq : 47.22 dBA

Total Leq All Segments: 48.80 dBA

STAMSON 5.0            NORMAL REPORT            Date: 11-09-2025 15:52:56  
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r0220.te                            Time Period: Day/Night 16/8 hours  
Description: Residential Building West Facade North Corner

Road data, segment # 1: NiagaraStone (day/night)

-----  
Car traffic volume : 13989/1554 veh/TimePeriod \*  
Medium truck volume : 47/5 veh/TimePeriod \*  
Heavy truck volume : 73/8 veh/TimePeriod \*  
Posted speed limit : 50 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 10550  
Percentage of Annual Growth : 2.00  
Number of Years of Growth : 20.00  
Medium Truck % of Total Volume : 0.33  
Heavy Truck % of Total Volume : 0.52  
Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 1: NiagaraStone (day/night)

-----  
Angle1 Angle2 : -90.00 deg 20.00 deg  
Wood depth : 0 (No woods.)  
No of house rows : 0 / 0  
Surface : 2 (Reflective ground surface)  
Receiver source distance : 284.00 / 284.00 m  
Receiver height : 13.05 / 13.05 m  
Topography : 1 (Flat/gentle slope; no barrier)  
Reference angle : 0.00

Results segment # 1: NiagaraStone (day)

-----  
Source height = 0.85 m

ROAD (0.00 + 47.99 + 0.00) = 47.99 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-90 20 0.00 62.90 0.00 -12.77 -2.14 0.00 0.00  
0.00 47.99

-----  
Segment Leq : 47.99 dBA

Total Leq All Segments: 47.99 dBA

Results segment # 1: NiagaraStone (night)

-----  
Source height = 0.85 m

ROAD (0.00 + 41.44 + 0.00) = 41.44 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-----  
-90 20 0.00 56.35 0.00 -12.77 -2.14 0.00 0.00  
0.00 41.44

-----  
Segment Leq : 41.44 dBA

Total Leq All Segments: 41.44 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 47.99  
(NIGHT): 41.44 STAMSON 5.0            NORMAL  
REPORT            Date: 11-02-2025 16:02:11  
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r02.te                            Time Period: Day/Night 16/8 hours  
Description:

Road data, segment # 1: NiagaraStone (day/night)

-----  
Car traffic volume : 11476/1275 veh/TimePeriod \*  
Medium truck volume : 38/4 veh/TimePeriod \*  
Heavy truck volume : 60/7 veh/TimePeriod \*  
Posted speed limit : 50 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 10550  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 10.00  
 Medium Truck % of Total Volume : 0.33  
 Heavy Truck % of Total Volume : 0.52  
 Day (16 hrs) % of Total Volume : 90.00

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj  | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|--------|-------|-------|-------|
| -90    | 20     | 0.00  | 55.55  | 0.00  | -12.77 | -2.14 | 0.00  | 0.00  |
| 0.00   | 40.64  |       |        |       |        |       |       |       |

Data for Segment # 1: NiagaraStone (day/night)

Angle1 Angle2 : -90.00 deg 20.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 284.00 / 284.00 m  
 Receiver height : 13.05 / 13.05 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Segment Leq : 40.64 dBA

Total Leq All Segments: 40.64 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 47.13  
 (NIGHT): 40.64

Results segment # 1: NiagaraStone (day)

Source height = 0.85 m

ROAD (0.00 + 47.13 + 0.00) = 47.13 dBA

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj  | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|--------|-------|-------|-------|
| -90    | 20     | 0.00  | 62.04  | 0.00  | -12.77 | -2.14 | 0.00  | 0.00  |
| 0.00   | 47.13  |       |        |       |        |       |       |       |

Segment Leq : 47.13 dBA

Total Leq All Segments: 47.13 dBA

Results segment # 1: NiagaraStone (night)

Source height = 0.86 m

ROAD (0.00 + 40.64 + 0.00) = 40.64 dBA

STAMSON 5.0 NORMAL REPORT Date: 11-09-2025 16:01:39  
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r0320.te Time Period: Day/Night 16/8 hours  
Description: Residential Building South Facade

Road data, segment # 1: FMC Road (day/night)

-----  
Car traffic volume : 6638/738 veh/TimePeriod \*  
Medium truck volume : 65/7 veh/TimePeriod \*  
Heavy truck volume : 104/12 veh/TimePeriod \*  
Posted speed limit : 50 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 5090  
Percentage of Annual Growth : 2.00  
Number of Years of Growth : 20.00  
Medium Truck % of Total Volume : 0.96  
Heavy Truck % of Total Volume : 1.53  
Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 1: FMC Road (day/night)

-----  
Angle1 Angle2 : 10.00 deg 90.00 deg  
Wood depth : 0 (No woods.)  
No of house rows : 0 / 0  
Surface : 2 (Reflective ground surface)  
Receiver source distance : 72.00 / 72.00 m  
Receiver height : 13.05 / 13.05 m  
Topography : 1 (Flat/gentle slope; no barrier)  
Reference angle : 0.00

Results segment # 1: FMC Road (day)

-----  
Source height = 1.11 m

ROAD (0.00 + 51.22 + 0.00) = 51.22 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

10 90 0.00 61.55 0.00 -6.81 -3.52 0.00 0.00  
0.00 51.22

-----  
Segment Leq : 51.22 dBA

Total Leq All Segments: 51.22 dBA

Results segment # 1: FMC Road (night)

-----  
Source height = 1.12 m

ROAD (0.00 + 44.76 + 0.00) = 44.76 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-----  
10 90 0.00 55.09 0.00 -6.81 -3.52 0.00 0.00  
0.00 44.76

-----  
Segment Leq : 44.76 dBA

Total Leq All Segments: 44.76 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 51.22  
(NIGHT): 44.76 STAMSON 5.0 NORMAL  
REPORT Date: 11-02-2025 16:01:53  
MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: r03.te Time Period: Day/Night 16/8 hours  
Description: Residential Building South Façade

Road data, segment # 1: FMC Road (day/night)

-----  
Car traffic volume : 5445/605 veh/TimePeriod \*  
Medium truck volume : 54/6 veh/TimePeriod \*  
Heavy truck volume : 85/9 veh/TimePeriod \*  
Posted speed limit : 50 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 5090  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 10.00  
 Medium Truck % of Total Volume : 0.96  
 Heavy Truck % of Total Volume : 1.53  
 Day (16 hrs) % of Total Volume : 90.00

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|-------|-------|-------|-------|
| 10     | 90     | 0.00  | 54.06  | 0.00  | -6.81 | -3.52 | 0.00  | 0.00  |
| 0.00   | 43.73  |       |        |       |       |       |       |       |

Data for Segment # 1: FMC Road (day/night)

Angle1 Angle2 : 10.00 deg 90.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 72.00 / 72.00 m  
 Receiver height : 13.05 / 13.05 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Segment Leq : 43.73 dBA

Total Leq All Segments: 43.73 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 50.35  
 (NIGHT): 43.73

Results segment # 1: FMC Road (day)

Source height = 1.11 m

ROAD (0.00 + 50.35 + 0.00) = 50.35 dBA

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|-------|-------|-------|-------|
| 10     | 90     | 0.00  | 60.69  | 0.00  | -6.81 | -3.52 | 0.00  | 0.00  |
| 0.00   | 50.35  |       |        |       |       |       |       |       |

Segment Leq : 50.35 dBA

Total Leq All Segments: 50.35 dBA

Results segment # 1: FMC Road (night)

Source height = 1.10 m

ROAD (0.00 + 43.73 + 0.00) = 43.73 dBA

Filename: r0420.te                    Time Period: Day/Night 16/8 hours  
 Description: Office Building North Facade East Corner

Road data, segment # 1: NiagaraStone (day/night)

-----  
 Car traffic volume : 13989/1554 veh/TimePeriod \*  
 Medium truck volume : 47/5 veh/TimePeriod \*  
 Heavy truck volume : 73/8 veh/TimePeriod \*  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 10550  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 20.00  
 Medium Truck % of Total Volume : 0.33  
 Heavy Truck % of Total Volume : 0.52  
 Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 1: NiagaraStone (day/night)

-----  
 Angle1 Angle2 : -90.00 deg 90.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 280.00 / 280.00 m  
 Receiver height : 7.00 / 7.00 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Road data, segment # 2: FMC Road (day/night)

-----  
 Car traffic volume : 6638/738 veh/TimePeriod \*  
 Medium truck volume : 65/7 veh/TimePeriod \*  
 Heavy truck volume : 104/12 veh/TimePeriod \*  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 5090  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 20.00  
 Medium Truck % of Total Volume : 0.96  
 Heavy Truck % of Total Volume : 1.53  
 Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 2: FMC Road (day/night)

-----  
 Angle1 Angle2 : -90.00 deg 20.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 15.00 / 15.00 m  
 Receiver height : 7.00 / 7.00 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Results segment # 1: NiagaraStone (day)

-----  
 Source height = 0.85 m

ROAD (0.00 + 50.19 + 0.00) = 50.19 dBA

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj  | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|--------|-------|-------|-------|
| 0.00   | 50.19  | 90    | 62.90  | 0.00  | -12.71 | 0.00  | 0.00  | 0.00  |

-----  
 Segment Leq : 50.19 dBA

Results segment # 2: FMC Road (day)

-----  
 Source height = 1.11 m

ROAD (0.00 + 59.41 + 0.00) = 59.41 dBA

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|-------|-------|-------|-------|
| B.Adj  | SubLeq |       |        |       |       |       |       |       |

```

-----
-----
-90    20    0.00  61.55    0.00    0.00  -2.14    0.00    0.00
0.00  59.41
-----
-----

```

TOTAL Leq FROM ALL SOURCES (DAY): 59.90  
(NIGHT): 53.43

Segment Leq : 59.41 dBA

Total Leq All Segments: 59.90 dBA

Results segment # 1: NiagaraStone (night)

Source height = 0.85 m

ROAD (0.00 + 43.64 + 0.00) = 43.64 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
-90    90    0.00  56.35    0.00 -12.71    0.00    0.00    0.00
0.00  43.64
-----
-----

```

Segment Leq : 43.64 dBA

Results segment # 2: FMC Road (night)

Source height = 1.12 m

ROAD (0.00 + 52.95 + 0.00) = 52.95 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
-90    20    0.00  55.09    0.00    0.00  -2.14    0.00    0.00
0.00  52.95
-----
-----

```

Segment Leq : 52.95 dBA

Total Leq All Segments: 53.43 dBA



```

-----
-----
  40    90    0.00  61.55    0.00  -2.22  -5.56    0.00    0.00
0.00  53.77
-----
-----

```

TOTAL Leq FROM ALL SOURCES (DAY): 54.34  
(NIGHT): 47.87

Segment Leq : 53.77 dBA

Total Leq All Segments: 54.34 dBA

Results segment # 1: NiagaraStone (night)

Source height = 0.85 m

ROAD (0.00 + 38.72 + 0.00) = 38.72 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
  -90   -20    0.00  56.35    0.00 -13.53  -4.10    0.00    0.00
0.00  38.72
-----
-----

```

Segment Leq : 38.72 dBA

Results segment # 2: FMC Road (night)

Source height = 1.12 m

ROAD (0.00 + 47.31 + 0.00) = 47.31 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
  40    90    0.00  55.09    0.00  -2.22  -5.56    0.00    0.00
0.00  47.31
-----
-----

```

Segment Leq : 47.31 dBA

Total Leq All Segments: 47.87 dBA



```

-----
-----
      60      90      0.00  63.29      0.00  -4.37  -7.78      0.00      0.00
0.00  51.14
-----
-----

```

TOTAL Leq FROM ALL SOURCES (DAY): 59.66  
(NIGHT): 53.20

Segment Leq : 51.14 dBA

Total Leq All Segments: 59.66 dBA

Results segment # 1: FMC Road (night)

Source height = 1.12 m

ROAD (0.00 + 52.54 + 0.00) = 52.54 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
     -10      90      0.00  55.09      0.00      0.00  -2.55      0.00      0.00
0.00  52.54
-----
-----

```

Segment Leq : 52.54 dBA

Results segment # 2: FMC Rd 60 (night)

Source height = 1.12 m

ROAD (0.00 + 44.67 + 0.00) = 44.67 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

```

-----
-----
      60      90      0.00  56.82      0.00  -4.37  -7.78      0.00      0.00
0.00  44.67
-----
-----

```

Segment Leq : 44.67 dBA

Total Leq All Segments: 53.20 dBA

Filename: r0720.te                    Time Period: Day/Night 16/8 hours  
 Description: Office Building East Facade North Corner

Road data, segment # 1: NiagaraStone (day/night)

-----  
 Car traffic volume : 13989/1554 veh/TimePeriod \*  
 Medium truck volume : 47/5 veh/TimePeriod \*  
 Heavy truck volume : 73/8 veh/TimePeriod \*  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 10550  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 20.00  
 Medium Truck % of Total Volume : 0.33  
 Heavy Truck % of Total Volume : 0.52  
 Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 1: NiagaraStone (day/night)

-----  
 Angle1 Angle2 : -10.00 deg 90.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 304.00 / 304.00 m  
 Receiver height : 7.00 / 7.00 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Road data, segment # 2: FMC Road (day/night)

-----  
 Car traffic volume : 6638/738 veh/TimePeriod \*  
 Medium truck volume : 65/7 veh/TimePeriod \*  
 Heavy truck volume : 104/12 veh/TimePeriod \*  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 5090  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 20.00  
 Medium Truck % of Total Volume : 0.96  
 Heavy Truck % of Total Volume : 1.53  
 Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 2: FMC Road (day/night)

-----  
 Angle1 Angle2 : -90.00 deg 90.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 15.00 / 15.00 m  
 Receiver height : 7.00 / 7.00 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Results segment # 1: NiagaraStone (day)

-----  
 Source height = 0.85 m

ROAD (0.00 + 47.28 + 0.00) = 47.28 dBA  
 Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
 B.Adj SubLeq

-----  
 -10 90 0.00 62.90 0.00 -13.07 -2.55 0.00 0.00  
 0.00 47.28  
 -----

Segment Leq : 47.28 dBA

Results segment # 2: FMC Road (day)

-----  
 Source height = 1.11 m

ROAD (0.00 + 61.55 + 0.00) = 61.55 dBA  
 Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
 B.Adj SubLeq

```

-----
-----
-90    90    0.00  61.55    0.00    0.00    0.00    0.00    0.00
0.00  61.55
-----
-----

```

TOTAL Leq FROM ALL SOURCES (DAY): 61.71  
(NIGHT): 55.

Segment Leq : 61.55 dBA

Total Leq All Segments: 61.71 dBA

Results segment # 1: NiagaraStone (night)

```

-----
Source height = 0.85 m

ROAD (0.00 + 40.73 + 0.00) = 40.73 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj
B.Adj SubLeq
-----

```

```

-----
-10    90    0.00  56.35    0.00 -13.07  -2.55    0.00    0.00
0.00  40.73
-----
-----

```

Segment Leq : 40.73 dBA

Results segment # 2: FMC Road (night)

```

-----
Source height = 1.12 m

ROAD (0.00 + 55.09 + 0.00) = 55.09 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj
B.Adj SubLeq
-----

```

```

-----
-90    90    0.00  55.09    0.00    0.00    0.00    0.00    0.00
0.00  55.09
-----
-----

```

Segment Leq : 55.09 dBA

Total Leq All Segments: 55.25 dBA

Filename: r0820.te                    Time Period: Day/Night 16/8 hours  
Description: Office Building East Facade South Corner

Road data, segment # 1: NiagaraStone (day/night)

-----  
Car traffic volume : 13989/1554    veh/TimePeriod \*  
Medium truck volume : 47/5        veh/TimePeriod \*  
Heavy truck volume : 73/8        veh/TimePeriod \*  
Posted speed limit : 50 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 10550  
Percentage of Annual Growth : 2.00  
Number of Years of Growth : 20.00  
Medium Truck % of Total Volume : 0.33  
Heavy Truck % of Total Volume : 0.52  
Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 1: NiagaraStone (day/night)

-----  
Angle1 Angle2 : -10.00 deg 90.00 deg  
Wood depth : 0 (No woods.)  
No of house rows : 0 / 0  
Surface : 2 (Reflective ground surface)  
Receiver source distance : 385.00 / 385.00 m  
Receiver height : 7.00 / 7.00 m  
Topography : 1 (Flat/gentle slope; no barrier)  
Reference angle : 0.00

Road data, segment # 2: FMC Road (day/night)

-----  
Car traffic volume : 6638/738    veh/TimePeriod \*  
Medium truck volume : 65/7        veh/TimePeriod \*  
Heavy truck volume : 104/12     veh/TimePeriod \*  
Posted speed limit : 50 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 5090  
Percentage of Annual Growth : 2.00  
Number of Years of Growth : 20.00  
Medium Truck % of Total Volume : 0.96  
Heavy Truck % of Total Volume : 1.53  
Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 2: FMC Road (day/night)

-----  
Angle1 Angle2 : -90.00 deg 90.00 deg  
Wood depth : 0 (No woods.)  
No of house rows : 0 / 0  
Surface : 2 (Reflective ground surface)  
Receiver source distance : 15.00 / 15.00 m  
Receiver height : 7.00 / 7.00 m  
Topography : 1 (Flat/gentle slope; no barrier)  
Reference angle : 0.00

Road data, segment # 3: FMC Rd 60 (day/night)

-----  
Car traffic volume : 6638/738    veh/TimePeriod \*  
Medium truck volume : 65/7        veh/TimePeriod \*  
Heavy truck volume : 104/12     veh/TimePeriod \*  
Posted speed limit : 60 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 5090  
Percentage of Annual Growth : 2.00  
Number of Years of Growth : 20.00  
Medium Truck % of Total Volume : 0.96  
Heavy Truck % of Total Volume : 1.53  
Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 3: FMC Rd 60 (day/night)

-----  
Angle1 Angle2 : 60.00 deg 90.00 deg  
Wood depth : 0 (No woods.)  
No of house rows : 0 / 0  
Surface : 2 (Reflective ground surface)  
Receiver source distance : 51.00 / 51.00 m  
Receiver height : 7.00 / 4.50 m

Topography : 1 (Flat/gentle slope; no barrier)  
Reference angle : 0.00

Results segment # 1: NiagaraStone (day)

Source height = 0.85 m

ROAD (0.00 + 46.26 + 0.00) = 46.26 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-10 90 0.00 62.90 0.00 -14.09 -2.55 0.00 0.00  
0.00 46.26

Segment Leq : 46.26 dBA

Results segment # 2: FMC Road (day)

Source height = 1.11 m

ROAD (0.00 + 61.55 + 0.00) = 61.55 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-90 90 0.00 61.55 0.00 0.00 0.00 0.00 0.00  
0.00 61.55

Segment Leq : 61.55 dBA

Results segment # 3: FMC Rd 60 (day)

Source height = 1.11 m

ROAD (0.00 + 50.20 + 0.00) = 50.20 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

60 90 0.00 63.29 0.00 -5.31 -7.78 0.00 0.00  
0.00 50.20

Segment Leq : 50.20 dBA

Total Leq All Segments: 61.98 dBA

Results segment # 1: NiagaraStone (night)

Source height = 0.85 m

ROAD (0.00 + 39.70 + 0.00) = 39.70 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-10 90 0.00 56.35 0.00 -14.09 -2.55 0.00 0.00  
0.00 39.70

Segment Leq : 39.70 dBA

Results segment # 2: FMC Road (night)

Source height = 1.12 m

ROAD (0.00 + 55.09 + 0.00) = 55.09 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-90 90 0.00 55.09 0.00 0.00 0.00 0.00 0.00  
0.00 55.09

Segment Leq : 55.09 dBA

Results segment # 3: FMC Rd 60 (night)

-----  
Source height = 1.12 m

ROAD (0.00 + 43.72 + 0.00) = 43.72 dBA

Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq

-----  
-----  
60 90 0.00 56.82 0.00 -5.31 -7.78 0.00 0.00  
0.00 43.72  
-----  
-----

Segment Leq : 43.72 dBA

Total Leq All Segments: 55.51 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 61.98  
(NIGHT): 55.51

Filename: r0920.te                    Time Period: Day/Night 16/8 hours  
 Description: Office Building North Facade West Corner

Road data, segment # 1: NiagaraStone (day/night)

-----  
 Car traffic volume : 13989/1554 veh/TimePeriod \*  
 Medium truck volume : 47/5 veh/TimePeriod \*  
 Heavy truck volume : 73/8 veh/TimePeriod \*  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 10550  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 20.00  
 Medium Truck % of Total Volume : 0.33  
 Heavy Truck % of Total Volume : 0.52  
 Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 1: NiagaraStone (day/night)

-----  
 Angle1 Angle2 : -90.00 deg 90.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 281.00 / 281.00 m  
 Receiver height : 7.00 / 7.00 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Road data, segment # 2: FMC Road (day/night)

-----  
 Car traffic volume : 6638/738 veh/TimePeriod \*  
 Medium truck volume : 65/7 veh/TimePeriod \*  
 Heavy truck volume : 104/12 veh/TimePeriod \*  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 5090  
 Percentage of Annual Growth : 2.00  
 Number of Years of Growth : 20.00  
 Medium Truck % of Total Volume : 0.96  
 Heavy Truck % of Total Volume : 1.53  
 Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 2: FMC Road (day/night)

-----  
 Angle1 Angle2 : -90.00 deg -10.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0 / 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 29.00 / 29.00 m  
 Receiver height : 7.00 / 7.00 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Results segment # 1: NiagaraStone (day)

-----  
 Source height = 0.85 m

ROAD (0.00 + 50.18 + 0.00) = 50.18 dBA  
 Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
 B.Adj SubLeq  
 -----  
 -90 90 0.00 62.90 0.00 -12.73 0.00 0.00 0.00  
 0.00 50.18  
 -----

Segment Leq : 50.18 dBA

Results segment # 2: FMC Road (day)

-----  
 Source height = 1.11 m

ROAD (0.00 + 55.17 + 0.00) = 55.17 dBA  
 Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
 B.Adj SubLeq

```

-----
-----
-90   -10   0.00  61.55   0.00  -2.86  -3.52   0.00   0.00
0.00  55.17
-----
-----

```

TOTAL Leq FROM ALL SOURCES (DAY): 56.37  
(NIGHT): 49.87

Segment Leq : 55.17 dBA

Total Leq All Segments: 56.37 dBA

Results segment # 1: NiagaraStone (night)

```

-----
Source height = 0.85 m

ROAD (0.00 + 43.62 + 0.00) = 43.62 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj
B.Adj SubLeq
-----

```

```

-----
-90    90    0.00  56.35   0.00 -12.73   0.00   0.00   0.00
0.00  43.62
-----
-----

```

Segment Leq : 43.62 dBA

Results segment # 2: FMC Road (night)

```

-----
Source height = 1.12 m

ROAD (0.00 + 48.70 + 0.00) = 48.70 dBA
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj
B.Adj SubLeq
-----

```

```

-----
-90   -10   0.00  55.09   0.00  -2.86  -3.52   0.00   0.00
0.00  48.70
-----
-----

```

Segment Leq : 48.70 dBA

Total Leq All Segments: 49.87 dBA

Filename: r1020.te                    Time Period: Day/Night 16/8 hours  
Description: Residential Building West Facade South Corner

Road data, segment # 1: NiagaraStone (day/night)

-----  
Car traffic volume : 13989/1554 veh/TimePeriod \*  
Medium truck volume : 47/5 veh/TimePeriod \*  
Heavy truck volume : 73/8 veh/TimePeriod \*  
Posted speed limit : 50 km/h  
Road gradient : 0 %  
Road pavement : 1 (Typical asphalt or concrete)

\* Refers to calculated road volumes based on the following input:

24 hr Traffic Volume (AADT or SADT): 10550  
Percentage of Annual Growth : 2.00  
Number of Years of Growth : 20.00  
Medium Truck % of Total Volume : 0.33  
Heavy Truck % of Total Volume : 0.52  
Day (16 hrs) % of Total Volume : 90.00

Data for Segment # 1: NiagaraStone (day/night)

-----  
Angle1 Angle2 : -90.00 deg 20.00 deg  
Wood depth : 0 (No woods.)  
No of house rows : 0 / 0  
Surface : 2 (Reflective ground surface)  
Receiver source distance : 350.00 / 350.00 m  
Receiver height : 13.05 / 13.05 m  
Topography : 1 (Flat/gentle slope; no barrier)  
Reference angle : 0.00

Results segment # 1: NiagaraStone (day)

-----  
Source height = 0.85 m

ROAD (0.00 + 47.09 + 0.00) = 47.09 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq  
-----  
-----

-90 20 0.00 62.90 0.00 -13.68 -2.14 0.00 0.00  
0.00 47.09  
-----

-----  
Segment Leq : 47.09 dBA

Total Leq All Segments: 47.09 dBA

Results segment # 1: NiagaraStone (night)

-----  
Source height = 0.85 m

ROAD (0.00 + 40.53 + 0.00) = 40.53 dBA  
Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
B.Adj SubLeq  
-----

-----  
-90 20 0.00 56.35 0.00 -13.68 -2.14 0.00 0.00  
0.00 40.53  
-----

-----  
Segment Leq : 40.53 dBA

Total Leq All Segments: 40.53 dBA

TOTAL Leq FROM ALL SOURCES (DAY): 47.09  
(NIGHT): 40.53

Filename: ola01.te                    Time Period: 16 hours  
 Description: Residential Building 4th Floor West Balcony

Road data, segment # 1: NiagaraStone

-----  
 Car traffic volume : 10362 veh/TimePeriod  
 Medium truck volume : 35 veh/TimePeriod  
 Heavy truck volume : 54 veh/TimePeriod  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 1: NiagaraStone

-----  
 Angle1    Angle2            : -90.00 deg    20.00 deg  
 Wood depth                : 0            (No woods.)  
 No of house rows         : 0  
 Surface                    : 2            (Reflective ground surface)  
 Receiver source distance : 286.00 m  
 Receiver height          : 1.50 m  
 Topography                : 0            (Define your own alpha.)  
 Barrier angle1            : -90.00 deg    Angle2 : 20.00 deg  
 Barrier height            : 1.10 m  
 Barrier receiver distance : 2.00 m  
 Source elevation         : 0.00 m  
 Receiver elevation        : 11.25 m  
 Barrier elevation         : 11.25 m  
 Alpha                     : 0.00  
 Reference angle          : 0.00

Results segment # 1: NiagaraStone

-----  
 Source height = 0.85 m

Barrier height for grazing incidence

-----  
 Source        ! Receiver    ! Barrier        ! Elevation of  
 Height (m) ! Height (m) ! Height (m) ! Barrier Top (m)  
 -----+-----+-----+-----  
 0.85 !        1.50 !        1.42 !        12.67

ROAD (0.00 + 46.66 + 0.00) = 46.66 dBA

Angle1 Angle2    Alpha RefLeq    P.Adj    D.Adj    F.Adj    W.Adj    H.Adj  
 B.Adj SubLeq

-----  
 -90     20     0.00 61.60    0.00 -12.80   -2.14    0.00    0.00    -  
 3.96 42.70\*  
 -90     20     0.00 61.60    0.00 -12.80   -2.14    0.00    0.00  
 0.00 46.66  
 -----

-----  
 \* Bright Zone !

Segment Leq : 46.66 dBA

Total Leq All Segments: 46.66 dBA

TOTAL Leq FROM ALL SOURCES:            46.66

Filename: ola02.te                    Time Period: 16 hours  
 Description: At-Grade Residential Patio

Road data, segment # 1: NiagaraStone

-----  
 Car traffic volume : 10362 veh/TimePeriod  
 Medium truck volume : 35 veh/TimePeriod  
 Heavy truck volume : 54 veh/TimePeriod  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 1: NiagaraStone

-----  
 Angle1 Angle2 : 10.00 deg 40.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 320.00 m  
 Receiver height : 1.50 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Road data, segment # 2: FMC Road

-----  
 Car traffic volume : 4917 veh/TimePeriod  
 Medium truck volume : 48 veh/TimePeriod  
 Heavy truck volume : 77 veh/TimePeriod  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 2: FMC Road

-----  
 Angle1 Angle2 : -90.00 deg -60.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 44.00 m  
 Receiver height : 1.50 m  
 Topography : 1 (Flat/gentle slope; no barrier)

Reference angle : 0.00

Road data, segment # 3: FMC Rd 60

-----  
 Car traffic volume : 4917 veh/TimePeriod  
 Medium truck volume : 48 veh/TimePeriod  
 Heavy truck volume : 77 veh/TimePeriod  
 Posted speed limit : 60 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 3: FMC Rd 60

-----  
 Angle1 Angle2 : 60.00 deg 90.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 83.00 m  
 Receiver height : 1.50 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Results segment # 1: NiagaraStone

-----  
 Source height = 0.85 m

ROAD (0.00 + 40.53 + 0.00) = 40.53 dBA  
 Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
 B.Adj SubLeq

-----  
 10 40 0.00 61.60 0.00 -13.29 -7.78 0.00 0.00  
 0.00 40.53  
 -----

-----  
 Segment Leq : 40.53 dBA

Results segment # 2: FMC Road

-----  
 Source height = 1.11 m

ROAD (0.00 + 47.80 + 0.00) = 47.80 dBA

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|-------|-------|-------|-------|
|--------|--------|-------|--------|-------|-------|-------|-------|-------|

B.Adj SubLeq

-----  
-----  
-90 -60 0.00 60.26 0.00 -4.67 -7.78 0.00 0.00  
0.00 47.80  
-----  
-----

Segment Leq : 47.80 dBA

Results segment # 3: FMC Rd 60  
-----

Source height = 1.11 m

ROAD (0.00 + 46.78 + 0.00) = 46.78 dBA

| Angle1 | Angle2 | Alpha | RefLeq | P.Adj | D.Adj | F.Adj | W.Adj | H.Adj |
|--------|--------|-------|--------|-------|-------|-------|-------|-------|
|--------|--------|-------|--------|-------|-------|-------|-------|-------|

B.Adj SubLeq

-----  
-----  
60 90 0.00 61.99 0.00 -7.43 -7.78 0.00 0.00  
0.00 46.78  
-----  
-----

Segment Leq : 46.78 dBA

Total Leq All Segments: 50.76 dBA

TOTAL Leq FROM ALL SOURCES: 50.76

STAMSON 5.0            COMPREHENSIVE REPORT            Date: 10-12-2025  
 11:28:43  
 MINISTRY OF ENVIRONMENT AND ENERGY / NOISE ASSESSMENT

Filename: ola03.te            Time Period: 16 hours  
 Description: Rooftop Pool

Road data, segment # 1: NiagaraStone

-----  
 Car traffic volume : 10362 veh/TimePeriod  
 Medium truck volume : 35 veh/TimePeriod  
 Heavy truck volume : 54 veh/TimePeriod  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 1: NiagaraStone

-----  
 Angle1 Angle2 : -90.00 deg -45.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 349.00 m  
 Receiver height : 17.35 m  
 Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Road data, segment # 2: FMC Road

-----  
 Car traffic volume : 4917 veh/TimePeriod  
 Medium truck volume : 48 veh/TimePeriod  
 Heavy truck volume : 77 veh/TimePeriod  
 Posted speed limit : 50 km/h  
 Road gradient : 0 %  
 Road pavement : 1 (Typical asphalt or concrete)

Data for Segment # 2: FMC Road

-----  
 Angle1 Angle2 : 40.00 deg 90.00 deg  
 Wood depth : 0 (No woods.)  
 No of house rows : 0  
 Surface : 2 (Reflective ground surface)  
 Receiver source distance : 96.00 m  
 Receiver height : 17.35 m

Topography : 1 (Flat/gentle slope; no barrier)  
 Reference angle : 0.00

Segment # 1: NiagaraStone

-----  
 Source height = 0.85 m

ROAD (0.00 + 41.91 + 0.00) = 41.91 dBA  
 Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
 B.Adj SubLeq  
 -----  
 -90 -45 0.00 61.60 0.00 -13.67 -6.02 0.00 0.00  
 0.00 41.91  
 -----

Segment Leq : 41.91 dBA

Segment # 2: FMC Road

-----  
 Source height = 1.11 m

ROAD (0.00 + 46.62 + 0.00) = 46.62 dBA  
 Angle1 Angle2 Alpha RefLeq P.Adj D.Adj F.Adj W.Adj H.Adj  
 B.Adj SubLeq  
 -----  
 40 90 0.00 60.25 0.00 -8.06 -5.56 0.00 0.00  
 0.00 46.62  
 -----

Segment Leq : 46.62 dBA

Total Leq All Segments: 47.88 dBA

TOTAL Leq FROM ALL SOURCES: 47.88



# APPENDIX D

## SAMPLE CADNA/A ANALYSIS

Project: 1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise Sources)  
Project Number: 25253

| Source ID         | Source Name                   | Point of Reception RP02<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP01<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP04<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP05<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP03<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP07<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP06<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP09<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP08<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day | Point of Reception RP10<br>Distance to POR (m)<br>Sound Level at POR (dBA)<br>Day |     |    |     |    |     |    |     |    |     |    |
|-------------------|-------------------------------|---|---|---|---|---|---|---|---|---|---|-----|----|-----|----|-----|----|-----|----|-----|----|
| L01               | 15-Ton Pass-by                | 193   | 8   | 170   | 32  | 133   | 34  | 161   | 9   | 197   | 7   | 129 | 34 | 152 | 18 | 170 | 10 | 179 | 16 | 194 | 31 |
| L02               | 5-Ton Pass-by 2               | 268   | 19  | 224   | 33  | 205   | 30  | 256   | 11  | 259   | 12  | 205 | 30 | 251 | 14 | 246 | 23 | 235 | 31 | 262 | 32 |
| S43               | 5-Ton Aggregate Loading Cycle | 177   | 16  | 149   | 38  | 112   | 40  | 147   | 18  | 182   | 15  | 110 | 39 | 139 | 21 | 153 | 19 | 158 | 23 | 177 | 34 |
| L03               | 5-Ton Pass-by                 | 193   | 8   | 170   | 32  | 133   | 34  | 161   | 9   | 197   | 7   | 129 | 34 | 152 | 18 | 170 | 10 | 179 | 16 | 194 | 31 |
| L04               | 5-Ton Pass-by 2               | 260   | 10  | 224   | 24  | 205   | 21  | 256   | 4   | 259   | 4   | 205 | 21 | 253 | 5  | 246 | 14 | 235 | 22 | 262 | 23 |
| S29               | Loading Hauler                | 314   | 14  | 349   | 3   | 382   | 1   | 346   | 13  | 309   | 14  | 383 | 9  | 357 | 13 | 335 | 11 | 339 | 13 | 314 | 14 |
| S40               | Dirt Loading Cycle            | 196   | 12  | 164   | 37  | 129   | 39  | 169   | 12  | 201   | 11  | 127 | 39 | 162 | 16 | 172 | 16 | 174 | 22 | 196 | 35 |
| S41               | Gravel Loading Cycle          | 174   | 18  | 141   | 44  | 107   | 46  | 152   | 18  | 181   | 16  | 105 | 46 | 146 | 23 | 151 | 22 | 151 | 30 | 175 | 42 |
| S15               | HWAC RTU                      | 245   | 19  | 204   | 27  | 188   | 29  | 252   | 11  | 257   | 7   | 192 | 29 | 253 | 11 | 232 | 27 | 211 | 27 | 250 | 20 |
| S17               | HWAC RTU                      | 154   | 9   | 114   | 29  | 87  | 31  | 147   | 7   | 163   | 4   | 89  | 31 | 116 | 11 | 134 | 16 | 122 | 15 | 156 | 23 |
| S14               | HWAC RTU                      | 248   | 13  | 207   | 25  | 190   | 26  | 254   | 5   | 260   | 3   | 194 | 26 | 254 | 5  | 234 | 17 | 214 | 25 | 253 | 17 |
| S08               | HWAC RTU                      | 276   | 8   | 239   | 27  | 207   | 28  | 257   | 6   | 263   | 9   | 207 | 28 | 251 | 13 | 234 | 11 | 249 | 19 | 277 | 25 |
| S16               | HWAC RTU                      | 158   | 9   | 119   | 29  | 91  | 30  | 149   | 7   | 167   | 6   | 92  | 30 | 141 | 11 | 138 | 14 | 128 | 22 | 160 | 26 |
| S26               | HWAC RTU                      | 282   | 25  | 311   | 13  | 346   | 9   | 311   | 24  | 276   | 26  | 348 | 4  | 333 | 24 | 326 | 8  | 321 | 25 | 281 | 25 |
| S11               | HWAC RTU                      | 284   | 8   | 247   | 27  | 216   | 28  | 268   | 6   | 293   | 8   | 217 | 28 | 263 | 12 | 263 | 12 | 256 | 20 | 286 | 25 |
| S35               | HWAC RTU                      | 286   | 6   | 254   | 26  | 219   | 27  | 257   | 7   | 291   | 9   | 218 | 27 | 248 | 15 | 252 | 9  | 264 | 15 | 286 | 25 |
| S10               | HWAC RTU                      | 287   | 8   | 250   | 27  | 219   | 28  | 270   | 6   | 295   | 8   | 219 | 28 | 284 | 12 | 266 | 11 | 259 | 20 | 289 | 25 |
| S27               | HWAC RTU                      | 288   | 25  | 319   | 11  | 353   | 8   | 317   | 24  | 286   | 25  | 355 | 24 | 326 | 24 | 313 | 8  | 309 | 14 | 291 | 25 |
| S25               | HWAC RTU                      | 290   | 22  | 310   | 8   | 346   | 14  | 336   | 21  | 291   | 22  | 349 | 1  | 349 | 12 | 313 | 2  | 300 | 22 | 293 | 22 |
| S34               | HWAC RTU                      | 319   | 6   | 291   | 25  | 255   | 26  | 285   | 6   | 322   | 9   | 252 | 26 | 275 | 15 | 295 | 8  | 300 | 13 | 318 | 24 |
| S18               | HWAC RTU                      | 327   | 23  | 287   | 24  | 276   | 26  | 341   | 11  | 340   | 7   | 281 | 25 | 342 | 8  | 317 | 24 | 292 | 24 | 333 | 20 |
| S36               | HWAC RTU                      | 328   | 2   | 266   | 23  | 232   | 24  | 276   | 2   | 317   | 3   | 231 | 24 | 268 | 8  | 273 | 4  | 276 | 11 | 311 | 25 |
| S19               | HWAC RTU                      | 330   | 23  | 289   | 25  | 278   | 25  | 342   | 10  | 342   | 7   | 282 | 25 | 343 | 8  | 319 | 25 | 295 | 24 | 335 | 16 |
| S21               | HWAC RTU                      | 330   | 19  | 289   | 25  | 274   | 26  | 338   | 8   | 343   | 5   | 278 | 25 | 338 | 9  | 318 | 16 | 295 | 25 | 335 | 16 |
| S20               | HWAC RTU                      | 331   | 23  | 290   | 25  | 277   | 25  | 341   | 9   | 343   | 7   | 282 | 25 | 342 | 8  | 319 | 25 | 296 | 24 | 336 | 16 |
| S05               | HWAC RTU                      | 334   | 8   | 304   | 25  | 269   | 26  | 301   | 6   | 338   | 8   | 306 | 26 | 315 | 15 | 309 | 8  | 314 | 13 | 351 | 24 |
| S06               | HWAC RTU                      | 335   | 5   | 306   | 25  | 271   | 25  | 303   | 6   | 339   | 8   | 268 | 25 | 293 | 15 | 311 | 8  | 316 | 13 | 335 | 24 |
| S33               | HWAC RTU                      | 317   | 5   | 288   | 24  | 252   | 25  | 283   | 5   | 321   | 8   | 260 | 25 | 274 | 14 | 292 | 7  | 298 | 12 | 316 | 23 |
| S07               | HWAC RTU                      | 345   | 5   | 315   | 24  | 279   | 25  | 314   | 6   | 350   | 8   | 277 | 25 | 305 | 14 | 321 | 8  | 324 | 13 | 345 | 23 |
| S28               | HWAC RTU                      | 348   | 21  | 304   | 23  | 281   | 24  | 344   | 26  | 345   | 21  | 304 | 23 | 346 | 26 | 348 | 21 | 348 | 21 | 348 | 21 |
| S24               | HWAC RTU                      | 331   | 9   | 289   | 22  | 271   | 23  | 334   | 3   | 342   | 2   | 274 | 23 | 333 | 4  | 316 | 14 | 296 | 22 | 335 | 13 |
| S32               | HWAC RTU                      | 410   | 22  | 428   | 12  | 464   | 20  | 458   | 21  | 412   | 22  | 467 | 4  | 470 | 13 | 434 | 4  | 419 | 21 | 414 | 22 |
| S31               | HWAC RTU                      | 411   | 22  | 429   | 12  | 464   | 20  | 459   | 21  | 413   | 22  | 468 | 4  | 471 | 13 | 435 | 4  | 420 | 21 | 415 | 22 |
| S13               | HWAC RTU                      | 248   | 12  | 204   | 27  | 188   | 29  | 252   | 11  | 257   | 7   | 190 | 24 | 258 | 11 | 231 | 18 | 211 | 27 | 258 | 16 |
| S01               | HWAC RTU                      | 250   | 3   | 232   | 15  | 197   | 15  | 206   | 4   | 250   | 7   | 193 | 21 | 195 | 15 | 225 | 4  | 241 | 6  | 247 | 19 |
| S12               | HWAC RTU                      | 264   | 6   | 224   | 23  | 198   | 24  | 255   | 3   | 274   | 5   | 199 | 24 | 251 | 8  | 245 | 5  | 233 | 23 | 267 | 21 |
| S02               | HWAC RTU                      | 272   | 2   | 256   | 14  | 221   | 14  | 228   | 4   | 272   | 6   | 216 | 20 | 216 | 15 | 248 | 4  | 264 | 6  | 269 | 19 |
| S09               | HWAC RTU                      | 268   | 4   | 264   | 22  | 222   | 23  | 272   | 5   | 272   | 6   | 268 | 21 | 268 | 21 | 268 | 21 | 268 | 21 | 268 | 21 |
| S03               | HWAC RTU                      | 309   | 2   | 293   | 13  | 258   | 13  | 264   | 3   | 308   | 6   | 253 | 19 | 252 | 14 | 285 | 3  | 301 | 5  | 306 | 17 |
| S38               | HWAC RTU                      | 324   | 14  | 283   | 21  | 268   | 21  | 332   | 5   | 336   | 3   | 272 | 21 | 332 | 5  | 312 | 12 | 289 | 20 | 329 | 12 |
| S04               | HWAC RTU                      | 332   | 2   | 317   | 12  | 282   | 12  | 287   | 3   | 331   | 5   | 277 | 18 | 275 | 18 | 308 | 3  | 325 | 5  | 329 | 17 |
| S02               | HWAC RTU                      | 334   | 14  | 295   | 20  | 280   | 21  | 344   | 5   | 348   | 3   | 284 | 21 | 344 | 5  | 323 | 12 | 301 | 24 | 341 | 12 |
| S23               | HWAC RTU                      | 337   | 13  | 295   | 20  | 279   | 21  | 343   | 4   | 349   | 3   | 283 | 21 | 342 | 5  | 323 | 12 | 302 | 20 | 341 | 12 |
| S29               | HWAC RTU                      | 345   | 18  | 383   | 4   | 414   | 2   | 372   | 17  | 359   | 18  | 414 | 1  | 382 | 17 | 368 | 6  | 374 | 17 | 345 | 18 |
| S30               | HWAC RTU                      | 365   | 18  | 401   | 4   | 433   | 2   | 394   | 17  | 359   | 18  | 433 | 1  | 404 | 17 | 388 | 3  | 391 | 17 | 364 | 18 |
| S37               | HWAC RTU                      | 268   | 2   | 237   | 17  | 202   | 18  | 239   | 2   | 273   | 3   | 200 | 18 | 230 | 7  | 244 | 3  | 247 | 7  | 268 | 16 |
| S42               | Large Aggregate Loading Cycle | 178   | 18  | 149   | 43  | 113   | 44  | 149   | 20  | 183   | 17  | 111 | 43 | 141 | 23 | 154 | 21 | 159 | 26 | 178 | 38 |
| Total Level (dBA) |                               | 34  | 48  | 50  | 50  | 50  | 50  | 50  | 32  | 32  | 32  | 50  | 50 | 33  | 34 | 34  | 34 | 39  | 34 | 38  | 45 |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name    | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|----------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L01       | 15-Ton Pass-by | 17652673.4 | 4786882.7 | 1.5 | 0     | 52 | 8.1  | 125  | 55.6 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652673.4 | 4786882.7 | 1.5 | 0     | 57 | 8.1  | 250  | 55.6 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652673.4 | 4786882.7 | 1.5 | 0     | 63 | 8.1  | 500  | 55.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652673.4 | 4786882.7 | 1.5 | 0     | 63 | 8.1  | 1000 | 55.6 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652673.4 | 4786882.7 | 1.5 | 0     | 61 | 8.1  | 2000 | 55.6 | 0.0 | -2.7 | 0.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652673.4 | 4786882.7 | 1.5 | 0     | 55 | 8.1  | 4000 | 55.6 | 0.0 | -2.7 | 0.0  | 5.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by | 17652657.4 | 4786882.7 | 1.5 | 0     | 41 | 14.1 | 63   | 54.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by | 17652657.4 | 4786882.7 | 1.5 | 0     | 52 | 14.1 | 125  | 54.9 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652657.4 | 4786882.7 | 1.5 | 0     | 57 | 14.1 | 250  | 54.9 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L01       | 15-Ton Pass-by | 17652657.4 | 4786882.7 | 1.5 | 0     | 63 | 14.1 | 500  | 54.9 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 24 |
| L01       | 15-Ton Pass-by | 17652657.4 | 4786882.7 | 1.5 | 0     | 63 | 14.1 | 1000 | 54.9 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 24 |
| L01       | 15-Ton Pass-by | 17652657.4 | 4786882.7 | 1.5 | 0     | 61 | 14.1 | 2000 | 54.9 | 0.0 | -2.7 | 0.0  | 1.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652657.4 | 4786882.7 | 1.5 | 0     | 55 | 14.1 | 4000 | 54.9 | 0.0 | -2.7 | 0.0  | 5.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 52 | 10.4 | 125  | 55.7 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 57 | 10.4 | 250  | 55.7 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 63 | 10.4 | 500  | 55.7 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 20 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 63 | 10.4 | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 61 | 10.4 | 2000 | 55.7 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 55 | 10.4 | 4000 | 55.7 | 0.0 | -2.7 | 0.0  | 5.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652680.7 | 4786874.3 | 1.5 | 0     | 52 | 3.9  | 125  | 55.7 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by | 17652680.7 | 4786874.3 | 1.5 | 0     | 57 | 3.9  | 250  | 55.7 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L01       | 15-Ton Pass-by | 17652680.7 | 4786874.3 | 1.5 | 0     | 63 | 3.9  | 500  | 55.7 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by | 17652680.7 | 4786874.3 | 1.5 | 0     | 63 | 3.9  | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by | 17652680.7 | 4786874.3 | 1.5 | 0     | 61 | 3.9  | 2000 | 55.7 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652680.7 | 4786874.3 | 1.5 | 0     | 55 | 3.9  | 4000 | 55.7 | 0.0 | -2.7 | 0.0  | 5.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 52 | 8.5  | 125  | 55.7 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 57 | 8.5  | 250  | 55.7 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 63 | 8.5  | 500  | 55.7 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 63 | 8.5  | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 61 | 8.5  | 2000 | 55.7 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 55 | 8.5  | 4000 | 55.7 | 0.0 | -2.7 | 0.0  | 5.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by | 17652676.8 | 4786882.2 | 1.5 | 0     | 57 | 0.2  | 250  | 55.7 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L01       | 15-Ton Pass-by | 17652676.8 | 4786882.2 | 1.5 | 0     | 63 | 0.2  | 500  | 55.7 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652676.8 | 4786882.2 | 1.5 | 0     | 63 | 0.2  | 1000 | 55.7 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L01       | 15-Ton Pass-by | 17652676.8 | 4786882.2 | 1.5 | 0     | 61 | 0.2  | 2000 | 55.7 | 0.0 | -2.8 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786867.0 | 1.5 | 0     | 52 | 3.7  | 125  | 55.7 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786867.0 | 1.5 | 0     | 57 | 3.7  | 250  | 55.7 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786867.0 | 1.5 | 0     | 63 | 3.7  | 500  | 55.7 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786867.0 | 1.5 | 0     | 63 | 3.7  | 1000 | 55.7 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786867.0 | 1.5 | 0     | 61 | 3.7  | 2000 | 55.7 | 0.0 | -2.8 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786867.0 | 1.5 | 0     | 55 | 3.7  | 4000 | 55.7 | 0.0 | -2.8 | 0.0  | 5.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L01       | 15-Ton Pass-by | 17652682.6 | 4786869.8 | 1.5 | 0     | 52 | 5.7  | 125  | 55.7 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by | 17652682.6 | 4786869.8 | 1.5 | 0     | 57 | 5.7  | 250  | 55.7 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L01       | 15-Ton Pass-by   | 17652682.6 | 4786869.8 | 1.5 | 0     | 63 | 5.7  | 500  | 55.7 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by   | 17652682.6 | 4786869.8 | 1.5 | 0     | 63 | 5.7  | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by   | 17652682.6 | 4786869.8 | 1.5 | 0     | 61 | 5.7  | 2000 | 55.7 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by   | 17652682.6 | 4786869.8 | 1.5 | 0     | 55 | 5.7  | 4000 | 55.7 | 0.0 | -2.7 | 0.0  | 5.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 52 | 2.5  | 125  | 55.7 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 57 | 2.5  | 250  | 55.7 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 63 | 2.5  | 500  | 55.7 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 63 | 2.5  | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 61 | 2.5  | 2000 | 55.7 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652660.2 | 4786967.8 | 1.5 | 0     | 52 | 11.9 | 125  | 57.8 | 0.0 | -2.9 | 7.7  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652660.2 | 4786967.8 | 1.5 | 0     | 57 | 11.9 | 250  | 57.8 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652660.2 | 4786967.8 | 1.5 | 0     | 63 | 11.9 | 500  | 57.8 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652660.2 | 4786967.8 | 1.5 | 0     | 63 | 11.9 | 1000 | 57.8 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652660.2 | 4786967.8 | 1.5 | 0     | 61 | 11.9 | 2000 | 57.8 | 0.0 | -2.9 | 7.7  | 2.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652646.2 | 4786967.1 | 1.5 | 0     | 52 | 11.1 | 125  | 57.4 | 0.0 | -2.9 | 7.7  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652646.2 | 4786967.1 | 1.5 | 0     | 57 | 11.1 | 250  | 57.4 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652646.2 | 4786967.1 | 1.5 | 0     | 63 | 11.1 | 500  | 57.4 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652646.2 | 4786967.1 | 1.5 | 0     | 63 | 11.1 | 1000 | 57.4 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652646.2 | 4786967.1 | 1.5 | 0     | 61 | 11.1 | 2000 | 57.4 | 0.0 | -2.9 | 7.7  | 2.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652639.3 | 4786966.8 | 1.5 | 0     | 63 | 0.1  | 500  | 57.2 | 0.0 | -3.0 | 3.1  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652639.3 | 4786966.8 | 1.5 | 0     | 63 | 0.1  | 1000 | 57.2 | 0.0 | -3.0 | 3.2  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652639.3 | 4786966.8 | 1.5 | 0     | 61 | 0.1  | 2000 | 57.2 | 0.0 | -3.0 | 3.4  | 2.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 52 | 11.1 | 125  | 57.1 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 57 | 11.1 | 250  | 57.1 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 63 | 11.1 | 500  | 57.1 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 63 | 11.1 | 1000 | 57.1 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 61 | 11.1 | 2000 | 57.1 | 0.0 | -3.0 | 0.0  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 55 | 11.1 | 4000 | 57.1 | 0.0 | -3.0 | 0.0  | 6.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 52 | 17.0 | 125  | 56.4 | 0.0 | -3.0 | 7.8  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 57 | 17.0 | 250  | 56.4 | 0.0 | -3.0 | 7.8  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 63 | 17.0 | 500  | 56.4 | 0.0 | -3.0 | 7.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 63 | 17.0 | 1000 | 56.4 | 0.0 | -3.0 | 7.8  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 61 | 17.0 | 2000 | 56.4 | 0.0 | -3.0 | 7.8  | 1.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 55 | 17.0 | 4000 | 56.4 | 0.0 | -3.0 | 7.8  | 6.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 52 | 14.6 | 125  | 55.7 | 0.0 | -2.8 | 7.6  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 57 | 14.6 | 250  | 55.7 | 0.0 | -2.8 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 63 | 14.6 | 500  | 55.7 | 0.0 | -2.8 | 7.8  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 63 | 14.6 | 1000 | 55.7 | 0.0 | -2.8 | 8.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 61 | 14.6 | 2000 | 55.7 | 0.0 | -2.8 | 8.5  | 1.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 55 | 14.6 | 4000 | 55.7 | 0.0 | -2.8 | 9.2  | 5.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 52 | 12.2 | 125  | 55.5 | 0.0 | -2.6 | 6.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 57 | 12.2 | 250  | 55.5 | 0.0 | -2.6 | 6.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 63 | 12.2 | 500  | 55.5 | 0.0 | -2.6 | 7.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 63 | 12.2 | 1000 | 55.5 | 0.0 | -2.6 | 8.1  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 61 | 12.2 | 2000 | 55.5 | 0.0 | -2.6 | 9.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 52 | 8.7  | 125  | 55.5 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 57 | 8.7  | 250  | 55.5 | 0.0 | -2.4 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 63 | 8.7  | 500  | 55.5 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 63 | 8.7  | 1000 | 55.5 | 0.0 | -2.4 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 61 | 8.7  | 2000 | 55.5 | 0.0 | -2.4 | 0.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 55 | 8.7  | 4000 | 55.5 | 0.0 | -2.4 | 0.0  | 5.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 52 | 8.2  | 125  | 58.4 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 57 | 8.2  | 250  | 58.4 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 63 | 8.2  | 500  | 58.4 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 63 | 8.2  | 1000 | 58.4 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 61 | 8.2  | 2000 | 58.4 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 55 | 8.2  | 4000 | 58.4 | 0.0 | -2.9 | 0.0  | 7.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 52 | 14.1 | 125  | 58.6 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 57 | 14.1 | 250  | 58.6 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 63 | 14.1 | 500  | 58.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| L02       | 15-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 63 | 14.1 | 1000 | 58.6 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 20 |
| L02       | 15-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 61 | 14.1 | 2000 | 58.6 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 55 | 14.1 | 4000 | 58.6 | 0.0 | -2.9 | 0.0  | 7.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652645.9 | 4787022.0 | 1.5 | 0     | 52 | 17.6 | 125  | 59.2 | 0.0 | -3.0 | 8.1  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652645.9 | 4787022.0 | 1.5 | 0     | 57 | 17.6 | 250  | 59.2 | 0.0 | -3.0 | 8.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652645.9 | 4787022.0 | 1.5 | 0     | 63 | 17.6 | 500  | 59.2 | 0.0 | -3.0 | 8.9  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652645.9 | 4787022.0 | 1.5 | 0     | 63 | 17.6 | 1000 | 59.2 | 0.0 | -3.0 | 9.8  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652645.9 | 4787022.0 | 1.5 | 0     | 61 | 17.6 | 2000 | 59.2 | 0.0 | -3.0 | 11.2 | 2.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652681.8 | 4787023.3 | 1.5 | 0     | 57 | 11.7 | 250  | 59.8 | 0.0 | -3.0 | 8.3  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652681.8 | 4787023.3 | 1.5 | 0     | 63 | 11.7 | 500  | 59.8 | 0.0 | -3.0 | 8.8  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652681.8 | 4787023.3 | 1.5 | 0     | 63 | 11.7 | 1000 | 59.8 | 0.0 | -3.0 | 9.7  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652681.8 | 4787023.3 | 1.5 | 0     | 61 | 11.7 | 2000 | 59.8 | 0.0 | -3.0 | 11.0 | 2.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652692.2 | 4787002.5 | 1.5 | 0     | 52 | 14.0 | 125  | 59.5 | 0.0 | -2.9 | 5.9  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652692.2 | 4787002.5 | 1.5 | 0     | 57 | 14.0 | 250  | 59.5 | 0.0 | -2.9 | 6.8  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652692.2 | 4787002.5 | 1.5 | 0     | 63 | 14.0 | 500  | 59.5 | 0.0 | -2.9 | 7.8  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652692.2 | 4787002.5 | 1.5 | 0     | 63 | 14.0 | 1000 | 59.5 | 0.0 | -2.9 | 9.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652692.2 | 4787002.5 | 1.5 | 0     | 61 | 14.0 | 2000 | 59.5 | 0.0 | -2.9 | 10.5 | 2.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 52 | 11.3 | 125  | 58.9 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 57 | 11.3 | 250  | 58.9 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 63 | 11.3 | 500  | 58.9 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 63 | 11.3 | 1000 | 58.9 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 61 | 11.3 | 2000 | 58.9 | 0.0 | -2.9 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 55 | 11.3 | 4000 | 58.9 | 0.0 | -2.9 | 0.0  | 8.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652570.1 | 4787042.8 | 1.5 | 0     | 57 | 9.1  | 250  | 59.0 | 0.0 | -2.8 | 7.6  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652570.1 | 4787042.8 | 1.5 | 0     | 63 | 9.1  | 500  | 59.0 | 0.0 | -2.8 | 7.6  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652570.1 | 4787042.8 | 1.5 | 0     | 63 | 9.1  | 1000 | 59.0 | 0.0 | -2.8 | 7.6  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2              | 17652570.1 | 4787042.8 | 1.5 | 0     | 61 | 9.1  | 2000 | 59.0 | 0.0 | -2.8 | 7.6  | 2.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652573.6 | 4787037.5 | 1.5 | 0     | 57 | 6.5  | 250  | 58.9 | 0.0 | -2.8 | 3.2  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652573.6 | 4787037.5 | 1.5 | 0     | 63 | 6.5  | 500  | 58.9 | 0.0 | -2.8 | 3.4  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2              | 17652573.6 | 4787037.5 | 1.5 | 0     | 63 | 6.5  | 1000 | 58.9 | 0.0 | -2.8 | 3.8  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652573.6 | 4787037.5 | 1.5 | 0     | 61 | 6.5  | 2000 | 58.9 | 0.0 | -2.8 | 4.4  | 2.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652579.9 | 4787027.7 | 1.5 | 0     | 52 | 12.8 | 125  | 58.6 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2              | 17652579.9 | 4787027.7 | 1.5 | 0     | 57 | 12.8 | 250  | 58.6 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2              | 17652579.9 | 4787027.7 | 1.5 | 0     | 63 | 12.8 | 500  | 58.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2              | 17652579.9 | 4787027.7 | 1.5 | 0     | 63 | 12.8 | 1000 | 58.6 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2              | 17652579.9 | 4787027.7 | 1.5 | 0     | 61 | 12.8 | 2000 | 58.6 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2              | 17652579.9 | 4787027.7 | 1.5 | 0     | 55 | 12.8 | 4000 | 58.6 | 0.0 | -2.9 | 0.0  | 7.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652688.4 | 4786975.7 | 1.5 | 0     | 52 | 6.7  | 125  | 58.7 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652688.4 | 4786975.7 | 1.5 | 0     | 57 | 6.7  | 250  | 58.7 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652688.4 | 4786975.7 | 1.5 | 0     | 63 | 6.7  | 500  | 58.7 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2              | 17652688.4 | 4786975.7 | 1.5 | 0     | 63 | 6.7  | 1000 | 58.7 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2              | 17652688.4 | 4786975.7 | 1.5 | 0     | 61 | 6.7  | 2000 | 58.7 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 52 | 12.9 | 125  | 58.3 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 57 | 12.9 | 250  | 58.3 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 63 | 12.9 | 500  | 58.3 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 20 |
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 63 | 12.9 | 1000 | 58.3 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 61 | 12.9 | 2000 | 58.3 | 0.0 | -2.9 | 0.0  | 2.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 55 | 12.9 | 4000 | 58.3 | 0.0 | -2.9 | 0.0  | 7.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652689.9 | 4787022.0 | 1.5 | 0     | 63 | 5.2  | 500  | 59.9 | 0.0 | -2.9 | 8.9  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652691.8 | 4787017.7 | 1.5 | 0     | 63 | 7.8  | 500  | 59.8 | 0.0 | -2.9 | 8.5  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652691.8 | 4787017.7 | 1.5 | 0     | 63 | 7.8  | 1000 | 59.8 | 0.0 | -2.9 | 9.2  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 71 | 0.0  | 63   | 54.4 | 0.0 | -3.0 | 3.3  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 54.4 | 0.0 | -2.7 | 3.4  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 23 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 54.4 | 0.0 | -2.7 | 3.8  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 29 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 54.4 | 0.0 | -2.7 | 4.5  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 33 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 54.4 | 0.0 | -2.7 | 5.5  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 34 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 54.4 | 0.0 | -2.7 | 6.8  | 1.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 30 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 89 | 0.0  | 4000 | 54.4 | 0.0 | -2.7 | 8.4  | 4.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L03       | 5-Ton Pass-by                 | 17652673.4 | 4786882.7 | 1.5 | 0     | 47 | 8.1  | 500  | 55.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652673.4 | 4786882.7 | 1.5 | 0     | 50 | 8.1  | 1000 | 55.6 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652673.4 | 4786882.7 | 1.5 | 0     | 47 | 8.1  | 2000 | 55.6 | 0.0 | -2.7 | 0.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by                 | 17652657.4 | 4786882.7 | 1.5 | 0     | 41 | 14.1 | 250  | 54.9 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652657.4 | 4786882.7 | 1.5 | 0     | 47 | 14.1 | 500  | 54.9 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L03       | 5-Ton Pass-by                 | 17652657.4 | 4786882.7 | 1.5 | 0     | 50 | 14.1 | 1000 | 54.9 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L03       | 5-Ton Pass-by                 | 17652657.4 | 4786882.7 | 1.5 | 0     | 47 | 14.1 | 2000 | 54.9 | 0.0 | -2.7 | 0.0  | 1.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L03       | 5-Ton Pass-by                 | 17652657.4 | 4786882.7 | 1.5 | 0     | 44 | 14.1 | 4000 | 54.9 | 0.0 | -2.7 | 0.0  | 5.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 47 | 10.4 | 500  | 55.7 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 50 | 10.4 | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 47 | 10.4 | 2000 | 55.7 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name     | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|-----------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L03       | 5-Ton Pass-by   | 17652680.7 | 4786874.3 | 1.5 | 0     | 50 | 3.9  | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by   | 17652678.6 | 4786878.6 | 1.5 | 0     | 47 | 8.5  | 500  | 55.7 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by   | 17652678.6 | 4786878.6 | 1.5 | 0     | 50 | 8.5  | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by   | 17652678.6 | 4786878.6 | 1.5 | 0     | 47 | 8.5  | 2000 | 55.7 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by   | 17652683.7 | 4786867.0 | 1.5 | 0     | 50 | 3.7  | 1000 | 55.7 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by   | 17652682.6 | 4786869.8 | 1.5 | 0     | 50 | 5.7  | 1000 | 55.7 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2 | 17652660.2 | 4786967.8 | 1.5 | 0     | 52 | 11.9 | 500  | 57.8 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2 | 17652660.2 | 4786967.8 | 1.5 | 0     | 55 | 11.9 | 1000 | 57.8 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2 | 17652646.2 | 4786967.1 | 1.5 | 0     | 55 | 11.1 | 1000 | 57.4 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 45 | 11.1 | 250  | 57.1 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 52 | 11.1 | 500  | 57.1 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 55 | 11.1 | 1000 | 57.1 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L04       | 5-Ton Pass-by 2 | 17652632.2 | 4786966.5 | 1.5 | 0     | 52 | 11.1 | 2000 | 57.1 | 0.0 | -3.0 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 45 | 17.0 | 250  | 56.4 | 0.0 | -3.0 | 7.8  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 52 | 17.0 | 500  | 56.4 | 0.0 | -3.0 | 7.8  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 55 | 17.0 | 1000 | 56.4 | 0.0 | -3.0 | 7.8  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2 | 17652600.8 | 4786965.0 | 1.5 | 0     | 52 | 17.0 | 2000 | 56.4 | 0.0 | -3.0 | 7.8  | 1.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 52 | 14.6 | 500  | 55.7 | 0.0 | -2.8 | 7.8  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 55 | 14.6 | 1000 | 55.7 | 0.0 | -2.8 | 8.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2 | 17652561.4 | 4786963.1 | 1.5 | 0     | 52 | 14.6 | 2000 | 55.7 | 0.0 | -2.8 | 8.5  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 52 | 12.2 | 500  | 55.5 | 0.0 | -2.6 | 7.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 55 | 12.2 | 1000 | 55.5 | 0.0 | -2.6 | 8.1  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2 | 17652538.6 | 4786962.1 | 1.5 | 0     | 52 | 12.2 | 2000 | 55.5 | 0.0 | -2.6 | 9.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 45 | 8.7  | 250  | 55.5 | 0.0 | -2.4 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 52 | 8.7  | 500  | 55.5 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 55 | 8.7  | 1000 | 55.5 | 0.0 | -2.4 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2 | 17652526.6 | 4786961.5 | 1.5 | 0     | 52 | 8.7  | 2000 | 55.5 | 0.0 | -2.4 | 0.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 52 | 8.2  | 500  | 58.4 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 55 | 8.2  | 1000 | 58.4 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2 | 17652588.3 | 4787019.9 | 1.5 | 0     | 52 | 8.2  | 2000 | 58.4 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 45 | 14.1 | 250  | 58.6 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 52 | 14.1 | 500  | 58.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 55 | 14.1 | 1000 | 58.6 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L04       | 5-Ton Pass-by 2 | 17652604.4 | 4787020.5 | 1.5 | 0     | 52 | 14.1 | 2000 | 58.6 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2 | 17652645.9 | 4787022.0 | 1.5 | 0     | 52 | 17.6 | 500  | 59.2 | 0.0 | -3.0 | 8.9  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2 | 17652645.9 | 4787022.0 | 1.5 | 0     | 55 | 17.6 | 1000 | 59.2 | 0.0 | -3.0 | 9.8  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2 | 17652692.2 | 4787002.5 | 1.5 | 0     | 52 | 14.0 | 500  | 59.5 | 0.0 | -2.9 | 7.8  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2 | 17652692.2 | 4787002.5 | 1.5 | 0     | 55 | 14.0 | 1000 | 59.5 | 0.0 | -2.9 | 9.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 45 | 11.3 | 250  | 58.9 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 52 | 11.3 | 500  | 58.9 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 55 | 11.3 | 1000 | 58.9 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2 | 17652691.1 | 4786983.3 | 1.5 | 0     | 52 | 11.3 | 2000 | 58.9 | 0.0 | -2.9 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2 | 17652573.6 | 4787037.5 | 1.5 | 0     | 55 | 6.5  | 1000 | 58.9 | 0.0 | -2.8 | 3.8  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name          | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|----------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| L04       | 5-Ton Pass-by 2      | 17652579.9 | 4787027.7 | 1.5 | 0     | 45 | 12.8 | 250  | 58.6 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652579.9 | 4787027.7 | 1.5 | 0     | 52 | 12.8 | 500  | 58.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2      | 17652579.9 | 4787027.7 | 1.5 | 0     | 55 | 12.8 | 1000 | 58.6 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| L04       | 5-Ton Pass-by 2      | 17652579.9 | 4787027.7 | 1.5 | 0     | 52 | 12.8 | 2000 | 58.6 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652688.4 | 4786975.7 | 1.5 | 0     | 52 | 6.7  | 500  | 58.7 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652688.4 | 4786975.7 | 1.5 | 0     | 55 | 6.7  | 1000 | 58.7 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2      | 17652688.4 | 4786975.7 | 1.5 | 0     | 52 | 6.7  | 2000 | 58.7 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652677.0 | 4786971.5 | 1.5 | 0     | 45 | 12.9 | 250  | 58.3 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2      | 17652677.0 | 4786971.5 | 1.5 | 0     | 52 | 12.9 | 500  | 58.3 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| L04       | 5-Ton Pass-by 2      | 17652677.0 | 4786971.5 | 1.5 | 0     | 55 | 12.9 | 1000 | 58.3 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 12 |
| L04       | 5-Ton Pass-by 2      | 17652677.0 | 4786971.5 | 1.5 | 0     | 52 | 12.9 | 2000 | 58.3 | 0.0 | -2.9 | 0.0  | 2.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 59 | 0.0  | 32   | 55.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 67 | 0.0  | 63   | 55.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 55.3 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 21 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 55.3 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 26 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 55.3 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 32 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 55.3 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 33 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 55.3 | 0.0 | -2.8 | 0.0  | 1.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 29 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 4000 | 55.3 | 0.0 | -2.8 | 0.0  | 5.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 21 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 81 | 0.0  | 8000 | 55.3 | 0.0 | -2.8 | 0.0  | 19.2 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 68 | 0.0  | 63   | 54.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 54.0 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 24 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0  | 250  | 54.0 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 32 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 500  | 54.0 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 39 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 1000 | 54.0 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 39 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 54.0 | 0.0 | -2.8 | 0.0  | 1.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 37 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0  | 4000 | 54.0 | 0.0 | -2.8 | 0.0  | 4.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 30 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 85 | 0.0  | 8000 | 54.0 | 0.0 | -2.8 | 0.0  | 16.5 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0  | 125  | 52.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -4.5  | 0.0 | 22 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0  | 250  | 52.2 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -8.5  | 0.0 | 21 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0  | 500  | 52.2 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 25 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 83 | 0.0  | 1000 | 52.2 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 23 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0  | 2000 | 52.2 | 0.0 | -3.0 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 17 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 73 | 0.0  | 4000 | 52.2 | 0.0 | -3.0 | 0.0  | 3.7  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 7  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0  | 63   | 57.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 12 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0  | 125  | 57.2 | 0.0 | -1.2 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 19 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0  | 250  | 57.2 | 0.0 | -2.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 20 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0  | 500  | 57.2 | 0.0 | -2.1 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 21 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0  | 1000 | 57.2 | 0.0 | -2.1 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 22 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 85 | 0.0  | 2000 | 57.2 | 0.0 | -2.1 | 0.0  | 2.0  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 16 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 78 | 0.0  | 4000 | 57.2 | 0.0 | -2.1 | 0.0  | 6.7  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 3  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0  | 125  | 52.5 | 0.0 | -2.9 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -4.5  | 0.0 | 22 |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0  | 250  | 52.5 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -8.5  | 0.0 | 21 |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0 | 500  | 52.5 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 24 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 52.5 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 22 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 52.5 | 0.0 | -2.9 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 16 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 73 | 0.0 | 4000 | 52.5 | 0.0 | -2.9 | 0.0  | 3.9  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 7  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 61 | 0.0 | 125  | 57.3 | 0.0 | -1.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 0  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 72 | 0.0 | 250  | 57.3 | 0.0 | -2.2 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 8  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 84 | 0.0 | 500  | 57.3 | 0.0 | -2.3 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.3 | 0.0 | -2.3 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 22 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 87 | 0.0 | 2000 | 57.3 | 0.0 | -2.3 | 0.0  | 2.0  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 18 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 81 | 0.0 | 4000 | 57.3 | 0.0 | -2.3 | 0.0  | 6.8  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 6  |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 67 | 0.0 | 63   | 58.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 10 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 58.6 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 19 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 58.6 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 20 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 87 | 0.0 | 500  | 58.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 21 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.6 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 22 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 58.6 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 15 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 58.6 | 0.0 | -2.9 | 0.0  | 7.8  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 2  |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 67 | 0.0 | 63   | 58.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 10 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 58.8 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 19 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 58.8 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 20 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 87 | 0.0 | 500  | 58.8 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 21 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.8 | 0.0 | -3.0 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 22 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 58.8 | 0.0 | -3.0 | 0.0  | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 15 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 58.8 | 0.0 | -3.0 | 0.0  | 8.1  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 1  |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 67 | 0.0 | 63   | 58.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 10 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 58.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 19 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 58.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 19 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 87 | 0.0 | 500  | 58.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 20 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.9 | 0.0 | -3.0 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 21 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 58.9 | 0.0 | -3.0 | 0.0  | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 15 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 78 | 0.0 | 4000 | 58.9 | 0.0 | -3.0 | 0.0  | 8.2  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 1  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 67 | 0.0 | 63   | 59.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 10 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 59.1 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 19 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 59.1 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 19 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 87 | 0.0 | 500  | 59.1 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 20 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.1 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 21 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.1 | 0.0 | -2.9 | 0.0  | 2.5  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 15 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 78 | 0.0 | 4000 | 59.1 | 0.0 | -2.9 | 0.0  | 8.3  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 1  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 67 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -1.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -2.2 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -2.2 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -2.2 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 19 |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -2.2 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 13 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 67 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -2.7 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 67 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -2.5 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -2.5 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -2.5 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 67 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -2.6 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -2.6 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -2.6 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 67 | 0.0 | 63   | 60.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 60.3 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 18 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 60.3 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 87 | 0.0 | 500  | 60.3 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.3 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.3 | 0.0 | -2.9 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 72 | 0.0 | 250  | 59.5 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 7  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 84 | 0.0 | 500  | 59.5 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 17 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.5 | 0.0 | -2.9 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 21 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 87 | 0.0 | 2000 | 59.5 | 0.0 | -2.9 | 0.0  | 2.6  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 16 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 81 | 0.0 | 4000 | 59.5 | 0.0 | -2.9 | 0.0  | 8.7  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 3  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 67 | 0.0 | 63   | 60.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.7 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.7 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 87 | 0.0 | 500  | 60.7 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.7 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.7 | 0.0 | -2.9 | 0.0  | 2.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 67 | 0.0 | 63   | 60.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 60.7 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 60.7 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 87 | 0.0 | 500  | 60.7 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 18 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.7 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.7 | 0.0 | -2.9 | 0.0  | 3.0  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 67 | 0.0 | 63   | 60.9 | 0.0 | -3.0 | 7.5  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 0  |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.9 | 0.0 | -2.7 | 9.6  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 7  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.9 | 0.0 | -2.7 | 12.2 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 5  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 60.9 | 0.0 | -2.7 | 15.0 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 3  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.9 | 0.0 | -2.7 | 17.9 | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 1  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 65 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 7  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 60.2 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 16 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 83 | 0.0 | 250  | 60.2 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 1000 | 60.2 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 18 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -2.9 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 13 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.2 | 0.0 | -2.9 | 0.0  | 9.4  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 1  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 67 | 0.0 | 63   | 61.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.0 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 61.0 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 87 | 0.0 | 500  | 61.0 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 18 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.0 | 0.0 | -2.9 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.0 | 0.0 | -2.9 | 0.0  | 3.0  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 12 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 72 | 0.0 | 250  | 60.2 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 6  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 84 | 0.0 | 500  | 60.2 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -2.8 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 87 | 0.0 | 2000 | 60.2 | 0.0 | -2.8 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 15 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.2 | 0.0 | -2.8 | 0.0  | 9.5  | 0.0  | 0.0  | 0.0  | -13.0 | 0.0 | 1  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 67 | 0.0 | 63   | 61.1 | 0.0 | -3.0 | 7.7  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 0  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 61.1 | 0.0 | -2.7 | 9.8  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 7  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 61.1 | 0.0 | -2.7 | 12.4 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 5  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 87 | 0.0 | 500  | 61.1 | 0.0 | -2.7 | 15.3 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 3  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.1 | 0.0 | -2.7 | 18.1 | 1.2  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 0  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 60.8 | 0.0 | -2.7 | 11.8 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 3  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.8 | 0.0 | -2.7 | 14.4 | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 4  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 62 | 0.0 | 63   | 57.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 7  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 57.2 | 0.0 | -1.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 15 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 57.2 | 0.0 | -2.3 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 17 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 83 | 0.0 | 500  | 57.2 | 0.0 | -2.4 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 18 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 82 | 0.0 | 1000 | 57.2 | 0.0 | -2.4 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 16 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 2000 | 57.2 | 0.0 | -2.4 | 0.0  | 2.0  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 12 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 77 | 0.0 | 4000 | 57.2 | 0.0 | -2.4 | 0.0  | 6.7  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 3  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 58.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 16 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 250  | 58.0 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 15 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 84 | 0.0 | 500  | 58.0 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 58.0 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 16 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 2000 | 58.0 | 0.0 | -3.0 | 0.0  | 2.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 10 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 61 | 0.0 | 63   | 58.3 | 0.0 | -3.0 | 4.2  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 0  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 74 | 0.0 | 125  | 58.3 | 0.0 | -0.2 | 4.1  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 7  |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 79 | 0.0 | 250  | 58.3 | 0.0 | -0.9 | 4.6  | 0.2  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 8  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 83 | 0.0 | 500  | 58.3 | 0.0 | -0.9 | 4.9  | 0.4  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 10 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 82 | 0.0 | 1000 | 58.3 | 0.0 | -0.9 | 5.3  | 0.8  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 7  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 81 | 0.0 | 2000 | 58.3 | 0.0 | -0.9 | 5.9  | 2.2  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 4  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 63.6 | 0.0 | -2.1 | 6.6  | 0.2  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 7  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 63.6 | 0.0 | -2.4 | 8.3  | 0.4  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 6  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 63.6 | 0.0 | -2.4 | 10.5 | 0.8  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 4  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.6 | 0.0 | -2.4 | 12.9 | 1.6  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 2  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 63.6 | 0.0 | -1.8 | 6.5  | 0.2  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 7  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 63.6 | 0.0 | -2.2 | 8.2  | 0.4  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 6  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 63.6 | 0.0 | -2.3 | 10.4 | 0.8  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 4  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.6 | 0.0 | -2.3 | 12.8 | 1.6  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 2  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 59.1 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 15 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 250  | 59.1 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 14 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 84 | 0.0 | 500  | 59.1 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 17 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 59.1 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 15 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 59.1 | 0.0 | -2.9 | 0.0  | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 9  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 74 | 0.0 | 125  | 59.2 | 0.0 | -0.3 | 4.2  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 6  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 79 | 0.0 | 250  | 59.2 | 0.0 | -1.0 | 4.7  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 8  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 83 | 0.0 | 500  | 59.2 | 0.0 | -1.0 | 5.1  | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 9  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 82 | 0.0 | 1000 | 59.2 | 0.0 | -1.0 | 5.6  | 0.9  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 6  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 81 | 0.0 | 2000 | 59.2 | 0.0 | -1.0 | 6.4  | 2.5  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 2  |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 76 | 0.0 | 125  | 60.0 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 14 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 79 | 0.0 | 250  | 60.0 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 13 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 84 | 0.0 | 500  | 60.0 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 16 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 83 | 0.0 | 1000 | 60.0 | 0.0 | -2.7 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 14 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 79 | 0.0 | 2000 | 60.0 | 0.0 | -2.7 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 7  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 74 | 0.0 | 125  | 60.3 | 0.0 | -0.2 | 4.1  | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 5  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 79 | 0.0 | 250  | 60.3 | 0.0 | -1.0 | 4.6  | 0.3  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 6  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 83 | 0.0 | 500  | 60.3 | 0.0 | -1.0 | 5.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 8  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 82 | 0.0 | 1000 | 60.3 | 0.0 | -1.0 | 5.5  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 5  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 81 | 0.0 | 2000 | 60.3 | 0.0 | -1.0 | 6.2  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 1  |
| S22       | HVAC RTU    | 17652529.8 | 4787088.9 | 5.5 | 0     | 76 | 0.0 | 125  | 60.4 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 13 |
| S22       | HVAC RTU    | 17652529.8 | 4787088.9 | 5.5 | 0     | 79 | 0.0 | 250  | 60.4 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 12 |
| S22       | HVAC RTU    | 17652529.8 | 4787088.9 | 5.5 | 0     | 84 | 0.0 | 500  | 60.4 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S22       | HVAC RTU    | 17652529.8 | 4787088.9 | 5.5 | 0     | 83 | 0.0 | 1000 | 60.4 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 13 |
| S22       | HVAC RTU    | 17652529.8 | 4787088.9 | 5.5 | 0     | 79 | 0.0 | 2000 | 60.4 | 0.0 | -2.7 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 7  |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 76 | 0.0 | 125  | 60.4 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 13 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 79 | 0.0 | 250  | 60.4 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 12 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 84 | 0.0 | 500  | 60.4 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 83 | 0.0 | 1000 | 60.4 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 13 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 79 | 0.0 | 2000 | 60.4 | 0.0 | -2.7 | 0.0  | 2.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 7  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 74 | 0.0 | 125  | 61.0 | 0.0 | -0.2 | 4.1  | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 4  |



Receiver: RP01

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 48          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP01          | RP01        | 17652528.55 m | 4786794.33 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 79  | 0.0 | 250  | 61.0 | 0.0 | -0.9 | 4.7  | 0.3  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 5  |
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 83  | 0.0 | 500  | 61.0 | 0.0 | -0.9 | 5.1  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 82  | 0.0 | 1000 | 61.0 | 0.0 | -0.9 | 5.7  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 4  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 62  | 0.0 | 63   | 58.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 6  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 70  | 0.0 | 125  | 58.5 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 9  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 72  | 0.0 | 250  | 58.5 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 7  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 79  | 0.0 | 500  | 58.5 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 13 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 76  | 0.0 | 1000 | 58.5 | 0.0 | -2.7 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 8  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 75  | 0.0 | 2000 | 58.5 | 0.0 | -2.7 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 5  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 61  | 0.0 | 32   | 54.5 | 0.0 | -3.0 | 3.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 72  | 0.0 | 63   | 54.5 | 0.0 | -3.0 | 3.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 12 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 54.5 | 0.0 | -2.7 | 2.9  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 26 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 54.5 | 0.0 | -2.7 | 3.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 30 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 54.5 | 0.0 | -2.7 | 3.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 37 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 54.5 | 0.0 | -2.7 | 3.1  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 39 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 54.5 | 0.0 | -2.7 | 3.3  | 1.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 36 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 54.5 | 0.0 | -2.7 | 3.7  | 4.9  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 28 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 85  | 0.0 | 8000 | 54.5 | 0.0 | -2.7 | 4.4  | 17.4 | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |



Receiver: RP02

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP02          | RP02        | 17652523.94 m | 4786753.00 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| L02       | 15-Ton Pass-by 2              | 17652527.7 | 4786961.5 | 1.5 | 0     | 52 | 7.8  | 125  | 57.4 | 0.0 | -2.5 | 4.6  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652527.7 | 4786961.5 | 1.5 | 0     | 57 | 7.8  | 250  | 57.4 | 0.0 | -2.5 | 4.8  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652527.7 | 4786961.5 | 1.5 | 0     | 63 | 7.8  | 500  | 57.4 | 0.0 | -2.5 | 4.9  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2              | 17652527.7 | 4786961.5 | 1.5 | 0     | 63 | 7.8  | 1000 | 57.4 | 0.0 | -2.5 | 5.2  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2              | 17652527.7 | 4786961.5 | 1.5 | 0     | 61 | 7.8  | 2000 | 57.4 | 0.0 | -2.5 | 5.6  | 2.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2              | 17652523.8 | 4786961.4 | 1.5 | 0     | 57 | 2.4  | 250  | 57.4 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652523.8 | 4786961.4 | 1.5 | 0     | 63 | 2.4  | 500  | 57.4 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2              | 17652523.8 | 4786961.4 | 1.5 | 0     | 63 | 2.4  | 1000 | 57.4 | 0.0 | -2.5 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2              | 17652523.8 | 4786961.4 | 1.5 | 0     | 61 | 2.4  | 2000 | 57.4 | 0.0 | -2.5 | 0.0  | 2.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2              | 17652600.8 | 4787020.4 | 1.5 | 0     | 57 | 15.0 | 250  | 59.9 | 0.0 | -3.0 | 14.1 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652600.8 | 4787020.4 | 1.5 | 0     | 63 | 15.0 | 500  | 59.9 | 0.0 | -3.0 | 17.0 | 0.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652600.8 | 4787020.4 | 1.5 | 0     | 63 | 15.0 | 1000 | 59.9 | 0.0 | -3.0 | 19.7 | 1.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652579.6 | 4787028.1 | 1.5 | 0     | 57 | 13.0 | 250  | 60.0 | 0.0 | -2.9 | 11.8 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652579.6 | 4787028.1 | 1.5 | 0     | 63 | 13.0 | 500  | 60.0 | 0.0 | -2.9 | 14.5 | 0.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652579.6 | 4787028.1 | 1.5 | 0     | 63 | 13.0 | 1000 | 60.0 | 0.0 | -2.9 | 17.2 | 1.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 56.0 | 0.0 | -2.6 | 19.9 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 56.0 | 0.0 | -2.6 | 22.9 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 8  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 56.0 | 0.0 | -2.6 | 25.9 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 56.0 | 0.0 | -2.6 | 26.8 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 11 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 56.0 | 0.0 | -2.6 | 27.2 | 1.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2               | 17652527.7 | 4786961.5 | 1.5 | 0     | 55 | 7.8  | 1000 | 57.4 | 0.0 | -2.5 | 5.2  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652523.8 | 4786961.4 | 1.5 | 0     | 55 | 2.4  | 1000 | 57.4 | 0.0 | -2.5 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 62 | 0.0  | 63   | 60.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 3  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 70 | 0.0  | 125  | 60.9 | 0.0 | -2.1 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 7  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 72 | 0.0  | 250  | 60.9 | 0.0 | -2.5 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 4  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 79 | 0.0  | 500  | 60.9 | 0.0 | -2.6 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 10 |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 76 | 0.0  | 1000 | 60.9 | 0.0 | -2.6 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 5  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 75 | 0.0  | 2000 | 60.9 | 0.0 | -2.6 | 0.0  | 3.0  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 1  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 56.8 | 0.0 | -2.7 | 16.5 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 3  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 56.8 | 0.0 | -2.7 | 20.1 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 4  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 56.8 | 0.0 | -2.7 | 23.4 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 56.8 | 0.0 | -2.7 | 25.3 | 0.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 6  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 56.8 | 0.0 | -2.7 | 26.3 | 1.9  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 55.8 | 0.0 | -2.8 | 16.4 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 6  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0  | 250  | 55.8 | 0.0 | -2.8 | 19.9 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 500  | 55.8 | 0.0 | -2.8 | 23.1 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 14 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 1000 | 55.8 | 0.0 | -2.8 | 25.1 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 12 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 55.8 | 0.0 | -2.8 | 26.2 | 1.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 9  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0  | 4000 | 55.8 | 0.0 | -2.8 | 26.9 | 5.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0  | 63   | 58.8 | 0.0 | -3.0 | 4.8  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 5  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0  | 125  | 58.8 | 0.0 | -1.2 | 5.3  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 12 |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0  | 250  | 58.8 | 0.0 | -2.0 | 6.1  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 13 |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0  | 500  | 58.8 | 0.0 | -2.2 | 7.2  | 0.5  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 13 |



Receiver: RP02

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP02          | RP02        | 17652523.94 m | 4786753.00 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.8 | 0.0 | -2.2 | 8.8  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 12 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 58.8 | 0.0 | -2.2 | 10.9 | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 3  |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0 | 125  | 54.7 | 0.0 | -2.8 | 13.9 | 0.1  | 0.0  | 0.0  | 0.0  | -4.6  | 0.0 | 6  |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0 | 250  | 54.7 | 0.0 | -2.9 | 16.9 | 0.2  | 0.0  | 0.0  | 0.0  | -8.6  | 0.0 | 2  |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0 | 500  | 54.7 | 0.0 | -2.9 | 19.9 | 0.3  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 2  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 84 | 0.0 | 500  | 58.9 | 0.0 | -2.4 | 8.9  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 8  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.9 | 0.0 | -2.4 | 10.9 | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 10 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 87 | 0.0 | 2000 | 58.9 | 0.0 | -2.4 | 13.3 | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 3  |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.8 | 0.0 | -2.8 | 14.8 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 3  |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.8 | 0.0 | -2.9 | 18.2 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 0  |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 55.0 | 0.0 | -2.6 | 14.1 | 0.1  | 0.0  | 0.0  | 0.0  | -4.6  | 0.0 | 5  |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 250  | 55.0 | 0.0 | -2.8 | 17.3 | 0.2  | 0.0  | 0.0  | 0.0  | -8.6  | 0.0 | 1  |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0 | 500  | 55.0 | 0.0 | -2.8 | 20.3 | 0.3  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 1  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 67 | 0.0 | 63   | 60.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 18 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 14 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.1 | 0.0 | -2.9 | 14.3 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 4  |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.1 | 0.0 | -2.9 | 17.7 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 1  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 60.1 | 0.0 | -2.3 | 15.4 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 2  |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -2.9 | 14.5 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 3  |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -2.9 | 17.9 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 0  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 67 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -3.0 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -3.0 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 72 | 0.0 | 250  | 60.2 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 6  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 60.2 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -2.8 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 87 | 0.0 | 2000 | 60.2 | 0.0 | -2.8 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 15 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.2 | 0.0 | -2.8 | 0.0  | 9.5  | 0.0  | 0.0  | 0.0  | -13.0 | 0.0 | 1  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.1 | 0.0 | -2.8 | 15.6 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 1  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 67 | 0.0 | 63   | 61.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.3 | 0.0 | -1.5 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 15 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.3 | 0.0 | -2.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 16 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 61.3 | 0.0 | -2.1 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 17 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.3 | 0.0 | -2.1 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.3 | 0.0 | -2.1 | 0.0  | 3.2  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 11 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 67 | 0.0 | 63   | 61.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 7  |



Receiver: RP02

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP02          | RP02        | 17652523.94 m | 4786753.00 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.4 | 0.0 | -1.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 15 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.4 | 0.0 | -2.2 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 16 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 61.4 | 0.0 | -2.3 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 17 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.3 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 18 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.4 | 0.0 | -2.3 | 0.0  | 3.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 11 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 67 | 0.0 | 63   | 61.4 | 0.0 | -3.0 | 4.1  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 3  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.4 | 0.0 | -2.7 | 4.5  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 12 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.4 | 0.0 | -2.7 | 4.7  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 12 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 87 | 0.0 | 500  | 61.4 | 0.0 | -2.7 | 4.9  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.7 | 5.1  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 13 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.4 | 0.0 | -2.7 | 5.4  | 3.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 6  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 67 | 0.0 | 63   | 61.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 7  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 61.4 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 16 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 61.4 | 0.0 | -2.5 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 16 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 61.4 | 0.0 | -2.5 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 17 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.5 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.4 | 0.0 | -2.5 | 0.0  | 3.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 11 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 61.5 | 0.0 | -2.8 | 15.5 | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 1  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.5 | 0.0 | -2.8 | 15.5 | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 1  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.8 | 0.0 | -2.8 | 15.6 | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 0  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 72 | 0.0 | 250  | 61.4 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 5  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 84 | 0.0 | 500  | 61.4 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.8 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 18 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 87 | 0.0 | 500  | 61.4 | 0.0 | -2.8 | 0.0  | 3.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 84 | 0.0 | 500  | 61.4 | 0.0 | -2.8 | 10.3 | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 4  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.8 | 12.7 | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 6  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 67 | 0.0 | 63   | 63.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 6  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 63.3 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 14 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 63.3 | 0.0 | -2.8 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 63.3 | 0.0 | -2.8 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.3 | 0.0 | -2.8 | 0.0  | 1.5  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.3 | 0.0 | -2.8 | 0.0  | 4.0  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 9  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 67 | 0.0 | 63   | 63.3 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 6  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 63.3 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 14 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 63.3 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 63.3 | 0.0 | -2.8 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 16 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.3 | 0.0 | -2.8 | 0.0  | 1.5  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 16 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.3 | 0.0 | -2.8 | 0.0  | 4.0  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 9  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 58.8 | 0.0 | -1.8 | 6.8  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 6  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 58.8 | 0.0 | -2.3 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 6  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 83 | 0.0 | 500  | 58.8 | 0.0 | -2.4 | 10.6 | 0.5  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 5  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 82 | 0.0 | 1000 | 58.8 | 0.0 | -2.4 | 13.0 | 0.9  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 1  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 59.4 | 0.0 | -3.0 | 13.0 | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 2  |



Receiver: RP02

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP02          | RP02        | 17652523.94 m | 4786753.00 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 76  | 0.0 | 125  | 61.2 | 0.0 | -2.7 | 4.6  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 8  |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 79  | 0.0 | 250  | 61.2 | 0.0 | -2.7 | 4.8  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 7  |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 84  | 0.0 | 500  | 61.2 | 0.0 | -2.7 | 5.1  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 10 |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.2 | 0.0 | -2.7 | 5.5  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 7  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 76  | 0.0 | 125  | 61.5 | 0.0 | -2.7 | 4.5  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 8  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 250  | 61.5 | 0.0 | -2.7 | 4.7  | 0.4  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 6  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 84  | 0.0 | 500  | 61.5 | 0.0 | -2.7 | 4.9  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 10 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.5 | 0.0 | -2.7 | 5.1  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 7  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 76  | 0.0 | 125  | 61.5 | 0.0 | -2.7 | 5.1  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 7  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 79  | 0.0 | 250  | 61.5 | 0.0 | -2.7 | 5.6  | 0.4  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 5  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 84  | 0.0 | 500  | 61.5 | 0.0 | -2.7 | 6.5  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 8  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.5 | 0.0 | -2.7 | 7.8  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 4  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 76  | 0.0 | 125  | 61.8 | 0.0 | -1.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 250  | 61.8 | 0.0 | -2.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 84  | 0.0 | 500  | 61.8 | 0.0 | -2.2 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.8 | 0.0 | -2.2 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 2000 | 61.8 | 0.0 | -2.2 | 0.0  | 3.3  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 4  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 76  | 0.0 | 125  | 62.2 | 0.0 | -1.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 250  | 62.2 | 0.0 | -2.3 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 84  | 0.0 | 500  | 62.2 | 0.0 | -2.4 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.2 | 0.0 | -2.4 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.2 | 0.0 | -2.4 | 0.0  | 3.5  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 4  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 56.0 | 0.0 | -2.6 | 19.9 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 56.0 | 0.0 | -2.6 | 22.9 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 9  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 56.0 | 0.0 | -2.6 | 25.9 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 13 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 56.0 | 0.0 | -2.6 | 26.8 | 0.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 13 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 56.0 | 0.0 | -2.6 | 27.2 | 1.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 11 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 56.0 | 0.0 | -2.6 | 27.4 | 5.8  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |



Receiver: RP03

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 32          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP03          | RP03        | 17652529.24 m | 4786741.01 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0 | 125  | 56.2 | 0.0 | -2.6 | 21.3 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0 | 250  | 56.2 | 0.0 | -2.6 | 24.2 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0 | 500  | 56.2 | 0.0 | -2.6 | 27.2 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0 | 1000 | 56.2 | 0.0 | -2.6 | 27.6 | 0.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 10 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0 | 2000 | 56.2 | 0.0 | -2.6 | 27.6 | 1.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 62 | 0.0 | 63   | 60.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 3  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 70 | 0.0 | 125  | 60.8 | 0.0 | -2.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 7  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 72 | 0.0 | 250  | 60.8 | 0.0 | -2.5 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 4  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 79 | 0.0 | 500  | 60.8 | 0.0 | -2.6 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 11 |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 76 | 0.0 | 1000 | 60.8 | 0.0 | -2.6 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 6  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 75 | 0.0 | 2000 | 60.8 | 0.0 | -2.6 | 0.0  | 3.0  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 2  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0 | 125  | 57.1 | 0.0 | -2.7 | 16.6 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0 | 250  | 57.1 | 0.0 | -2.7 | 20.5 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0 | 500  | 57.1 | 0.0 | -2.7 | 24.6 | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 5  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0 | 1000 | 57.1 | 0.0 | -2.7 | 26.7 | 0.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0 | 2000 | 57.1 | 0.0 | -2.7 | 27.2 | 1.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0 | 125  | 56.1 | 0.0 | -2.7 | 17.1 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0 | 250  | 56.1 | 0.0 | -2.7 | 21.2 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0 | 500  | 56.1 | 0.0 | -2.7 | 25.3 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0 | 1000 | 56.1 | 0.0 | -2.7 | 27.1 | 0.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0 | 2000 | 56.1 | 0.0 | -2.7 | 27.4 | 1.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.2 | 0.0 | -1.4 | 15.2 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 2  |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 67 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 59.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 18 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 14 |
| S08       | HVAC RTU                      | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.0 | 0.0 | -2.7 | 12.8 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 5  |
| S08       | HVAC RTU                      | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.0 | 0.0 | -2.8 | 16.6 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 2  |
| S17       | HVAC RTU                      | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0 | 125  | 55.2 | 0.0 | -2.8 | 16.4 | 0.1  | 0.0  | 0.0  | 0.0  | -4.6  | 0.0 | 3  |
| S27       | HVAC RTU                      | 17652296.3 | 4786576.0 | 5.5 | 0     | 67 | 0.0 | 63   | 60.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S27       | HVAC RTU                      | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 60.1 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 18 |
| S27       | HVAC RTU                      | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 60.1 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S27       | HVAC RTU                      | 17652296.3 | 4786576.0 | 5.5 | 0     | 87 | 0.0 | 500  | 60.1 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S27       | HVAC RTU                      | 17652296.3 | 4786576.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.1 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |
| S27       | HVAC RTU                      | 17652296.3 | 4786576.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.1 | 0.0 | -3.0 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 13 |
| S35       | HVAC RTU                      | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 60.3 | 0.0 | -2.3 | 11.8 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 5  |
| S35       | HVAC RTU                      | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 60.3 | 0.0 | -2.5 | 15.5 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 2  |
| S16       | HVAC RTU                      | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 55.4 | 0.0 | -2.4 | 15.9 | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 2  |
| S11       | HVAC RTU                      | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.3 | 0.0 | -2.9 | 13.1 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 5  |
| S11       | HVAC RTU                      | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.3 | 0.0 | -2.9 | 16.9 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 1  |
| S10       | HVAC RTU                      | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.4 | 0.0 | -2.9 | 13.0 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 5  |



Receiver: RP03

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 32          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP03          | RP03        | 17652529.24 m | 4786741.01 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.4 | 0.0 | -2.9 | 16.8 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 1  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 72 | 0.0 | 250  | 60.3 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 6  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 60.3 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.3 | 0.0 | -3.0 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 87 | 0.0 | 2000 | 60.3 | 0.0 | -3.0 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 15 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.3 | 0.0 | -3.0 | 0.0  | 9.5  | 0.0  | 0.0  | 0.0  | -13.0 | 0.0 | 1  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.2 | 0.0 | -2.8 | 11.3 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 5  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 61.2 | 0.0 | -2.8 | 14.8 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 2  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 61.6 | 0.0 | -2.8 | 11.5 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 5  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 61.6 | 0.0 | -2.8 | 15.1 | 0.4  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 1  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.6 | 0.0 | -2.8 | 11.5 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 5  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.6 | 0.0 | -2.8 | 15.0 | 0.4  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 1  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.6 | 0.0 | -1.6 | 13.5 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 1  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -2.8 | 15.7 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 0  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -2.2 | 13.7 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 2  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -2.6 | 13.8 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 2  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 61.1 | 0.0 | -2.8 | 11.4 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 3  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 83 | 0.0 | 250  | 61.1 | 0.0 | -2.8 | 14.9 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 1  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.9 | 0.0 | -2.8 | 11.7 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 4  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 61.9 | 0.0 | -2.8 | 15.3 | 0.4  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 1  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 72 | 0.0 | 250  | 61.2 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 5  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 84 | 0.0 | 500  | 61.2 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 15 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.2 | 0.0 | -2.7 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 18 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 87 | 0.0 | 2000 | 61.2 | 0.0 | -2.7 | 0.0  | 3.1  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 14 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 67 | 0.0 | 63   | 63.3 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 6  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 63.3 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 63.3 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 63.3 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.3 | 0.0 | -3.0 | 0.0  | 1.5  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.3 | 0.0 | -3.0 | 0.0  | 4.0  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 9  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 67 | 0.0 | 63   | 63.3 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 6  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 63.3 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 63.3 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 63.3 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.3 | 0.0 | -3.0 | 0.0  | 1.5  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 16 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.3 | 0.0 | -3.0 | 0.0  | 4.0  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 9  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 74 | 0.0 | 125  | 58.9 | 0.0 | -0.3 | 8.8  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 2  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 79 | 0.0 | 250  | 58.9 | 0.0 | -1.0 | 12.2 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 0  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 74 | 0.0 | 125  | 59.7 | 0.0 | -0.4 | 8.6  | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 1  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 59.7 | 0.0 | -2.7 | 13.5 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 1  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 60.5 | 0.0 | -2.9 | 12.9 | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 1  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 74 | 0.0 | 125  | 60.8 | 0.0 | -0.3 | 8.4  | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 0  |
| S29       | HVAC RTU    | 17652331.9 | 4786466.0 | 5.5 | 0     | 76 | 0.0 | 125  | 61.6 | 0.0 | -1.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 10 |



Receiver: RP03

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 32          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP03          | RP03        | 17652529.24 m | 4786741.01 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 250  | 61.6 | 0.0 | -1.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 84  | 0.0 | 500  | 61.6 | 0.0 | -2.1 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.6 | 0.0 | -2.1 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 2000 | 61.6 | 0.0 | -2.1 | 0.0  | 3.3  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 4  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 76  | 0.0 | 125  | 62.1 | 0.0 | -1.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 250  | 62.1 | 0.0 | -2.2 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 84  | 0.0 | 500  | 62.1 | 0.0 | -2.4 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.1 | 0.0 | -2.4 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.1 | 0.0 | -2.4 | 0.0  | 3.5  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 4  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 56.2 | 0.0 | -2.6 | 21.3 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 6  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 56.2 | 0.0 | -2.6 | 24.2 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 56.2 | 0.0 | -2.6 | 27.2 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 11 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 56.2 | 0.0 | -2.6 | 27.6 | 0.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 12 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 56.2 | 0.0 | -2.6 | 27.6 | 1.8  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 56.2 | 0.0 | -2.6 | 27.6 | 6.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name    | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc  | RL  | Lr |
|-----------|----------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L01       | 15-Ton Pass-by | 17652672.5 | 4786882.7 | 1.5 | 0     | 52 | 9.1  | 125  | 53.5 | 0.0 | -2.1 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652672.5 | 4786882.7 | 1.5 | 0     | 57 | 9.1  | 250  | 53.5 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by | 17652672.5 | 4786882.7 | 1.5 | 0     | 63 | 9.1  | 500  | 53.5 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652672.5 | 4786882.7 | 1.5 | 0     | 63 | 9.1  | 1000 | 53.5 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 20 |
| L01       | 15-Ton Pass-by | 17652672.5 | 4786882.7 | 1.5 | 0     | 61 | 9.1  | 2000 | 53.5 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652672.5 | 4786882.7 | 1.5 | 0     | 55 | 9.1  | 4000 | 53.5 | 0.0 | -2.6 | 0.0  | 4.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L01       | 15-Ton Pass-by | 17652656.6 | 4786882.7 | 1.5 | 0     | 41 | 13.8 | 63   | 52.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by | 17652656.6 | 4786882.7 | 1.5 | 0     | 52 | 13.8 | 125  | 52.6 | 0.0 | -2.3 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652656.6 | 4786882.7 | 1.5 | 0     | 57 | 13.8 | 250  | 52.6 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652656.6 | 4786882.7 | 1.5 | 0     | 63 | 13.8 | 500  | 52.6 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 26 |
| L01       | 15-Ton Pass-by | 17652656.6 | 4786882.7 | 1.5 | 0     | 63 | 13.8 | 1000 | 52.6 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 26 |
| L01       | 15-Ton Pass-by | 17652656.6 | 4786882.7 | 1.5 | 0     | 61 | 13.8 | 2000 | 52.6 | 0.0 | -2.7 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 23 |
| L01       | 15-Ton Pass-by | 17652656.6 | 4786882.7 | 1.5 | 0     | 55 | 13.8 | 4000 | 52.6 | 0.0 | -2.7 | 0.0  | 3.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 41 | 10.4 | 63   | 53.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 52 | 10.4 | 125  | 53.6 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 57 | 10.4 | 250  | 53.6 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 63 | 10.4 | 500  | 53.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 22 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 63 | 10.4 | 1000 | 53.6 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 22 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 61 | 10.4 | 2000 | 53.6 | 0.0 | -2.7 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 19 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 55 | 10.4 | 4000 | 53.6 | 0.0 | -2.7 | 0.0  | 4.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652679.0 | 4786877.7 | 1.5 | 0     | 41 | 10.1 | 63   | 53.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L01       | 15-Ton Pass-by | 17652679.0 | 4786877.7 | 1.5 | 0     | 52 | 10.1 | 125  | 53.7 | 0.0 | -2.1 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652679.0 | 4786877.7 | 1.5 | 0     | 57 | 10.1 | 250  | 53.7 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652679.0 | 4786877.7 | 1.5 | 0     | 63 | 10.1 | 500  | 53.7 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 22 |
| L01       | 15-Ton Pass-by | 17652679.0 | 4786877.7 | 1.5 | 0     | 63 | 10.1 | 1000 | 53.7 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652679.0 | 4786877.7 | 1.5 | 0     | 61 | 10.1 | 2000 | 53.7 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652679.0 | 4786877.7 | 1.5 | 0     | 55 | 10.1 | 4000 | 53.7 | 0.0 | -2.6 | 0.0  | 4.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652676.7 | 4786882.5 | 1.5 | 0     | 57 | -3.7 | 250  | 53.7 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L01       | 15-Ton Pass-by | 17652676.7 | 4786882.5 | 1.5 | 0     | 63 | -3.7 | 500  | 53.7 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L01       | 15-Ton Pass-by | 17652676.7 | 4786882.5 | 1.5 | 0     | 63 | -3.7 | 1000 | 53.7 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652676.7 | 4786882.5 | 1.5 | 0     | 61 | -3.7 | 2000 | 53.7 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786866.8 | 1.5 | 0     | 52 | 3.2  | 125  | 53.6 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786866.8 | 1.5 | 0     | 57 | 3.2  | 250  | 53.6 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786866.8 | 1.5 | 0     | 63 | 3.2  | 500  | 53.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786866.8 | 1.5 | 0     | 63 | 3.2  | 1000 | 53.6 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786866.8 | 1.5 | 0     | 61 | 3.2  | 2000 | 53.6 | 0.0 | -2.7 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652683.7 | 4786866.8 | 1.5 | 0     | 55 | 3.2  | 4000 | 53.6 | 0.0 | -2.7 | 0.0  | 4.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by | 17652682.7 | 4786869.6 | 1.5 | 0     | 52 | 5.9  | 125  | 53.7 | 0.0 | -2.2 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652682.7 | 4786869.6 | 1.5 | 0     | 57 | 5.9  | 250  | 53.7 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652682.7 | 4786869.6 | 1.5 | 0     | 63 | 5.9  | 500  | 53.7 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652682.7 | 4786869.6 | 1.5 | 0     | 63 | 5.9  | 1000 | 53.7 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652682.7 | 4786869.6 | 1.5 | 0     | 61 | 5.9  | 2000 | 53.7 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652682.7 | 4786869.6 | 1.5 | 0     | 55 | 5.9  | 4000 | 53.7 | 0.0 | -2.6 | 0.0  | 4.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 52 | 2.7  | 125  | 53.7 | 0.0 | -2.2 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 57 | 2.7  | 250  | 53.7 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 63 | 2.7  | 500  | 53.7 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 63 | 2.7  | 1000 | 53.7 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 61 | 2.7  | 2000 | 53.7 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by   | 17652681.6 | 4786872.3 | 1.5 | 0     | 55 | 2.7  | 4000 | 53.7 | 0.0 | -2.6 | 0.0  | 4.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652649.9 | 4786967.3 | 1.5 | 0     | 52 | 15.6 | 125  | 56.1 | 0.0 | -2.7 | 7.5  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652649.9 | 4786967.3 | 1.5 | 0     | 57 | 15.6 | 250  | 56.1 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652649.9 | 4786967.3 | 1.5 | 0     | 63 | 15.6 | 500  | 56.1 | 0.0 | -2.9 | 7.7  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2 | 17652649.9 | 4786967.3 | 1.5 | 0     | 63 | 15.6 | 1000 | 56.1 | 0.0 | -2.9 | 7.8  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652649.9 | 4786967.3 | 1.5 | 0     | 61 | 15.6 | 2000 | 56.1 | 0.0 | -2.9 | 8.0  | 1.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652649.9 | 4786967.3 | 1.5 | 0     | 55 | 15.6 | 4000 | 56.1 | 0.0 | -2.9 | 8.4  | 5.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652629.9 | 4786966.3 | 1.5 | 0     | 52 | 6.1  | 125  | 55.6 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652629.9 | 4786966.3 | 1.5 | 0     | 57 | 6.1  | 250  | 55.6 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652629.9 | 4786966.3 | 1.5 | 0     | 63 | 6.1  | 500  | 55.6 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652629.9 | 4786966.3 | 1.5 | 0     | 63 | 6.1  | 1000 | 55.6 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652629.9 | 4786966.3 | 1.5 | 0     | 61 | 6.1  | 2000 | 55.6 | 0.0 | -2.8 | 0.0  | 1.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652629.9 | 4786966.3 | 1.5 | 0     | 55 | 6.1  | 4000 | 55.6 | 0.0 | -2.8 | 0.0  | 5.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652624.0 | 4786966.1 | 1.5 | 0     | 52 | 8.8  | 125  | 55.5 | 0.0 | -2.7 | 3.3  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652624.0 | 4786966.1 | 1.5 | 0     | 57 | 8.8  | 250  | 55.5 | 0.0 | -2.8 | 3.8  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652624.0 | 4786966.1 | 1.5 | 0     | 63 | 8.8  | 500  | 55.5 | 0.0 | -2.8 | 4.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652624.0 | 4786966.1 | 1.5 | 0     | 63 | 8.8  | 1000 | 55.5 | 0.0 | -2.8 | 5.1  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652624.0 | 4786966.1 | 1.5 | 0     | 61 | 8.8  | 2000 | 55.5 | 0.0 | -2.8 | 5.9  | 1.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652587.6 | 4786964.4 | 1.5 | 0     | 52 | 18.1 | 125  | 54.9 | 0.0 | -2.8 | 7.9  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652587.6 | 4786964.4 | 1.5 | 0     | 57 | 18.1 | 250  | 54.9 | 0.0 | -2.9 | 8.3  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652587.6 | 4786964.4 | 1.5 | 0     | 63 | 18.1 | 500  | 54.9 | 0.0 | -2.9 | 8.8  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 20 |
| L02       | 15-Ton Pass-by 2 | 17652587.6 | 4786964.4 | 1.5 | 0     | 63 | 18.1 | 1000 | 54.9 | 0.0 | -2.9 | 9.6  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652587.6 | 4786964.4 | 1.5 | 0     | 61 | 18.1 | 2000 | 54.9 | 0.0 | -2.9 | 10.9 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652587.6 | 4786964.4 | 1.5 | 0     | 55 | 18.1 | 4000 | 54.9 | 0.0 | -2.9 | 12.8 | 5.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652538.9 | 4786962.1 | 1.5 | 0     | 52 | 15.1 | 125  | 54.7 | 0.0 | -3.0 | 7.8  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652538.9 | 4786962.1 | 1.5 | 0     | 57 | 15.1 | 250  | 54.7 | 0.0 | -3.0 | 8.5  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652538.9 | 4786962.1 | 1.5 | 0     | 63 | 15.1 | 500  | 54.7 | 0.0 | -3.0 | 9.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652538.9 | 4786962.1 | 1.5 | 0     | 63 | 15.1 | 1000 | 54.7 | 0.0 | -3.0 | 10.7 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652538.9 | 4786962.1 | 1.5 | 0     | 61 | 15.1 | 2000 | 54.7 | 0.0 | -3.0 | 12.5 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652600.1 | 4787020.3 | 1.5 | 0     | 52 | 14.8 | 125  | 57.6 | 0.0 | -2.8 | 7.6  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652600.1 | 4787020.3 | 1.5 | 0     | 57 | 14.8 | 250  | 57.6 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652600.1 | 4787020.3 | 1.5 | 0     | 63 | 14.8 | 500  | 57.6 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652600.1 | 4787020.3 | 1.5 | 0     | 63 | 14.8 | 1000 | 57.6 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652600.1 | 4787020.3 | 1.5 | 0     | 61 | 14.8 | 2000 | 57.6 | 0.0 | -2.9 | 7.7  | 2.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652600.1 | 4787020.3 | 1.5 | 0     | 55 | 14.8 | 4000 | 57.6 | 0.0 | -2.9 | 7.7  | 7.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652628.6 | 4787021.4 | 1.5 | 0     | 52 | 14.2 | 125  | 57.9 | 0.0 | -2.7 | 8.2  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652628.6 | 4787021.4 | 1.5 | 0     | 57 | 14.2 | 250  | 57.9 | 0.0 | -2.9 | 8.9  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652628.6 | 4787021.4 | 1.5 | 0     | 63 | 14.2 | 500  | 57.9 | 0.0 | -2.9 | 9.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2 | 17652628.6 | 4787021.4 | 1.5 | 0     | 63 | 14.2 | 1000 | 57.9 | 0.0 | -2.9 | 11.4 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652628.6 | 4787021.4 | 1.5 | 0     | 61 | 14.2 | 2000 | 57.9 | 0.0 | -2.9 | 13.4 | 2.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652646.9 | 4787022.0 | 1.5 | 0     | 57 | 10.1 | 250  | 58.2 | 0.0 | -2.9 | 8.9  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652646.9 | 4787022.0 | 1.5 | 0     | 63 | 10.1 | 500  | 58.2 | 0.0 | -2.9 | 9.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652646.9 | 4787022.0 | 1.5 | 0     | 63 | 10.1 | 1000 | 58.2 | 0.0 | -2.9 | 11.3 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652654.4 | 4787022.3 | 1.5 | 0     | 63 | 6.9  | 500  | 58.3 | 0.0 | -2.9 | 9.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652654.4 | 4787022.3 | 1.5 | 0     | 63 | 6.9  | 1000 | 58.3 | 0.0 | -2.9 | 11.2 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652659.4 | 4787022.5 | 1.5 | 0     | 63 | 7.1  | 500  | 58.4 | 0.0 | -2.9 | 9.8  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652659.4 | 4787022.5 | 1.5 | 0     | 63 | 7.1  | 1000 | 58.4 | 0.0 | -2.9 | 11.2 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652675.6 | 4787023.1 | 1.5 | 0     | 52 | 14.3 | 125  | 58.7 | 0.0 | -2.7 | 8.1  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652675.6 | 4787023.1 | 1.5 | 0     | 57 | 14.3 | 250  | 58.7 | 0.0 | -2.9 | 8.8  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652675.6 | 4787023.1 | 1.5 | 0     | 63 | 14.3 | 500  | 58.7 | 0.0 | -2.9 | 9.7  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652675.6 | 4787023.1 | 1.5 | 0     | 63 | 14.3 | 1000 | 58.7 | 0.0 | -2.9 | 11.2 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652675.6 | 4787023.1 | 1.5 | 0     | 61 | 14.3 | 2000 | 58.7 | 0.0 | -2.9 | 13.1 | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652692.6 | 4787008.3 | 1.5 | 0     | 52 | 11.3 | 125  | 58.5 | 0.0 | -2.8 | 7.3  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652692.6 | 4787008.3 | 1.5 | 0     | 57 | 11.3 | 250  | 58.5 | 0.0 | -2.9 | 8.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652692.6 | 4787008.3 | 1.5 | 0     | 63 | 11.3 | 500  | 58.5 | 0.0 | -2.9 | 8.8  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652692.6 | 4787008.3 | 1.5 | 0     | 63 | 11.3 | 1000 | 58.5 | 0.0 | -2.9 | 10.0 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652692.6 | 4787008.3 | 1.5 | 0     | 61 | 11.3 | 2000 | 58.5 | 0.0 | -2.9 | 11.6 | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652691.9 | 4786996.8 | 1.5 | 0     | 57 | 9.9  | 250  | 58.2 | 0.0 | -2.9 | 7.9  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652691.9 | 4786996.8 | 1.5 | 0     | 63 | 9.9  | 500  | 58.2 | 0.0 | -2.9 | 9.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652691.9 | 4786996.8 | 1.5 | 0     | 63 | 9.9  | 1000 | 58.2 | 0.0 | -2.9 | 10.5 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652691.9 | 4786996.8 | 1.5 | 0     | 61 | 9.9  | 2000 | 58.2 | 0.0 | -2.9 | 12.4 | 2.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652691.2 | 4786985.4 | 1.5 | 0     | 52 | 11.2 | 125  | 57.8 | 0.0 | -2.7 | 7.5  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652691.2 | 4786985.4 | 1.5 | 0     | 57 | 11.2 | 250  | 57.8 | 0.0 | -2.9 | 7.6  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652691.2 | 4786985.4 | 1.5 | 0     | 63 | 11.2 | 500  | 57.8 | 0.0 | -2.9 | 7.6  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652691.2 | 4786985.4 | 1.5 | 0     | 63 | 11.2 | 1000 | 57.8 | 0.0 | -2.9 | 7.6  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652691.2 | 4786985.4 | 1.5 | 0     | 61 | 11.2 | 2000 | 57.8 | 0.0 | -2.9 | 7.6  | 2.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652690.7 | 4786977.7 | 1.5 | 0     | 63 | 3.6  | 500  | 57.5 | 0.0 | -2.9 | 7.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652690.7 | 4786977.7 | 1.5 | 0     | 63 | 3.6  | 1000 | 57.5 | 0.0 | -2.9 | 8.0  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 52 | 15.0 | 125  | 58.0 | 0.0 | -3.0 | 7.8  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 57 | 15.0 | 250  | 58.0 | 0.0 | -3.0 | 7.8  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 63 | 15.0 | 500  | 58.0 | 0.0 | -3.0 | 7.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 63 | 15.0 | 1000 | 58.0 | 0.0 | -3.0 | 7.8  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 61 | 15.0 | 2000 | 58.0 | 0.0 | -3.0 | 7.8  | 2.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 55 | 15.0 | 4000 | 58.0 | 0.0 | -3.0 | 7.8  | 7.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652689.9 | 4786976.3 | 1.5 | 0     | 63 | 1.8  | 500  | 57.5 | 0.0 | -2.9 | 7.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652689.9 | 4786976.3 | 1.5 | 0     | 63 | 1.8  | 1000 | 57.5 | 0.0 | -2.9 | 8.1  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652678.5 | 4786972.1 | 1.5 | 0     | 52 | 13.6 | 125  | 57.0 | 0.0 | -2.7 | 4.9  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652678.5 | 4786972.1 | 1.5 | 0     | 57 | 13.6 | 250  | 57.0 | 0.0 | -2.9 | 5.8  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652678.5 | 4786972.1 | 1.5 | 0     | 63 | 13.6 | 500  | 57.0 | 0.0 | -2.9 | 6.5  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652678.5 | 4786972.1 | 1.5 | 0     | 63 | 13.6 | 1000 | 57.0 | 0.0 | -2.9 | 7.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652678.5 | 4786972.1 | 1.5 | 0     | 61 | 13.6 | 2000 | 57.0 | 0.0 | -2.9 | 7.3  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc  | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2              | 17652678.5 | 4786972.1 | 1.5 | 0     | 55 | 13.6 | 4000 | 57.0 | 0.0 | -2.9 | 7.5  | 6.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 57 | 9.7  | 250  | 58.8 | 0.0 | -2.9 | 8.3  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 63 | 9.7  | 500  | 58.8 | 0.0 | -2.9 | 9.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 63 | 9.7  | 1000 | 58.8 | 0.0 | -2.9 | 10.2 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 61 | 9.7  | 2000 | 58.8 | 0.0 | -2.9 | 11.8 | 2.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 60 | 0.0  | 32   | 52.0 | 0.0 | -3.0 | 3.2  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 71 | 0.0  | 63   | 52.0 | 0.0 | -3.0 | 3.5  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 52.0 | 0.0 | -2.1 | 3.5  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 24 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 52.0 | 0.0 | -2.5 | 4.3  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 31 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 52.0 | 0.0 | -2.6 | 5.4  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 35 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 52.0 | 0.0 | -2.6 | 6.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 35 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 52.0 | 0.0 | -2.6 | 8.7  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 31 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 89 | 0.0  | 4000 | 52.0 | 0.0 | -2.6 | 11.0 | 3.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 19 |
| L03       | 5-Ton Pass-by                 | 17652672.5 | 4786882.7 | 1.5 | 0     | 47 | 9.1  | 500  | 53.5 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652672.5 | 4786882.7 | 1.5 | 0     | 50 | 9.1  | 1000 | 53.5 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L03       | 5-Ton Pass-by                 | 17652672.5 | 4786882.7 | 1.5 | 0     | 47 | 9.1  | 2000 | 53.5 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L03       | 5-Ton Pass-by                 | 17652656.6 | 4786882.7 | 1.5 | 0     | 41 | 13.8 | 250  | 52.6 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L03       | 5-Ton Pass-by                 | 17652656.6 | 4786882.7 | 1.5 | 0     | 47 | 13.8 | 500  | 52.6 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L03       | 5-Ton Pass-by                 | 17652656.6 | 4786882.7 | 1.5 | 0     | 50 | 13.8 | 1000 | 52.6 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L03       | 5-Ton Pass-by                 | 17652656.6 | 4786882.7 | 1.5 | 0     | 47 | 13.8 | 2000 | 52.6 | 0.0 | -2.7 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L03       | 5-Ton Pass-by                 | 17652656.6 | 4786882.7 | 1.5 | 0     | 44 | 13.8 | 4000 | 52.6 | 0.0 | -2.7 | 0.0  | 3.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 47 | 10.4 | 500  | 53.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 50 | 10.4 | 1000 | 53.6 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 47 | 10.4 | 2000 | 53.6 | 0.0 | -2.7 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652679.0 | 4786877.7 | 1.5 | 0     | 47 | 10.1 | 500  | 53.7 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652679.0 | 4786877.7 | 1.5 | 0     | 50 | 10.1 | 1000 | 53.7 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L03       | 5-Ton Pass-by                 | 17652679.0 | 4786877.7 | 1.5 | 0     | 47 | 10.1 | 2000 | 53.7 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652683.7 | 4786866.8 | 1.5 | 0     | 50 | 3.2  | 1000 | 53.6 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652682.7 | 4786869.6 | 1.5 | 0     | 47 | 5.9  | 500  | 53.7 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by                 | 17652682.7 | 4786869.6 | 1.5 | 0     | 50 | 5.9  | 1000 | 53.7 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652682.7 | 4786869.6 | 1.5 | 0     | 47 | 5.9  | 2000 | 53.7 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by                 | 17652681.6 | 4786872.3 | 1.5 | 0     | 50 | 2.7  | 1000 | 53.7 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652649.9 | 4786967.3 | 1.5 | 0     | 52 | 15.6 | 500  | 56.1 | 0.0 | -2.9 | 7.7  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652649.9 | 4786967.3 | 1.5 | 0     | 55 | 15.6 | 1000 | 56.1 | 0.0 | -2.9 | 7.8  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L04       | 5-Ton Pass-by 2               | 17652649.9 | 4786967.3 | 1.5 | 0     | 52 | 15.6 | 2000 | 56.1 | 0.0 | -2.9 | 8.0  | 1.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2               | 17652629.9 | 4786966.3 | 1.5 | 0     | 52 | 6.1  | 500  | 55.6 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652629.9 | 4786966.3 | 1.5 | 0     | 55 | 6.1  | 1000 | 55.6 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2               | 17652629.9 | 4786966.3 | 1.5 | 0     | 52 | 6.1  | 2000 | 55.6 | 0.0 | -2.8 | 0.0  | 1.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652624.0 | 4786966.1 | 1.5 | 0     | 52 | 8.8  | 500  | 55.5 | 0.0 | -2.8 | 4.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652624.0 | 4786966.1 | 1.5 | 0     | 55 | 8.8  | 1000 | 55.5 | 0.0 | -2.8 | 5.1  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652624.0 | 4786966.1 | 1.5 | 0     | 52 | 8.8  | 2000 | 55.5 | 0.0 | -2.8 | 5.9  | 1.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652587.6 | 4786964.4 | 1.5 | 0     | 45 | 18.1 | 250  | 54.9 | 0.0 | -2.9 | 8.3  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652587.6 | 4786964.4 | 1.5 | 0     | 52 | 18.1 | 500  | 54.9 | 0.0 | -2.9 | 8.8  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name          | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc    | RL  | Lr |
|-----------|----------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| L04       | 5-Ton Pass-by 2      | 17652587.6 | 4786964.4 | 1.5 | 0     | 55 | 18.1 | 1000 | 54.9 | 0.0 | -2.9 | 9.6  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| L04       | 5-Ton Pass-by 2      | 17652587.6 | 4786964.4 | 1.5 | 0     | 52 | 18.1 | 2000 | 54.9 | 0.0 | -2.9 | 10.9 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2      | 17652538.9 | 4786962.1 | 1.5 | 0     | 52 | 15.1 | 500  | 54.7 | 0.0 | -3.0 | 9.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2      | 17652538.9 | 4786962.1 | 1.5 | 0     | 55 | 15.1 | 1000 | 54.7 | 0.0 | -3.0 | 10.7 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652538.9 | 4786962.1 | 1.5 | 0     | 52 | 15.1 | 2000 | 54.7 | 0.0 | -3.0 | 12.5 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2      | 17652600.1 | 4787020.3 | 1.5 | 0     | 52 | 14.8 | 500  | 57.6 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2      | 17652600.1 | 4787020.3 | 1.5 | 0     | 55 | 14.8 | 1000 | 57.6 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652600.1 | 4787020.3 | 1.5 | 0     | 52 | 14.8 | 2000 | 57.6 | 0.0 | -2.9 | 7.7  | 2.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652628.6 | 4787021.4 | 1.5 | 0     | 52 | 14.2 | 500  | 57.9 | 0.0 | -2.9 | 9.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652628.6 | 4787021.4 | 1.5 | 0     | 55 | 14.2 | 1000 | 57.9 | 0.0 | -2.9 | 11.4 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652675.6 | 4787023.1 | 1.5 | 0     | 55 | 14.3 | 1000 | 58.7 | 0.0 | -2.9 | 11.2 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652692.6 | 4787008.3 | 1.5 | 0     | 55 | 11.3 | 1000 | 58.5 | 0.0 | -2.9 | 10.0 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652691.2 | 4786985.4 | 1.5 | 0     | 55 | 11.2 | 1000 | 57.8 | 0.0 | -2.9 | 7.6  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2      | 17652576.5 | 4787033.0 | 1.5 | 0     | 52 | 15.0 | 500  | 58.0 | 0.0 | -3.0 | 7.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2      | 17652576.5 | 4787033.0 | 1.5 | 0     | 55 | 15.0 | 1000 | 58.0 | 0.0 | -3.0 | 7.8  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652576.5 | 4787033.0 | 1.5 | 0     | 52 | 15.0 | 2000 | 58.0 | 0.0 | -3.0 | 7.8  | 2.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652678.5 | 4786972.1 | 1.5 | 0     | 52 | 13.6 | 500  | 57.0 | 0.0 | -2.9 | 6.5  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2      | 17652678.5 | 4786972.1 | 1.5 | 0     | 55 | 13.6 | 1000 | 57.0 | 0.0 | -2.9 | 7.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652678.5 | 4786972.1 | 1.5 | 0     | 52 | 13.6 | 2000 | 57.0 | 0.0 | -2.9 | 7.3  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 59 | 0.0  | 32   | 53.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 67 | 0.0  | 63   | 53.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 53.2 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 23 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 53.2 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 28 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 53.2 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 34 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 53.2 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 35 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 53.2 | 0.0 | -2.8 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 32 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 4000 | 53.2 | 0.0 | -2.8 | 0.0  | 4.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 24 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 81 | 0.0  | 8000 | 53.2 | 0.0 | -2.8 | 0.0  | 15.1 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 57 | 0.0  | 32   | 51.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 68 | 0.0  | 63   | 51.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 13 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 51.6 | 0.0 | -2.4 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 26 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0  | 250  | 51.6 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 35 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 500  | 51.6 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 42 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 1000 | 51.6 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 41 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 51.6 | 0.0 | -2.7 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 40 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0  | 4000 | 51.6 | 0.0 | -2.7 | 0.0  | 3.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 33 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 85 | 0.0  | 8000 | 51.6 | 0.0 | -2.7 | 0.0  | 12.5 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 17 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0  | 125  | 49.8 | 0.0 | -2.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 23 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0  | 250  | 49.8 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 23 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0  | 500  | 49.8 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 27 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 83 | 0.0  | 1000 | 49.8 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 25 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0  | 2000 | 49.8 | 0.0 | -2.6 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 19 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 73 | 0.0  | 4000 | 49.8 | 0.0 | -2.6 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -13.0 | 0.0 | 10 |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 50.1 | 0.0 | -1.5 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 23 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 250  | 50.1 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 22 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0 | 500  | 50.1 | 0.0 | -2.4 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 26 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 50.1 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 24 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 50.1 | 0.0 | -2.4 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 18 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 73 | 0.0 | 4000 | 50.1 | 0.0 | -2.4 | 0.0  | 3.0  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 9  |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0 | 63   | 56.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 12 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0 | 125  | 56.5 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 21 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0 | 250  | 56.5 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 22 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0 | 500  | 56.5 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 23 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 56.5 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 24 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 56.5 | 0.0 | -3.0 | 0.0  | 1.8  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 18 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 56.5 | 0.0 | -3.0 | 0.0  | 6.2  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 5  |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 67 | 0.0 | 63   | 57.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 12 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 57.3 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 20 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 57.3 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 21 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 87 | 0.0 | 500  | 57.3 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 22 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.3 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 23 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.3 | 0.0 | -2.9 | 0.0  | 2.0  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 17 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.3 | 0.0 | -2.9 | 0.0  | 6.8  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 4  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 61 | 0.0 | 125  | 56.6 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 2  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 72 | 0.0 | 250  | 56.6 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 10 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 84 | 0.0 | 500  | 56.6 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 56.6 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 24 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 87 | 0.0 | 2000 | 56.6 | 0.0 | -3.0 | 0.0  | 1.8  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 20 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 81 | 0.0 | 4000 | 56.6 | 0.0 | -3.0 | 0.0  | 6.2  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 8  |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 67 | 0.0 | 63   | 57.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 11 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 57.7 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 20 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 57.7 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 20 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 87 | 0.0 | 500  | 57.7 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 22 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.7 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.7 | 0.0 | -2.9 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 16 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.7 | 0.0 | -2.9 | 0.0  | 7.1  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 3  |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 67 | 0.0 | 63   | 57.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 11 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 57.8 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 20 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 57.8 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 20 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 87 | 0.0 | 500  | 57.8 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 22 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.8 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.8 | 0.0 | -2.9 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 16 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.8 | 0.0 | -2.9 | 0.0  | 7.2  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 3  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 67 | 0.0 | 63   | 57.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 11 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 57.8 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 20 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 57.8 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 20 |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 87 | 0.0 | 500  | 57.8 | 0.0 | -2.8 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 21 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.8 | 0.0 | -2.8 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.8 | 0.0 | -2.8 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 16 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.8 | 0.0 | -2.8 | 0.0  | 7.2  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 3  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 61 | 0.0 | 125  | 58.3 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 72 | 0.0 | 250  | 58.3 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 8  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 84 | 0.0 | 500  | 58.3 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 18 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.3 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 87 | 0.0 | 2000 | 58.3 | 0.0 | -2.9 | 0.0  | 2.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 18 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 81 | 0.0 | 4000 | 58.3 | 0.0 | -2.9 | 0.0  | 7.6  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 5  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 67 | 0.0 | 63   | 59.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 10 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 59.1 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 59.1 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 19 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 87 | 0.0 | 500  | 59.1 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.1 | 0.0 | -2.8 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 21 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.1 | 0.0 | -2.8 | 0.0  | 2.5  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 78 | 0.0 | 4000 | 59.1 | 0.0 | -2.8 | 0.0  | 8.4  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 0  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.6 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.6 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.6 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.6 | 0.0 | -2.8 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.6 | 0.0 | -2.8 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 67 | 0.0 | 63   | 59.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 59.6 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 59.6 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 87 | 0.0 | 500  | 59.6 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.6 | 0.0 | -2.8 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.6 | 0.0 | -2.8 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 65 | 0.0 | 63   | 59.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 8  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 59.0 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 16 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 83 | 0.0 | 250  | 59.0 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 500  | 59.0 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 1000 | 59.0 | 0.0 | -2.8 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.0 | 0.0 | -2.8 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 15 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 81 | 0.0 | 4000 | 59.0 | 0.0 | -2.8 | 0.0  | 8.3  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 4  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 67 | 0.0 | 63   | 59.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 59.8 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 59.8 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 87 | 0.0 | 500  | 59.8 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.8 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.8 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 67 | 0.0 | 63   | 59.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 59.8 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 59.8 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 59.8 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.8 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.8 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 14 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 67 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 59.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 14 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 67 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 59.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 18 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 18 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 14 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 67 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 59.9 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 18 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 59.9 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 18 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 87 | 0.0 | 500  | 59.9 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.9 | 0.0 | -2.9 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.9 | 0.0 | -2.9 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 72 | 0.0 | 250  | 59.7 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 7  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 84 | 0.0 | 500  | 59.7 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 17 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.7 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 20 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 87 | 0.0 | 2000 | 59.7 | 0.0 | -3.0 | 0.0  | 2.6  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 16 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 81 | 0.0 | 4000 | 59.7 | 0.0 | -3.0 | 0.0  | 8.9  | 0.0  | 0.0  | 0.0  | -13.0 | 0.0 | 3  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 62 | 0.0 | 63   | 56.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 7  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 56.4 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 17 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 56.4 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 18 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 83 | 0.0 | 500  | 56.4 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 82 | 0.0 | 1000 | 56.4 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 17 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 2000 | 56.4 | 0.0 | -3.0 | 0.0  | 1.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 77 | 0.0 | 4000 | 56.4 | 0.0 | -3.0 | 0.0  | 6.1  | 0.0  | 0.0  | 0.0  | -13.0 | 0.0 | 5  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 61 | 0.0 | 63   | 56.9 | 0.0 | -3.0 | 4.3  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 74 | 0.0 | 125  | 56.9 | 0.0 | 1.9  | 4.0  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 6  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 79 | 0.0 | 250  | 56.9 | 0.0 | -0.4 | 5.0  | 0.2  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 9  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 83 | 0.0 | 500  | 56.9 | 0.0 | -0.5 | 5.8  | 0.4  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 10 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 82 | 0.0 | 1000 | 56.9 | 0.0 | -0.5 | 6.9  | 0.7  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 7  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 81 | 0.0 | 2000 | 56.9 | 0.0 | -0.5 | 8.4  | 1.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 2  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 56.9 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 16 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 250  | 56.9 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 16 |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 84 | 0.0 | 500  | 56.9 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 56.9 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 17 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 2000 | 56.9 | 0.0 | -2.7 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 11 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 61.8 | 0.0 | -2.2 | 11.2 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 61.8 | 0.0 | -2.6 | 14.0 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 2  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 61.8 | 0.0 | -2.7 | 16.8 | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 0  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 62.0 | 0.0 | -2.3 | 11.8 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 62.0 | 0.0 | -2.7 | 14.6 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 61.8 | 0.0 | -2.6 | 5.8  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 8  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.8 | 0.0 | -2.6 | 6.7  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 87 | 0.0 | 2000 | 61.8 | 0.0 | -2.6 | 8.0  | 3.3  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 5  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 61 | 0.0 | 63   | 57.9 | 0.0 | -3.0 | 4.4  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 1  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 74 | 0.0 | 125  | 57.9 | 0.0 | 1.5  | 4.2  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 5  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 79 | 0.0 | 250  | 57.9 | 0.0 | -0.6 | 5.2  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 8  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 83 | 0.0 | 500  | 57.9 | 0.0 | -0.7 | 6.2  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 9  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 82 | 0.0 | 1000 | 57.9 | 0.0 | -0.7 | 7.4  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 6  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 81 | 0.0 | 2000 | 57.9 | 0.0 | -0.7 | 9.1  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 1  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 57.9 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 16 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 250  | 57.9 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 15 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 84 | 0.0 | 500  | 57.9 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 57.9 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 16 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 57.9 | 0.0 | -2.9 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 10 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 74 | 0.0 | 125  | 59.2 | 0.0 | 1.6  | 4.1  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 79 | 0.0 | 250  | 59.2 | 0.0 | -0.6 | 5.1  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 6  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 83 | 0.0 | 500  | 59.2 | 0.0 | -0.7 | 5.9  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 8  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 82 | 0.0 | 1000 | 59.2 | 0.0 | -0.7 | 7.1  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 4  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 67 | 0.0 | 63   | 64.3 | 0.0 | -3.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 5  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 64.3 | 0.0 | -1.8 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 12 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 64.3 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 64.3 | 0.0 | -2.8 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 64.3 | 0.0 | -2.8 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 85 | 0.0 | 2000 | 64.3 | 0.0 | -2.8 | 0.0  | 4.5  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 7  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 67 | 0.0 | 63   | 64.3 | 0.0 | -3.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 5  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 64.3 | 0.0 | -1.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 12 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 64.3 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 64.3 | 0.0 | -2.7 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 64.3 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 64.3 | 0.0 | -2.7 | 0.0  | 4.5  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 7  |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 76 | 0.0 | 125  | 59.6 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 79 | 0.0 | 250  | 59.6 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 84 | 0.0 | 500  | 59.6 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 17 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 83 | 0.0 | 1000 | 59.6 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 15 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 79 | 0.0 | 2000 | 59.6 | 0.0 | -3.0 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |



Receiver: RP04

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP04          | RP04        | 17652560.55 m | 4786810.62 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 76  | 0.0 | 125  | 59.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 79  | 0.0 | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 84  | 0.0 | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 17 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 14 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 79  | 0.0 | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 7  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 76  | 0.0 | 125  | 59.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 84  | 0.0 | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 17 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 83  | 0.0 | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 14 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 7  |
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 74  | 0.0 | 125  | 60.0 | 0.0 | 1.6  | 4.1  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 79  | 0.0 | 250  | 60.0 | 0.0 | -0.6 | 5.2  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 6  |
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 83  | 0.0 | 500  | 60.0 | 0.0 | -0.7 | 6.1  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 82  | 0.0 | 1000 | 60.0 | 0.0 | -0.7 | 7.4  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 3  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 62  | 0.0 | 63   | 57.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 7  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 70  | 0.0 | 125  | 57.1 | 0.0 | -2.1 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 10 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 72  | 0.0 | 250  | 57.1 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 8  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 79  | 0.0 | 500  | 57.1 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 76  | 0.0 | 1000 | 57.1 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 10 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 75  | 0.0 | 2000 | 57.1 | 0.0 | -2.7 | 0.0  | 2.0  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 6  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 74  | 0.0 | 4000 | 57.1 | 0.0 | -2.7 | 0.0  | 6.6  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 0  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 61  | 0.0 | 32   | 52.1 | 0.0 | -3.0 | 3.1  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 3  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 72  | 0.0 | 63   | 52.1 | 0.0 | -3.0 | 3.1  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 14 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 52.1 | 0.0 | -2.1 | 2.9  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 28 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 52.1 | 0.0 | -2.5 | 3.2  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 32 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 52.1 | 0.0 | -2.6 | 3.5  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 39 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 52.1 | 0.0 | -2.6 | 4.1  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 40 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 52.1 | 0.0 | -2.6 | 5.1  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 37 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 52.1 | 0.0 | -2.6 | 6.6  | 3.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 28 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 85  | 0.0 | 8000 | 52.1 | 0.0 | -2.6 | 8.6  | 13.2 | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 8  |



Receiver: RP05

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 31          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP05          | RP05        | 17652574.56 m | 4786747.95 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0 | 125  | 54.4 | 0.0 | -1.7 | 18.5 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0 | 250  | 54.4 | 0.0 | -2.4 | 22.0 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0 | 500  | 54.4 | 0.0 | -2.4 | 25.0 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 13 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0 | 1000 | 54.4 | 0.0 | -2.4 | 26.2 | 0.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 13 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0 | 2000 | 54.4 | 0.0 | -2.4 | 26.7 | 1.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 62 | 0.0 | 63   | 61.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 2  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 70 | 0.0 | 125  | 61.8 | 0.0 | -2.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 6  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 72 | 0.0 | 250  | 61.8 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 79 | 0.0 | 500  | 61.8 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 10 |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 76 | 0.0 | 1000 | 61.8 | 0.0 | -2.7 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 4  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 75 | 0.0 | 2000 | 61.8 | 0.0 | -2.7 | 0.0  | 3.3  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 0  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0 | 125  | 55.6 | 0.0 | -2.0 | 16.9 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 3  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0 | 250  | 55.6 | 0.0 | -2.5 | 21.2 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 4  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0 | 500  | 55.6 | 0.0 | -2.5 | 24.6 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0 | 1000 | 55.6 | 0.0 | -2.5 | 26.2 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 6  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0 | 2000 | 55.6 | 0.0 | -2.5 | 26.8 | 1.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0 | 125  | 54.6 | 0.0 | -1.8 | 17.0 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0 | 250  | 54.6 | 0.0 | -2.4 | 21.3 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0 | 500  | 54.6 | 0.0 | -2.4 | 24.7 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 13 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0 | 1000 | 54.6 | 0.0 | -2.4 | 26.2 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 12 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0 | 2000 | 54.6 | 0.0 | -2.4 | 26.8 | 1.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 9  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0 | 4000 | 54.6 | 0.0 | -2.4 | 27.1 | 5.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.0 | 0.0 | -3.0 | 9.7  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 0  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.0 | 0.0 | -3.0 | 12.5 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 6  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.0 | 0.0 | -3.0 | 15.4 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.0 | 0.0 | -3.0 | 18.3 | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 2  |
| S15       | HVAC RTU                      | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.0 | 0.0 | -3.0 | 21.0 | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 0  |
| S17       | HVAC RTU                      | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0 | 125  | 54.3 | 0.0 | -2.1 | 15.3 | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 4  |
| S35       | HVAC RTU                      | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 59.2 | 0.0 | -1.7 | 15.2 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S08       | HVAC RTU                      | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.2 | 0.0 | -1.8 | 16.1 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S16       | HVAC RTU                      | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 54.5 | 0.0 | -1.6 | 15.2 | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 3  |
| S11       | HVAC RTU                      | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.6 | 0.0 | -2.1 | 16.5 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S10       | HVAC RTU                      | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 59.6 | 0.0 | -2.1 | 16.4 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S34       | HVAC RTU                      | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 60.1 | 0.0 | -1.7 | 14.7 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S05       | HVAC RTU                      | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.6 | 0.0 | -1.8 | 14.9 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S06       | HVAC RTU                      | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 60.6 | 0.0 | -1.8 | 14.9 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S07       | HVAC RTU                      | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 60.9 | 0.0 | -1.8 | 15.0 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 67 | 0.0 | 63   | 61.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 8  |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 61.1 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 17 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 61.1 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 17 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 61.1 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 18 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.1 | 0.0 | -3.0 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S26       | HVAC RTU                      | 17652295.7 | 4786588.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.1 | 0.0 | -3.0 | 0.0  | 3.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 12 |



Receiver: RP05

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 31          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP05          | RP05        | 17652574.56 m | 4786747.95 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 67 | 0.0 | 63   | 61.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 8  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 61.3 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 16 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 61.3 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 17 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 87 | 0.0 | 500  | 61.3 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.3 | 0.0 | -2.9 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.3 | 0.0 | -2.9 | 0.0  | 3.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 12 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.6 | 0.0 | -3.0 | 12.4 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.6 | 0.0 | -3.0 | 15.3 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.6 | 0.0 | -2.9 | 9.6  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 6  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.6 | 0.0 | -2.9 | 12.1 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 61.6 | 0.0 | -2.9 | 14.8 | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 3  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.6 | 0.0 | -2.9 | 17.5 | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 1  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -3.0 | 11.2 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 5  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 61.7 | 0.0 | -3.0 | 13.9 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 61.7 | 0.0 | -3.0 | 16.8 | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 1  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -3.0 | 10.4 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 6  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.7 | 0.0 | -3.0 | 13.0 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 61.7 | 0.0 | -3.0 | 15.8 | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 2  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 72 | 0.0 | 250  | 61.5 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 5  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 61.5 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.5 | 0.0 | -3.0 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 18 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 87 | 0.0 | 2000 | 61.5 | 0.0 | -3.0 | 0.0  | 3.3  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 13 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 72 | 0.0 | 250  | 62.2 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 84 | 0.0 | 500  | 62.2 | 0.0 | -2.8 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 62.2 | 0.0 | -2.8 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 17 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 87 | 0.0 | 2000 | 62.2 | 0.0 | -2.8 | 0.0  | 3.5  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 12 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 59.0 | 0.0 | -3.0 | 13.5 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 67 | 0.0 | 63   | 64.2 | 0.0 | -3.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 5  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 64.2 | 0.0 | -3.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 64.2 | 0.0 | -3.5 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 14 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 64.2 | 0.0 | -3.5 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 64.2 | 0.0 | -3.5 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 85 | 0.0 | 2000 | 64.2 | 0.0 | -3.5 | 0.0  | 4.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 67 | 0.0 | 63   | 64.2 | 0.0 | -3.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 5  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 64.2 | 0.0 | -3.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 64.2 | 0.0 | -3.5 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 14 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 64.2 | 0.0 | -3.5 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 64.2 | 0.0 | -3.5 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 16 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 64.2 | 0.0 | -3.5 | 0.0  | 4.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 76 | 0.0 | 125  | 61.4 | 0.0 | -3.0 | 12.5 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S29       | HVAC RTU    | 17652331.9 | 4786466.0 | 5.5 | 0     | 76 | 0.0 | 125  | 62.4 | 0.0 | -1.1 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 10 |
| S29       | HVAC RTU    | 17652331.9 | 4786466.0 | 5.5 | 0     | 79 | 0.0 | 250  | 62.4 | 0.0 | -2.1 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S29       | HVAC RTU    | 17652331.9 | 4786466.0 | 5.5 | 0     | 84 | 0.0 | 500  | 62.4 | 0.0 | -2.4 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |



Receiver: RP05

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 31          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP05          | RP05        | 17652574.56 m | 4786747.95 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.4 | 0.0 | -2.4 | 0.0  | 1.4  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.4 | 0.0 | -2.4 | 0.0  | 3.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 3  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 76  | 0.0 | 125  | 62.9 | 0.0 | -1.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 250  | 62.9 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 84  | 0.0 | 500  | 62.9 | 0.0 | -2.6 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.9 | 0.0 | -2.6 | 0.0  | 1.4  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.9 | 0.0 | -2.6 | 0.0  | 3.8  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 3  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 54.4 | 0.0 | -1.7 | 18.4 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 9  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 54.4 | 0.0 | -2.4 | 21.9 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 11 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 54.4 | 0.0 | -2.4 | 24.9 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 15 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 54.4 | 0.0 | -2.4 | 26.2 | 0.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 15 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 54.4 | 0.0 | -2.4 | 26.8 | 1.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 13 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 54.4 | 0.0 | -2.4 | 27.1 | 4.9  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 4  |



Receiver: RP06

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 33          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP06          | RP06        | 17652586.84 m | 4786749.91 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc   | RL    | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|------|-------|----|
| L01       | 15-Ton Pass-by                | 17652674.7 | 4786882.7 | 1.5 | 0     | 57 | 5.9  | 250  | 55.0 | 0.0 | -2.3 | 9.8  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0  |
| L01       | 15-Ton Pass-by                | 17652674.7 | 4786882.7 | 1.5 | 0     | 63 | 5.9  | 500  | 55.0 | 0.0 | -2.3 | 12.3 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 3  |
| L01       | 15-Ton Pass-by                | 17652674.7 | 4786882.7 | 1.5 | 0     | 63 | 5.9  | 1000 | 55.0 | 0.0 | -2.3 | 15.0 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0  |
| L01       | 15-Ton Pass-by                | 17652667.5 | 4786882.7 | 1.5 | 0     | 63 | 8.5  | 500  | 54.8 | 0.0 | -2.3 | 17.4 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| L01       | 15-Ton Pass-by                | 17652655.9 | 4786882.7 | 1.5 | 0     | 63 | 9.3  | 500  | 54.5 | 0.0 | -2.4 | 18.8 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| L01       | 15-Ton Pass-by                | 17652648.5 | 4786882.7 | 1.5 | 0     | 57 | 8.0  | 250  | 54.3 | 0.0 | -2.3 | 11.2 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 2  |
| L01       | 15-Ton Pass-by                | 17652648.5 | 4786882.7 | 1.5 | 0     | 63 | 8.0  | 500  | 54.3 | 0.0 | -2.4 | 13.9 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 5  |
| L01       | 15-Ton Pass-by                | 17652648.5 | 4786882.7 | 1.5 | 0     | 63 | 8.0  | 1000 | 54.3 | 0.0 | -2.4 | 16.7 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| L01       | 15-Ton Pass-by                | 17652686.4 | 4786859.8 | 1.5 | 0     | 52 | 9.4  | 125  | 54.4 | 0.0 | -0.2 | 6.3  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| L01       | 15-Ton Pass-by                | 17652686.4 | 4786859.8 | 1.5 | 0     | 57 | 9.4  | 250  | 54.4 | 0.0 | 0.4  | 7.9  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 4  |
| L01       | 15-Ton Pass-by                | 17652686.4 | 4786859.8 | 1.5 | 0     | 63 | 9.4  | 500  | 54.4 | 0.0 | -0.2 | 10.2 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 8  |
| L01       | 15-Ton Pass-by                | 17652686.4 | 4786859.8 | 1.5 | 0     | 63 | 9.4  | 1000 | 54.4 | 0.0 | -1.4 | 12.8 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 6  |
| L01       | 15-Ton Pass-by                | 17652686.4 | 4786859.8 | 1.5 | 0     | 61 | 9.4  | 2000 | 54.4 | 0.0 | -1.6 | 15.3 | 1.4  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| L01       | 15-Ton Pass-by                | 17652684.5 | 4786864.9 | 1.5 | 0     | 63 | 3.3  | 500  | 54.6 | 0.0 | -1.4 | 10.7 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 2  |
| L01       | 15-Ton Pass-by                | 17652678.9 | 4786877.9 | 1.5 | 0     | 52 | 10.3 | 125  | 55.0 | 0.0 | -1.5 | 7.3  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 2  |
| L01       | 15-Ton Pass-by                | 17652678.9 | 4786877.9 | 1.5 | 0     | 57 | 10.3 | 250  | 55.0 | 0.0 | -2.3 | 9.4  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 5  |
| L01       | 15-Ton Pass-by                | 17652678.9 | 4786877.9 | 1.5 | 0     | 63 | 10.3 | 500  | 55.0 | 0.0 | -2.3 | 11.8 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 8  |
| L01       | 15-Ton Pass-by                | 17652678.9 | 4786877.9 | 1.5 | 0     | 63 | 10.3 | 1000 | 55.0 | 0.0 | -2.3 | 14.5 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 5  |
| L01       | 15-Ton Pass-by                | 17652682.7 | 4786869.5 | 1.5 | 0     | 52 | 8.9  | 125  | 54.7 | 0.0 | -1.3 | 6.9  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| L01       | 15-Ton Pass-by                | 17652682.7 | 4786869.5 | 1.5 | 0     | 57 | 8.9  | 250  | 54.7 | 0.0 | -2.2 | 8.9  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 4  |
| L01       | 15-Ton Pass-by                | 17652682.7 | 4786869.5 | 1.5 | 0     | 63 | 8.9  | 500  | 54.7 | 0.0 | -2.2 | 11.2 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 8  |
| L01       | 15-Ton Pass-by                | 17652682.7 | 4786869.5 | 1.5 | 0     | 63 | 8.9  | 1000 | 54.7 | 0.0 | -2.2 | 13.8 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 5  |
| L02       | 15-Ton Pass-by 2              | 17652616.3 | 4786965.7 | 1.5 | 0     | 63 | 9.9  | 500  | 57.8 | 0.0 | -2.6 | 16.3 | 0.4  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| L02       | 15-Ton Pass-by 2              | 17652672.0 | 4786969.7 | 1.5 | 0     | 63 | 9.5  | 500  | 58.4 | 0.0 | -2.5 | 14.5 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 71 | 0.0  | 63   | 53.9 | 0.0 | -3.0 | 13.3 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 53.9 | 0.0 | -1.5 | 15.8 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 10 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 53.9 | 0.0 | -2.2 | 19.1 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 14 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 53.9 | 0.0 | -2.3 | 22.1 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 16 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 53.9 | 0.0 | -2.3 | 24.1 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 16 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 53.9 | 0.0 | -2.3 | 25.4 | 1.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 12 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 89 | 0.0  | 4000 | 53.9 | 0.0 | -2.3 | 26.2 | 4.6  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 62 | 0.0  | 63   | 62.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0 | 0.0   | 2  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 70 | 0.0  | 125  | 62.1 | 0.0 | -2.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 5  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 72 | 0.0  | 250  | 62.1 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0  | -9.0  | 3  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 79 | 0.0  | 500  | 62.1 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0  | -10.0 | 9  |
| S39       | Cooling Tower                 | 17652315.3 | 4786518.2 | 5.5 | 0     | 76 | 0.0  | 1000 | 62.1 | 0.0 | -2.7 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0  | -11.0 | 4  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 55.2 | 0.0 | -1.7 | 12.8 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 8  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 55.2 | 0.0 | -2.4 | 16.2 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 9  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 55.2 | 0.0 | -2.4 | 19.7 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 12 |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 55.2 | 0.0 | -2.4 | 22.8 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 10 |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 55.2 | 0.0 | -2.4 | 24.5 | 1.6  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 5  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 68 | 0.0  | 63   | 54.3 | 0.0 | -3.0 | 9.4  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 1  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 54.3 | 0.0 | -1.6 | 11.8 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 11 |



Receiver: RP06

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 33          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP06          | RP06        | 17652586.84 m | 4786749.91 m | 7.00 m |

| Source ID | Source Name          | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc    | RL  | Lr |
|-----------|----------------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0 | 250  | 54.3 | 0.0 | -2.3 | 15.2 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 16 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0 | 500  | 54.3 | 0.0 | -2.3 | 18.5 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 20 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0 | 1000 | 54.3 | 0.0 | -2.3 | 21.5 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 17 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0 | 2000 | 54.3 | 0.0 | -2.3 | 23.5 | 1.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 13 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0 | 4000 | 54.3 | 0.0 | -2.3 | 25.0 | 4.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| S35       | HVAC RTU             | 17652724.4 | 4786956.5 | 5.5 | 0     | 67 | 0.0 | 63   | 58.9 | 0.0 | -3.0 | 6.2  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 4  |
| S35       | HVAC RTU             | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 58.9 | 0.0 | -1.5 | 7.5  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 10 |
| S35       | HVAC RTU             | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 58.9 | 0.0 | -2.3 | 9.7  | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 9  |
| S35       | HVAC RTU             | 17652724.4 | 4786956.5 | 5.5 | 0     | 87 | 0.0 | 500  | 58.9 | 0.0 | -2.4 | 12.2 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 8  |
| S35       | HVAC RTU             | 17652724.4 | 4786956.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.9 | 0.0 | -2.4 | 15.0 | 0.9  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 6  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.0 | 0.0 | -3.0 | 7.3  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 3  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.0 | 0.0 | -1.6 | 9.1  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 8  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.0 | 0.0 | -2.4 | 11.8 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 7  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.0 | 0.0 | -2.4 | 14.7 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.0 | 0.0 | -2.4 | 17.5 | 0.9  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 3  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.0 | 0.0 | -3.0 | 9.2  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 1  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.0 | 0.0 | -2.7 | 12.0 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 7  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.0 | 0.0 | -2.9 | 15.0 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 4  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.0 | 0.0 | -2.9 | 18.0 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 2  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.0 | 0.0 | -2.9 | 20.7 | 0.9  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 0  |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0 | 125  | 54.2 | 0.0 | -1.1 | 10.9 | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 7  |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0 | 250  | 54.2 | 0.0 | -2.1 | 14.2 | 0.2  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 4  |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0 | 500  | 54.2 | 0.0 | -2.3 | 17.3 | 0.3  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 54.3 | 0.0 | -0.7 | 10.6 | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 7  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 250  | 54.3 | 0.0 | -1.9 | 13.9 | 0.2  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 4  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0 | 500  | 54.3 | 0.0 | -2.1 | 17.0 | 0.3  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.4 | 0.0 | -3.0 | 7.6  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.4 | 0.0 | -1.8 | 9.5  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 8  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.4 | 0.0 | -2.4 | 12.2 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 6  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.4 | 0.0 | -2.5 | 15.1 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 4  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.4 | 0.0 | -2.5 | 18.0 | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 2  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 67 | 0.0 | 63   | 59.4 | 0.0 | -3.0 | 7.5  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 59.4 | 0.0 | -1.8 | 9.3  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 8  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 59.4 | 0.0 | -2.4 | 12.0 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 6  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 87 | 0.0 | 500  | 59.4 | 0.0 | -2.5 | 14.9 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 4  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.4 | 0.0 | -2.5 | 17.8 | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 2  |
| S34       | HVAC RTU             | 17652772.1 | 4786953.1 | 5.5 | 0     | 67 | 0.0 | 63   | 59.8 | 0.0 | -3.0 | 5.4  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 4  |
| S34       | HVAC RTU             | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 59.8 | 0.0 | -1.3 | 6.4  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 10 |
| S34       | HVAC RTU             | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 59.8 | 0.0 | -2.2 | 8.1  | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 9  |
| S34       | HVAC RTU             | 17652772.1 | 4786953.1 | 5.5 | 0     | 87 | 0.0 | 500  | 59.8 | 0.0 | -2.3 | 10.2 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 9  |
| S34       | HVAC RTU             | 17652772.1 | 4786953.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.8 | 0.0 | -2.3 | 12.7 | 1.0  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 7  |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.1 | 0.0 | -2.8 | 20.6 | 0.9  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 0  |
| S05       | HVAC RTU             | 17652774.7 | 4786972.8 | 5.5 | 0     | 67 | 0.0 | 63   | 60.3 | 0.0 | -3.0 | 5.6  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 3  |



Receiver: RP06

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 33          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP06          | RP06        | 17652586.84 m | 4786749.91 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.3 | 0.0 | -1.6 | 6.7  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 9  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.3 | 0.0 | -2.3 | 8.6  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 87 | 0.0 | 500  | 60.3 | 0.0 | -2.4 | 10.8 | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 8  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.3 | 0.0 | -2.4 | 13.3 | 1.1  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 6  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 67 | 0.0 | 63   | 60.3 | 0.0 | -3.0 | 5.6  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 3  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 60.3 | 0.0 | -1.6 | 6.7  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 9  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 60.3 | 0.0 | -2.3 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 87 | 0.0 | 500  | 60.3 | 0.0 | -2.4 | 10.7 | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 8  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.3 | 0.0 | -2.4 | 13.3 | 1.1  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 6  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 84 | 0.0 | 500  | 59.6 | 0.0 | -2.5 | 13.4 | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 3  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.6 | 0.0 | -2.5 | 16.3 | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 4  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 65 | 0.0 | 63   | 59.8 | 0.0 | -3.0 | 5.5  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 2  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 59.8 | 0.0 | -1.5 | 6.6  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 8  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 83 | 0.0 | 250  | 59.8 | 0.0 | -2.3 | 8.4  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 8  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 500  | 59.8 | 0.0 | -2.3 | 10.6 | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 8  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 1000 | 59.8 | 0.0 | -2.3 | 13.2 | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 4  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 67 | 0.0 | 63   | 60.7 | 0.0 | -3.0 | 5.8  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 2  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 60.7 | 0.0 | -1.7 | 7.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 9  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 60.7 | 0.0 | -2.4 | 9.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 8  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 87 | 0.0 | 500  | 60.7 | 0.0 | -2.4 | 11.3 | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.7 | 0.0 | -2.4 | 13.9 | 1.1  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 5  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 67 | 0.0 | 63   | 61.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 7  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 61.4 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 16 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 61.4 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 17 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 61.4 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 18 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -3.0 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 18 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.4 | 0.0 | -3.0 | 0.0  | 3.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 12 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.6 | 0.0 | -2.8 | 11.8 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.6 | 0.0 | -2.9 | 14.9 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 2  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 67 | 0.0 | 63   | 61.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 7  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 61.6 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 16 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 61.6 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 16 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 87 | 0.0 | 500  | 61.6 | 0.0 | -2.9 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.6 | 0.0 | -2.9 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.6 | 0.0 | -2.9 | 0.0  | 3.3  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 11 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 61 | 0.0 | 63   | 56.8 | 0.0 | -3.0 | 4.4  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 2  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 74 | 0.0 | 125  | 56.8 | 0.0 | 1.9  | 4.1  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 6  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 79 | 0.0 | 250  | 56.8 | 0.0 | -0.4 | 4.9  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 83 | 0.0 | 500  | 56.8 | 0.0 | -0.5 | 5.5  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 11 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 82 | 0.0 | 1000 | 56.8 | 0.0 | -0.5 | 6.3  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 8  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 81 | 0.0 | 2000 | 56.8 | 0.0 | -0.5 | 7.5  | 1.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 4  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -3.0 | 12.5 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.7 | 0.0 | -3.0 | 15.4 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |



Receiver: RP06

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 33          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP06          | RP06        | 17652586.84 m | 4786749.91 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -3.0 | 12.2 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 61.7 | 0.0 | -3.0 | 15.2 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -3.0 | 12.3 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.7 | 0.0 | -3.0 | 15.3 | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 61 | 0.0 | 63   | 57.7 | 0.0 | -3.0 | 4.2  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 1  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 74 | 0.0 | 125  | 57.7 | 0.0 | 1.3  | 4.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 6  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 79 | 0.0 | 250  | 57.7 | 0.0 | -0.7 | 4.6  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 83 | 0.0 | 500  | 57.7 | 0.0 | -0.8 | 4.9  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 11 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 82 | 0.0 | 1000 | 57.7 | 0.0 | -0.8 | 5.3  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 8  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 81 | 0.0 | 2000 | 57.7 | 0.0 | -0.8 | 5.7  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 4  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 61.9 | 0.0 | -3.0 | 7.8  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.9 | 0.0 | -3.0 | 9.6  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 8  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 87 | 0.0 | 2000 | 61.9 | 0.0 | -3.0 | 11.8 | 3.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 1  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 72 | 0.0 | 250  | 62.5 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 84 | 0.0 | 500  | 62.5 | 0.0 | -2.8 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 62.5 | 0.0 | -2.8 | 0.0  | 1.4  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 17 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 87 | 0.0 | 2000 | 62.5 | 0.0 | -2.8 | 0.0  | 3.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 12 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 59.0 | 0.0 | -1.7 | 10.2 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 250  | 59.0 | 0.0 | -2.4 | 13.2 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 84 | 0.0 | 500  | 59.0 | 0.0 | -2.5 | 16.3 | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 1  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 74 | 0.0 | 125  | 59.0 | 0.0 | 1.2  | 3.9  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 5  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 79 | 0.0 | 250  | 59.0 | 0.0 | -0.7 | 4.5  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 7  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 83 | 0.0 | 500  | 59.0 | 0.0 | -0.8 | 4.7  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 9  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 82 | 0.0 | 1000 | 59.0 | 0.0 | -0.8 | 4.9  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 7  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 81 | 0.0 | 2000 | 59.0 | 0.0 | -0.8 | 5.0  | 2.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 4  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 58.9 | 0.0 | -2.2 | 11.6 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 58.9 | 0.0 | -2.6 | 14.7 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 59.5 | 0.0 | -1.8 | 9.1  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 4  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 250  | 59.5 | 0.0 | -2.4 | 11.8 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 84 | 0.0 | 500  | 59.5 | 0.0 | -2.5 | 14.7 | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 2  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 64.4 | 0.0 | -3.6 | 5.8  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 8  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 64.4 | 0.0 | -3.6 | 7.0  | 0.5  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 7  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 64.4 | 0.0 | -3.6 | 8.6  | 0.9  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 64.4 | 0.0 | -3.6 | 10.6 | 1.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 5  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 64.5 | 0.0 | -3.6 | 5.9  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 8  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 64.5 | 0.0 | -3.6 | 7.1  | 0.5  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 7  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 64.5 | 0.0 | -3.6 | 8.8  | 0.9  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 6  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 64.5 | 0.0 | -3.6 | 10.8 | 1.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 5  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 61 | 0.0 | 63   | 59.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 3  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 74 | 0.0 | 125  | 59.8 | 0.0 | 1.3  | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 8  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 79 | 0.0 | 250  | 59.8 | 0.0 | -0.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 11 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 83 | 0.0 | 500  | 59.8 | 0.0 | -0.8 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 82 | 0.0 | 1000 | 59.8 | 0.0 | -0.8 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |



Receiver: RP06

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 33          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP06          | RP06        | 17652586.84 m | 4786749.91 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S04       | HVAC RTU                      | 17652837.9 | 4786861.4 | 8.0 | 0     | 81  | 0.0 | 2000 | 59.8 | 0.0 | -0.8 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 76  | 0.0 | 125  | 61.4 | 0.0 | -2.8 | 11.8 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 76  | 0.0 | 125  | 61.7 | 0.0 | -2.7 | 11.6 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 76  | 0.0 | 125  | 61.7 | 0.0 | -2.8 | 11.8 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 76  | 0.0 | 125  | 62.6 | 0.0 | -1.1 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 9  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 250  | 62.6 | 0.0 | -2.2 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 84  | 0.0 | 500  | 62.6 | 0.0 | -2.4 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.6 | 0.0 | -2.4 | 0.0  | 1.4  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.6 | 0.0 | -2.4 | 0.0  | 3.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 3  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 76  | 0.0 | 125  | 63.1 | 0.0 | -1.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 9  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 250  | 63.1 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 84  | 0.0 | 500  | 63.1 | 0.0 | -2.7 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 83  | 0.0 | 1000 | 63.1 | 0.0 | -2.7 | 0.0  | 1.5  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 2000 | 63.1 | 0.0 | -2.7 | 0.0  | 3.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 3  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 70  | 0.0 | 125  | 58.3 | 0.0 | -1.0 | 7.5  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 79  | 0.0 | 500  | 58.3 | 0.0 | -2.2 | 12.3 | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 1  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 72  | 0.0 | 63   | 54.0 | 0.0 | -3.0 | 13.5 | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 54.0 | 0.0 | -1.5 | 15.9 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 12 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 54.0 | 0.0 | -2.2 | 19.2 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 14 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 54.0 | 0.0 | -2.3 | 22.2 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 18 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 54.0 | 0.0 | -2.3 | 24.2 | 0.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 18 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 54.0 | 0.0 | -2.3 | 25.5 | 1.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 14 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 54.0 | 0.0 | -2.3 | 26.3 | 4.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name    | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|----------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L01       | 15-Ton Pass-by | 17652675.5 | 4786882.7 | 1.5 | 0     | 52 | 3.3  | 125  | 53.5 | 0.0 | -2.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L01       | 15-Ton Pass-by | 17652675.5 | 4786882.7 | 1.5 | 0     | 57 | 3.3  | 250  | 53.5 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L01       | 15-Ton Pass-by | 17652675.5 | 4786882.7 | 1.5 | 0     | 63 | 3.3  | 500  | 53.5 | 0.0 | -2.5 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by | 17652675.5 | 4786882.7 | 1.5 | 0     | 63 | 3.3  | 1000 | 53.5 | 0.0 | -2.5 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652675.5 | 4786882.7 | 1.5 | 0     | 61 | 3.3  | 2000 | 53.5 | 0.0 | -2.5 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652675.5 | 4786882.7 | 1.5 | 0     | 55 | 3.3  | 4000 | 53.5 | 0.0 | -2.5 | 0.0  | 4.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by | 17652670.0 | 4786882.7 | 1.5 | 0     | 41 | 9.5  | 63   | 53.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L01       | 15-Ton Pass-by | 17652670.0 | 4786882.7 | 1.5 | 0     | 52 | 9.5  | 125  | 53.2 | 0.0 | -1.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652670.0 | 4786882.7 | 1.5 | 0     | 57 | 9.5  | 250  | 53.2 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652670.0 | 4786882.7 | 1.5 | 0     | 63 | 9.5  | 500  | 53.2 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652670.0 | 4786882.7 | 1.5 | 0     | 63 | 9.5  | 1000 | 53.2 | 0.0 | -2.5 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652670.0 | 4786882.7 | 1.5 | 0     | 61 | 9.5  | 2000 | 53.2 | 0.0 | -2.5 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652670.0 | 4786882.7 | 1.5 | 0     | 55 | 9.5  | 4000 | 53.2 | 0.0 | -2.5 | 0.0  | 4.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652655.1 | 4786882.7 | 1.5 | 0     | 41 | 13.2 | 63   | 52.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by | 17652655.1 | 4786882.7 | 1.5 | 0     | 52 | 13.2 | 125  | 52.3 | 0.0 | -1.9 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by | 17652655.1 | 4786882.7 | 1.5 | 0     | 57 | 13.2 | 250  | 52.3 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 20 |
| L01       | 15-Ton Pass-by | 17652655.1 | 4786882.7 | 1.5 | 0     | 63 | 13.2 | 500  | 52.3 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 26 |
| L01       | 15-Ton Pass-by | 17652655.1 | 4786882.7 | 1.5 | 0     | 63 | 13.2 | 1000 | 52.3 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 26 |
| L01       | 15-Ton Pass-by | 17652655.1 | 4786882.7 | 1.5 | 0     | 61 | 13.2 | 2000 | 52.3 | 0.0 | -2.5 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 23 |
| L01       | 15-Ton Pass-by | 17652655.1 | 4786882.7 | 1.5 | 0     | 55 | 13.2 | 4000 | 52.3 | 0.0 | -2.5 | 0.0  | 3.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 41 | 10.4 | 63   | 53.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 52 | 10.4 | 125  | 53.4 | 0.0 | -2.1 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 57 | 10.4 | 250  | 53.4 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 63 | 10.4 | 500  | 53.4 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 22 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 63 | 10.4 | 1000 | 53.4 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 22 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 61 | 10.4 | 2000 | 53.4 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L01       | 15-Ton Pass-by | 17652686.0 | 4786860.8 | 1.5 | 0     | 55 | 10.4 | 4000 | 53.4 | 0.0 | -2.6 | 0.0  | 4.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652678.9 | 4786877.9 | 1.5 | 0     | 41 | 10.3 | 63   | 53.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L01       | 15-Ton Pass-by | 17652678.9 | 4786877.9 | 1.5 | 0     | 52 | 10.3 | 125  | 53.5 | 0.0 | -2.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652678.9 | 4786877.9 | 1.5 | 0     | 57 | 10.3 | 250  | 53.5 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652678.9 | 4786877.9 | 1.5 | 0     | 63 | 10.3 | 500  | 53.5 | 0.0 | -2.5 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 22 |
| L01       | 15-Ton Pass-by | 17652678.9 | 4786877.9 | 1.5 | 0     | 63 | 10.3 | 1000 | 53.5 | 0.0 | -2.5 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652678.9 | 4786877.9 | 1.5 | 0     | 61 | 10.3 | 2000 | 53.5 | 0.0 | -2.5 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L01       | 15-Ton Pass-by | 17652678.9 | 4786877.9 | 1.5 | 0     | 55 | 10.3 | 4000 | 53.5 | 0.0 | -2.5 | 0.0  | 4.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652683.4 | 4786867.6 | 1.5 | 0     | 52 | 5.8  | 125  | 53.4 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652683.4 | 4786867.6 | 1.5 | 0     | 57 | 5.8  | 250  | 53.4 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652683.4 | 4786867.6 | 1.5 | 0     | 63 | 5.8  | 500  | 53.4 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652683.4 | 4786867.6 | 1.5 | 0     | 63 | 5.8  | 1000 | 53.4 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652683.4 | 4786867.6 | 1.5 | 0     | 61 | 5.8  | 2000 | 53.4 | 0.0 | -2.7 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652683.4 | 4786867.6 | 1.5 | 0     | 55 | 5.8  | 4000 | 53.4 | 0.0 | -2.7 | 0.0  | 4.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L01       | 15-Ton Pass-by | 17652682.0 | 4786871.3 | 1.5 | 0     | 52 | 6.1  | 125  | 53.4 | 0.0 | -2.2 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652682.0 | 4786871.3 | 1.5 | 0     | 57 | 6.1  | 250  | 53.4 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652682.0 | 4786871.3 | 1.5 | 0     | 63 | 6.1  | 500  | 53.4 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L01       | 15-Ton Pass-by   | 17652682.0 | 4786871.3 | 1.5 | 0     | 63 | 6.1  | 1000 | 53.4 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by   | 17652682.0 | 4786871.3 | 1.5 | 0     | 61 | 6.1  | 2000 | 53.4 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by   | 17652682.0 | 4786871.3 | 1.5 | 0     | 55 | 6.1  | 4000 | 53.4 | 0.0 | -2.6 | 0.0  | 4.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652648.9 | 4786967.2 | 1.5 | 0     | 52 | 15.8 | 125  | 56.1 | 0.0 | -2.7 | 7.5  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652648.9 | 4786967.2 | 1.5 | 0     | 57 | 15.8 | 250  | 56.1 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652648.9 | 4786967.2 | 1.5 | 0     | 63 | 15.8 | 500  | 56.1 | 0.0 | -2.9 | 7.8  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2 | 17652648.9 | 4786967.2 | 1.5 | 0     | 63 | 15.8 | 1000 | 56.1 | 0.0 | -2.9 | 7.9  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2 | 17652648.9 | 4786967.2 | 1.5 | 0     | 61 | 15.8 | 2000 | 56.1 | 0.0 | -2.9 | 8.1  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652648.9 | 4786967.2 | 1.5 | 0     | 55 | 15.8 | 4000 | 56.1 | 0.0 | -2.9 | 8.5  | 5.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652627.2 | 4786966.2 | 1.5 | 0     | 52 | 7.2  | 125  | 55.6 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652627.2 | 4786966.2 | 1.5 | 0     | 57 | 7.2  | 250  | 55.6 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652627.2 | 4786966.2 | 1.5 | 0     | 63 | 7.2  | 500  | 55.6 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2 | 17652627.2 | 4786966.2 | 1.5 | 0     | 63 | 7.2  | 1000 | 55.6 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652627.2 | 4786966.2 | 1.5 | 0     | 61 | 7.2  | 2000 | 55.6 | 0.0 | -2.9 | 0.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652627.2 | 4786966.2 | 1.5 | 0     | 55 | 7.2  | 4000 | 55.6 | 0.0 | -2.9 | 0.0  | 5.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 52 | 8.9  | 125  | 55.5 | 0.0 | -2.7 | 3.4  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 57 | 8.9  | 250  | 55.5 | 0.0 | -2.8 | 3.8  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 63 | 8.9  | 500  | 55.5 | 0.0 | -2.8 | 4.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 63 | 8.9  | 1000 | 55.5 | 0.0 | -2.8 | 5.2  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 61 | 8.9  | 2000 | 55.5 | 0.0 | -2.8 | 6.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652584.0 | 4786964.2 | 1.5 | 0     | 52 | 18.2 | 125  | 55.0 | 0.0 | -2.7 | 7.8  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652584.0 | 4786964.2 | 1.5 | 0     | 57 | 18.2 | 250  | 55.0 | 0.0 | -2.9 | 8.2  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652584.0 | 4786964.2 | 1.5 | 0     | 63 | 18.2 | 500  | 55.0 | 0.0 | -2.9 | 8.7  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 20 |
| L02       | 15-Ton Pass-by 2 | 17652584.0 | 4786964.2 | 1.5 | 0     | 63 | 18.2 | 1000 | 55.0 | 0.0 | -2.9 | 9.6  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652584.0 | 4786964.2 | 1.5 | 0     | 61 | 18.2 | 2000 | 55.0 | 0.0 | -2.9 | 10.9 | 1.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652584.0 | 4786964.2 | 1.5 | 0     | 55 | 18.2 | 4000 | 55.0 | 0.0 | -2.9 | 12.8 | 5.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652537.0 | 4786962.0 | 1.5 | 0     | 52 | 14.5 | 125  | 54.9 | 0.0 | -3.0 | 7.7  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652537.0 | 4786962.0 | 1.5 | 0     | 57 | 14.5 | 250  | 54.9 | 0.0 | -3.0 | 8.5  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652537.0 | 4786962.0 | 1.5 | 0     | 63 | 14.5 | 500  | 54.9 | 0.0 | -3.0 | 9.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652537.0 | 4786962.0 | 1.5 | 0     | 63 | 14.5 | 1000 | 54.9 | 0.0 | -3.0 | 10.7 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652537.0 | 4786962.0 | 1.5 | 0     | 61 | 14.5 | 2000 | 54.9 | 0.0 | -3.0 | 12.5 | 1.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652599.9 | 4787020.3 | 1.5 | 0     | 52 | 14.7 | 125  | 57.7 | 0.0 | -2.7 | 7.5  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652599.9 | 4787020.3 | 1.5 | 0     | 57 | 14.7 | 250  | 57.7 | 0.0 | -2.9 | 7.6  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652599.9 | 4787020.3 | 1.5 | 0     | 63 | 14.7 | 500  | 57.7 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652599.9 | 4787020.3 | 1.5 | 0     | 63 | 14.7 | 1000 | 57.7 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652599.9 | 4787020.3 | 1.5 | 0     | 61 | 14.7 | 2000 | 57.7 | 0.0 | -2.9 | 7.7  | 2.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652599.9 | 4787020.3 | 1.5 | 0     | 55 | 14.7 | 4000 | 57.7 | 0.0 | -2.9 | 7.7  | 7.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4787021.3 | 1.5 | 0     | 52 | 13.6 | 125  | 57.9 | 0.0 | -2.7 | 8.2  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4787021.3 | 1.5 | 0     | 57 | 13.6 | 250  | 57.9 | 0.0 | -2.9 | 8.9  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4787021.3 | 1.5 | 0     | 63 | 13.6 | 500  | 57.9 | 0.0 | -2.9 | 9.9  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4787021.3 | 1.5 | 0     | 63 | 13.6 | 1000 | 57.9 | 0.0 | -2.9 | 11.4 | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4787021.3 | 1.5 | 0     | 61 | 13.6 | 2000 | 57.9 | 0.0 | -2.9 | 13.4 | 2.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652641.3 | 4787021.8 | 1.5 | 0     | 57 | 8.8  | 250  | 58.1 | 0.0 | -2.9 | 8.9  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2 | 17652641.3 | 4787021.8 | 1.5 | 0     | 63 | 8.8  | 500  | 58.1 | 0.0 | -2.9 | 9.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652641.3 | 4787021.8 | 1.5 | 0     | 63 | 8.8  | 1000 | 58.1 | 0.0 | -2.9 | 11.4 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652648.7 | 4787022.1 | 1.5 | 0     | 57 | 8.6  | 250  | 58.2 | 0.0 | -2.9 | 8.9  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652648.7 | 4787022.1 | 1.5 | 0     | 63 | 8.6  | 500  | 58.2 | 0.0 | -2.9 | 9.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652648.7 | 4787022.1 | 1.5 | 0     | 63 | 8.6  | 1000 | 58.2 | 0.0 | -2.9 | 11.4 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652655.0 | 4787022.3 | 1.5 | 0     | 63 | 7.3  | 500  | 58.3 | 0.0 | -2.9 | 9.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652655.0 | 4787022.3 | 1.5 | 0     | 63 | 7.3  | 1000 | 58.3 | 0.0 | -2.9 | 11.3 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652673.4 | 4787023.0 | 1.5 | 0     | 52 | 15.0 | 125  | 58.6 | 0.0 | -2.8 | 8.2  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652673.4 | 4787023.0 | 1.5 | 0     | 57 | 15.0 | 250  | 58.6 | 0.0 | -2.9 | 8.9  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652673.4 | 4787023.0 | 1.5 | 0     | 63 | 15.0 | 500  | 58.6 | 0.0 | -2.9 | 9.8  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652673.4 | 4787023.0 | 1.5 | 0     | 63 | 15.0 | 1000 | 58.6 | 0.0 | -2.9 | 11.2 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652673.4 | 4787023.0 | 1.5 | 0     | 61 | 15.0 | 2000 | 58.6 | 0.0 | -2.9 | 13.2 | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652692.7 | 4787009.8 | 1.5 | 0     | 57 | 10.2 | 250  | 58.6 | 0.0 | -2.9 | 7.8  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652692.7 | 4787009.8 | 1.5 | 0     | 63 | 10.2 | 500  | 58.6 | 0.0 | -2.9 | 8.6  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652692.7 | 4787009.8 | 1.5 | 0     | 63 | 10.2 | 1000 | 58.6 | 0.0 | -2.9 | 9.7  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652692.7 | 4787009.8 | 1.5 | 0     | 61 | 10.2 | 2000 | 58.6 | 0.0 | -2.9 | 11.1 | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652692.0 | 4786998.7 | 1.5 | 0     | 52 | 10.7 | 125  | 58.2 | 0.0 | -2.7 | 6.3  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652692.0 | 4786998.7 | 1.5 | 0     | 57 | 10.7 | 250  | 58.2 | 0.0 | -2.9 | 7.4  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652692.0 | 4786998.7 | 1.5 | 0     | 63 | 10.7 | 500  | 58.2 | 0.0 | -2.9 | 8.6  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652692.0 | 4786998.7 | 1.5 | 0     | 63 | 10.7 | 1000 | 58.2 | 0.0 | -2.9 | 10.0 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652692.0 | 4786998.7 | 1.5 | 0     | 61 | 10.7 | 2000 | 58.2 | 0.0 | -2.9 | 11.9 | 2.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652691.3 | 4786987.2 | 1.5 | 0     | 52 | 10.6 | 125  | 57.8 | 0.0 | -2.7 | 3.6  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652691.3 | 4786987.2 | 1.5 | 0     | 57 | 10.6 | 250  | 57.8 | 0.0 | -2.9 | 4.2  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652691.3 | 4786987.2 | 1.5 | 0     | 63 | 10.6 | 500  | 57.8 | 0.0 | -2.9 | 4.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652691.3 | 4786987.2 | 1.5 | 0     | 63 | 10.6 | 1000 | 57.8 | 0.0 | -2.9 | 5.6  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652691.3 | 4786987.2 | 1.5 | 0     | 61 | 10.6 | 2000 | 57.8 | 0.0 | -2.9 | 6.4  | 2.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786979.1 | 1.5 | 0     | 57 | 6.9  | 250  | 57.5 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786979.1 | 1.5 | 0     | 63 | 6.9  | 500  | 57.5 | 0.0 | -2.9 | 7.8  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786979.1 | 1.5 | 0     | 63 | 6.9  | 1000 | 57.5 | 0.0 | -2.9 | 8.0  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786979.1 | 1.5 | 0     | 61 | 6.9  | 2000 | 57.5 | 0.0 | -2.9 | 8.2  | 2.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 52 | 15.0 | 125  | 58.1 | 0.0 | -2.8 | 7.6  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 57 | 15.0 | 250  | 58.1 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 63 | 15.0 | 500  | 58.1 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 63 | 15.0 | 1000 | 58.1 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652576.5 | 4787033.0 | 1.5 | 0     | 61 | 15.0 | 2000 | 58.1 | 0.0 | -2.9 | 7.7  | 2.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652688.4 | 4786975.7 | 1.5 | 0     | 57 | 6.7  | 250  | 57.4 | 0.0 | -2.9 | 7.8  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652688.4 | 4786975.7 | 1.5 | 0     | 63 | 6.7  | 500  | 57.4 | 0.0 | -2.9 | 7.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652688.4 | 4786975.7 | 1.5 | 0     | 63 | 6.7  | 1000 | 57.4 | 0.0 | -2.9 | 8.2  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652688.4 | 4786975.7 | 1.5 | 0     | 61 | 6.7  | 2000 | 57.4 | 0.0 | -2.9 | 8.6  | 2.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652677.0 | 4786971.5 | 1.5 | 0     | 52 | 12.9 | 125  | 56.9 | 0.0 | -2.7 | 4.4  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652677.0 | 4786971.5 | 1.5 | 0     | 57 | 12.9 | 250  | 56.9 | 0.0 | -2.9 | 5.2  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652677.0 | 4786971.5 | 1.5 | 0     | 63 | 12.9 | 500  | 56.9 | 0.0 | -2.9 | 6.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652677.0 | 4786971.5 | 1.5 | 0     | 63 | 12.9 | 1000 | 56.9 | 0.0 | -2.9 | 6.7  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc  | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 61 | 12.9 | 2000 | 56.9 | 0.0 | -2.9 | 7.1  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2              | 17652677.0 | 4786971.5 | 1.5 | 0     | 55 | 12.9 | 4000 | 56.9 | 0.0 | -2.9 | 7.4  | 6.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 57 | 9.7  | 250  | 58.8 | 0.0 | -2.9 | 8.1  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 63 | 9.7  | 500  | 58.8 | 0.0 | -2.9 | 8.9  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 63 | 9.7  | 1000 | 58.8 | 0.0 | -2.9 | 9.9  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2              | 17652691.1 | 4787019.3 | 1.5 | 0     | 61 | 9.7  | 2000 | 58.8 | 0.0 | -2.9 | 11.5 | 2.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 60 | 0.0  | 32   | 51.8 | 0.0 | -3.0 | 3.4  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 71 | 0.0  | 63   | 51.8 | 0.0 | -3.0 | 3.8  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 51.8 | 0.0 | -1.9 | 3.8  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 24 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 51.8 | 0.0 | -2.4 | 4.9  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 30 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 51.8 | 0.0 | -2.5 | 6.1  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 34 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 51.8 | 0.0 | -2.5 | 7.6  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 35 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 51.8 | 0.0 | -2.5 | 9.5  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 30 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 89 | 0.0  | 4000 | 51.8 | 0.0 | -2.5 | 11.7 | 3.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 18 |
| L03       | 5-Ton Pass-by                 | 17652675.5 | 4786882.7 | 1.5 | 0     | 50 | 3.3  | 1000 | 53.5 | 0.0 | -2.5 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652670.0 | 4786882.7 | 1.5 | 0     | 47 | 9.5  | 500  | 53.2 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652670.0 | 4786882.7 | 1.5 | 0     | 50 | 9.5  | 1000 | 53.2 | 0.0 | -2.5 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L03       | 5-Ton Pass-by                 | 17652670.0 | 4786882.7 | 1.5 | 0     | 47 | 9.5  | 2000 | 53.2 | 0.0 | -2.5 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652655.1 | 4786882.7 | 1.5 | 0     | 41 | 13.2 | 250  | 52.3 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L03       | 5-Ton Pass-by                 | 17652655.1 | 4786882.7 | 1.5 | 0     | 47 | 13.2 | 500  | 52.3 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L03       | 5-Ton Pass-by                 | 17652655.1 | 4786882.7 | 1.5 | 0     | 50 | 13.2 | 1000 | 52.3 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L03       | 5-Ton Pass-by                 | 17652655.1 | 4786882.7 | 1.5 | 0     | 47 | 13.2 | 2000 | 52.3 | 0.0 | -2.5 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L03       | 5-Ton Pass-by                 | 17652655.1 | 4786882.7 | 1.5 | 0     | 44 | 13.2 | 4000 | 52.3 | 0.0 | -2.5 | 0.0  | 3.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 47 | 10.4 | 500  | 53.4 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 50 | 10.4 | 1000 | 53.4 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L03       | 5-Ton Pass-by                 | 17652686.0 | 4786860.8 | 1.5 | 0     | 47 | 10.4 | 2000 | 53.4 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652678.9 | 4786877.9 | 1.5 | 0     | 47 | 10.3 | 500  | 53.5 | 0.0 | -2.5 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L03       | 5-Ton Pass-by                 | 17652678.9 | 4786877.9 | 1.5 | 0     | 50 | 10.3 | 1000 | 53.5 | 0.0 | -2.5 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L03       | 5-Ton Pass-by                 | 17652678.9 | 4786877.9 | 1.5 | 0     | 47 | 10.3 | 2000 | 53.5 | 0.0 | -2.5 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652683.4 | 4786867.6 | 1.5 | 0     | 47 | 5.8  | 500  | 53.4 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652683.4 | 4786867.6 | 1.5 | 0     | 50 | 5.8  | 1000 | 53.4 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652683.4 | 4786867.6 | 1.5 | 0     | 47 | 5.8  | 2000 | 53.4 | 0.0 | -2.7 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by                 | 17652682.0 | 4786871.3 | 1.5 | 0     | 47 | 6.1  | 500  | 53.4 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652682.0 | 4786871.3 | 1.5 | 0     | 50 | 6.1  | 1000 | 53.4 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652682.0 | 4786871.3 | 1.5 | 0     | 47 | 6.1  | 2000 | 53.4 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2               | 17652648.9 | 4786967.2 | 1.5 | 0     | 52 | 15.8 | 500  | 56.1 | 0.0 | -2.9 | 7.8  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652648.9 | 4786967.2 | 1.5 | 0     | 55 | 15.8 | 1000 | 56.1 | 0.0 | -2.9 | 7.9  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L04       | 5-Ton Pass-by 2               | 17652648.9 | 4786967.2 | 1.5 | 0     | 52 | 15.8 | 2000 | 56.1 | 0.0 | -2.9 | 8.1  | 1.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652627.2 | 4786966.2 | 1.5 | 0     | 52 | 7.2  | 500  | 55.6 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652627.2 | 4786966.2 | 1.5 | 0     | 55 | 7.2  | 1000 | 55.6 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L04       | 5-Ton Pass-by 2               | 17652627.2 | 4786966.2 | 1.5 | 0     | 52 | 7.2  | 2000 | 55.6 | 0.0 | -2.9 | 0.0  | 1.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652620.7 | 4786965.9 | 1.5 | 0     | 52 | 8.9  | 500  | 55.5 | 0.0 | -2.8 | 4.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652620.7 | 4786965.9 | 1.5 | 0     | 55 | 8.9  | 1000 | 55.5 | 0.0 | -2.8 | 5.2  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name          | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc    | RL  | Lr |
|-----------|----------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| L04       | 5-Ton Pass-by 2      | 17652620.7 | 4786965.9 | 1.5 | 0     | 52 | 8.9  | 2000 | 55.5 | 0.0 | -2.8 | 6.0  | 1.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652584.0 | 4786964.2 | 1.5 | 0     | 45 | 18.2 | 250  | 55.0 | 0.0 | -2.9 | 8.2  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2      | 17652584.0 | 4786964.2 | 1.5 | 0     | 52 | 18.2 | 500  | 55.0 | 0.0 | -2.9 | 8.7  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| L04       | 5-Ton Pass-by 2      | 17652584.0 | 4786964.2 | 1.5 | 0     | 55 | 18.2 | 1000 | 55.0 | 0.0 | -2.9 | 9.6  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| L04       | 5-Ton Pass-by 2      | 17652584.0 | 4786964.2 | 1.5 | 0     | 52 | 18.2 | 2000 | 55.0 | 0.0 | -2.9 | 10.9 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2      | 17652537.0 | 4786962.0 | 1.5 | 0     | 52 | 14.5 | 500  | 54.9 | 0.0 | -3.0 | 9.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2      | 17652537.0 | 4786962.0 | 1.5 | 0     | 55 | 14.5 | 1000 | 54.9 | 0.0 | -3.0 | 10.7 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652537.0 | 4786962.0 | 1.5 | 0     | 52 | 14.5 | 2000 | 54.9 | 0.0 | -3.0 | 12.5 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652599.9 | 4787020.3 | 1.5 | 0     | 52 | 14.7 | 500  | 57.7 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2      | 17652599.9 | 4787020.3 | 1.5 | 0     | 55 | 14.7 | 1000 | 57.7 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652599.9 | 4787020.3 | 1.5 | 0     | 52 | 14.7 | 2000 | 57.7 | 0.0 | -2.9 | 7.7  | 2.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652626.2 | 4787021.3 | 1.5 | 0     | 55 | 13.6 | 1000 | 57.9 | 0.0 | -2.9 | 11.4 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2      | 17652673.4 | 4787023.0 | 1.5 | 0     | 52 | 15.0 | 500  | 58.6 | 0.0 | -2.9 | 9.8  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652673.4 | 4787023.0 | 1.5 | 0     | 55 | 15.0 | 1000 | 58.6 | 0.0 | -2.9 | 11.2 | 0.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652691.3 | 4786987.2 | 1.5 | 0     | 52 | 10.6 | 500  | 57.8 | 0.0 | -2.9 | 4.9  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652691.3 | 4786987.2 | 1.5 | 0     | 55 | 10.6 | 1000 | 57.8 | 0.0 | -2.9 | 5.6  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2      | 17652576.5 | 4787033.0 | 1.5 | 0     | 52 | 15.0 | 500  | 58.1 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2      | 17652576.5 | 4787033.0 | 1.5 | 0     | 55 | 15.0 | 1000 | 58.1 | 0.0 | -2.9 | 7.7  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652576.5 | 4787033.0 | 1.5 | 0     | 52 | 15.0 | 2000 | 58.1 | 0.0 | -2.9 | 7.7  | 2.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652677.0 | 4786971.5 | 1.5 | 0     | 52 | 12.9 | 500  | 56.9 | 0.0 | -2.9 | 6.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2      | 17652677.0 | 4786971.5 | 1.5 | 0     | 55 | 12.9 | 1000 | 56.9 | 0.0 | -2.9 | 6.7  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652677.0 | 4786971.5 | 1.5 | 0     | 52 | 12.9 | 2000 | 56.9 | 0.0 | -2.9 | 7.1  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 59 | 0.0  | 32   | 53.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 67 | 0.0  | 63   | 53.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 53.1 | 0.0 | -2.2 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 23 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 53.1 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 28 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 53.1 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 34 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 53.1 | 0.0 | -2.6 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 35 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 53.1 | 0.0 | -2.6 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 32 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 4000 | 53.1 | 0.0 | -2.6 | 0.0  | 4.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 24 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 81 | 0.0  | 8000 | 53.1 | 0.0 | -2.6 | 0.0  | 14.9 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 57 | 0.0  | 32   | 51.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 68 | 0.0  | 63   | 51.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 14 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 51.5 | 0.0 | -2.4 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 26 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0  | 250  | 51.5 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 35 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 500  | 51.5 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 42 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 1000 | 51.5 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 41 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 51.5 | 0.0 | -2.7 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 40 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0  | 4000 | 51.5 | 0.0 | -2.7 | 0.0  | 3.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 34 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 85 | 0.0  | 8000 | 51.5 | 0.0 | -2.7 | 0.0  | 12.3 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 17 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0  | 125  | 50.0 | 0.0 | -1.6 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 23 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0  | 250  | 50.0 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 22 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0  | 500  | 50.0 | 0.0 | -2.4 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 26 |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 50.0 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 24 |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0 | 2000 | 50.0 | 0.0 | -2.4 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 19 |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 73 | 0.0 | 4000 | 50.0 | 0.0 | -2.4 | 0.0  | 2.9  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 10 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 50.3 | 0.0 | -1.6 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 22 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 250  | 50.3 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 22 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0 | 500  | 50.3 | 0.0 | -2.4 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 26 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 50.3 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 24 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 50.3 | 0.0 | -2.4 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 18 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 73 | 0.0 | 4000 | 50.3 | 0.0 | -2.4 | 0.0  | 3.0  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 9  |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0 | 63   | 56.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 12 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0 | 125  | 56.7 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 21 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0 | 250  | 56.7 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 22 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0 | 500  | 56.7 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 23 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 56.7 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 24 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 56.7 | 0.0 | -3.0 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 18 |
| S15       | HVAC RTU    | 17652538.8 | 4786997.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 56.7 | 0.0 | -3.0 | 0.0  | 6.3  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 5  |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 67 | 0.0 | 63   | 57.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 12 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 57.3 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 20 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 57.3 | 0.0 | -2.8 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 21 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 87 | 0.0 | 500  | 57.3 | 0.0 | -2.8 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 22 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.3 | 0.0 | -2.8 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 23 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.3 | 0.0 | -2.8 | 0.0  | 2.0  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 17 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.3 | 0.0 | -2.8 | 0.0  | 6.8  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 4  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 61 | 0.0 | 125  | 56.8 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 2  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 72 | 0.0 | 250  | 56.8 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 10 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 84 | 0.0 | 500  | 56.8 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 56.8 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 24 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 87 | 0.0 | 2000 | 56.8 | 0.0 | -3.0 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 20 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 81 | 0.0 | 4000 | 56.8 | 0.0 | -3.0 | 0.0  | 6.4  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 8  |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 67 | 0.0 | 63   | 57.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 11 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 57.7 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 20 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 57.7 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 20 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 87 | 0.0 | 500  | 57.7 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 22 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.7 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.7 | 0.0 | -2.9 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 16 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.7 | 0.0 | -2.9 | 0.0  | 7.1  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 3  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 67 | 0.0 | 63   | 57.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 11 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 57.8 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 19 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 57.8 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 20 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 87 | 0.0 | 500  | 57.8 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 21 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.8 | 0.0 | -2.7 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.8 | 0.0 | -2.7 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 16 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.8 | 0.0 | -2.7 | 0.0  | 7.1  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 3  |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 67 | 0.0 | 63   | 57.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 11 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 57.8 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 20 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 57.8 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 20 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 87 | 0.0 | 500  | 57.8 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 22 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 57.8 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 57.8 | 0.0 | -2.9 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 16 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 78 | 0.0 | 4000 | 57.8 | 0.0 | -2.9 | 0.0  | 7.2  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 3  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 67 | 0.0 | 63   | 59.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 10 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 59.0 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 59.0 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 19 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 87 | 0.0 | 500  | 59.0 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.0 | 0.0 | -2.7 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 21 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.0 | 0.0 | -2.7 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 78 | 0.0 | 4000 | 59.0 | 0.0 | -2.7 | 0.0  | 8.3  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 0  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 61 | 0.0 | 125  | 58.3 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 72 | 0.0 | 250  | 58.3 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 8  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 84 | 0.0 | 500  | 58.3 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 18 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.3 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 22 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 87 | 0.0 | 2000 | 58.3 | 0.0 | -2.9 | 0.0  | 2.2  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 18 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 81 | 0.0 | 4000 | 58.3 | 0.0 | -2.9 | 0.0  | 7.6  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 5  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.5 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.5 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.5 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.5 | 0.0 | -2.7 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.5 | 0.0 | -2.7 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 67 | 0.0 | 63   | 59.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 59.6 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 59.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 87 | 0.0 | 500  | 59.6 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.6 | 0.0 | -2.7 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.6 | 0.0 | -2.7 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 65 | 0.0 | 63   | 59.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 8  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 59.0 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 16 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 83 | 0.0 | 250  | 59.0 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 500  | 59.0 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 20 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 1000 | 59.0 | 0.0 | -2.7 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.0 | 0.0 | -2.7 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 15 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 81 | 0.0 | 4000 | 59.0 | 0.0 | -2.7 | 0.0  | 8.2  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 4  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 67 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 59.9 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 17 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 59.9 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 87 | 0.0 | 500  | 59.9 | 0.0 | -2.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.9 | 0.0 | -2.7 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.9 | 0.0 | -2.7 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 13 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 67 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 59.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 87 | 0.0 | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 67 | 0.0 | 63   | 60.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 60.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 67 | 0.0 | 63   | 60.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 60.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 67 | 0.0 | 63   | 60.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 60.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 18 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 14 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 72 | 0.0 | 250  | 59.8 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 6  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 84 | 0.0 | 500  | 59.8 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 17 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.8 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 20 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 87 | 0.0 | 2000 | 59.8 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 16 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 81 | 0.0 | 4000 | 59.8 | 0.0 | -3.0 | 0.0  | 9.0  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 2  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 62 | 0.0 | 63   | 56.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 7  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 56.6 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 16 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 56.6 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 18 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 83 | 0.0 | 500  | 56.6 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 82 | 0.0 | 1000 | 56.6 | 0.0 | -3.0 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 17 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 2000 | 56.6 | 0.0 | -3.0 | 0.0  | 1.8  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 13 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 77 | 0.0 | 4000 | 56.6 | 0.0 | -3.0 | 0.0  | 6.2  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 4  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 61 | 0.0 | 63   | 56.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 6  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 74 | 0.0 | 125  | 56.7 | 0.0 | 2.0  | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 10 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 79 | 0.0 | 250  | 56.7 | 0.0 | -0.3 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 14 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 83 | 0.0 | 500  | 56.7 | 0.0 | -0.4 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 16 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 82 | 0.0 | 1000 | 56.7 | 0.0 | -0.4 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 14 |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 81 | 0.0 | 2000 | 56.7 | 0.0 | -0.4 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 11 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 78 | 0.0 | 4000 | 56.7 | 0.0 | -0.4 | 0.0  | 6.3  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 2  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 57.0 | 0.0 | -2.2 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 16 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 250  | 57.0 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 16 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 84 | 0.0 | 500  | 57.0 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 57.0 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 17 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 2000 | 57.0 | 0.0 | -2.7 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 11 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 61 | 0.0 | 63   | 57.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 5  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 74 | 0.0 | 125  | 57.7 | 0.0 | 1.5  | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 10 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 79 | 0.0 | 250  | 57.7 | 0.0 | -0.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 83 | 0.0 | 500  | 57.7 | 0.0 | -0.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 82 | 0.0 | 1000 | 57.7 | 0.0 | -0.7 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 13 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 81 | 0.0 | 2000 | 57.7 | 0.0 | -0.7 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 10 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 78 | 0.0 | 4000 | 57.7 | 0.0 | -0.7 | 0.0  | 7.1  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 1  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 57.9 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 16 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 250  | 57.9 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 15 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 84 | 0.0 | 500  | 57.9 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 57.9 | 0.0 | -2.9 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 16 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 57.9 | 0.0 | -2.9 | 0.0  | 2.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 10 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 61 | 0.0 | 63   | 59.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 4  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 74 | 0.0 | 125  | 59.1 | 0.0 | 1.5  | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 8  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 79 | 0.0 | 250  | 59.1 | 0.0 | -0.6 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 12 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 83 | 0.0 | 500  | 59.1 | 0.0 | -0.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 82 | 0.0 | 1000 | 59.1 | 0.0 | -0.7 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 12 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 81 | 0.0 | 2000 | 59.1 | 0.0 | -0.7 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 76 | 0.0 | 125  | 59.7 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 79 | 0.0 | 250  | 59.7 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 84 | 0.0 | 500  | 59.7 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 17 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 83 | 0.0 | 1000 | 59.7 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 14 |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 79 | 0.0 | 2000 | 59.7 | 0.0 | -3.0 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 61 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 3  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 74 | 0.0 | 125  | 59.9 | 0.0 | 1.5  | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 7  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 79 | 0.0 | 250  | 59.9 | 0.0 | -0.6 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 11 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 83 | 0.0 | 500  | 59.9 | 0.0 | -0.7 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 13 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 82 | 0.0 | 1000 | 59.9 | 0.0 | -0.7 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 81 | 0.0 | 2000 | 59.9 | 0.0 | -0.7 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 7  |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 76 | 0.0 | 125  | 60.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 79 | 0.0 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 84 | 0.0 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 16 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 83 | 0.0 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 14 |
| S23       | HVAC RTU    | 17652540.9 | 4787089.3 | 5.5 | 0     | 79 | 0.0 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 7  |
| S22       | HVAC RTU    | 17652529.8 | 4787088.9 | 5.5 | 0     | 76 | 0.0 | 125  | 60.1 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 14 |
| S22       | HVAC RTU    | 17652529.8 | 4787088.9 | 5.5 | 0     | 79 | 0.0 | 250  | 60.1 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 13 |



Receiver: RP07

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 50          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP07          | RP07        | 17652566.00 m | 4786807.33 m | 7.00 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 84  | 0.0 | 500  | 60.1 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 16 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 83  | 0.0 | 1000 | 60.1 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 14 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 2000 | 60.1 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 7  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 62  | 0.0 | 63   | 57.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 7  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 70  | 0.0 | 125  | 57.0 | 0.0 | -1.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 10 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 72  | 0.0 | 250  | 57.0 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 8  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 79  | 0.0 | 500  | 57.0 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 76  | 0.0 | 1000 | 57.0 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 10 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 75  | 0.0 | 2000 | 57.0 | 0.0 | -2.6 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 6  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 74  | 0.0 | 4000 | 57.0 | 0.0 | -2.6 | 0.0  | 6.6  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 0  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 61  | 0.0 | 32   | 51.9 | 0.0 | -3.0 | 3.2  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 3  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 72  | 0.0 | 63   | 51.9 | 0.0 | -3.0 | 3.3  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 14 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 51.9 | 0.0 | -1.9 | 3.1  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 27 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 51.9 | 0.0 | -2.4 | 3.8  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 32 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 51.9 | 0.0 | -2.5 | 4.6  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 38 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 51.9 | 0.0 | -2.5 | 5.8  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 39 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 51.9 | 0.0 | -2.5 | 7.4  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 35 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 51.9 | 0.0 | -2.5 | 9.5  | 3.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 25 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 85  | 0.0 | 8000 | 51.9 | 0.0 | -2.5 | 11.9 | 12.9 | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L01       | 15-Ton Pass-by   | 17652673.2 | 4786882.7 | 1.5 | 0     | 57 | 8.4  | 250  | 56.1 | 0.0 | -2.7 | 11.6 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L01       | 15-Ton Pass-by   | 17652673.2 | 4786882.7 | 1.5 | 0     | 63 | 8.4  | 500  | 56.1 | 0.0 | -2.7 | 14.6 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by   | 17652657.2 | 4786882.7 | 1.5 | 0     | 52 | 14.0 | 125  | 55.4 | 0.0 | -2.8 | 8.5  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by   | 17652657.2 | 4786882.7 | 1.5 | 0     | 57 | 14.0 | 250  | 55.4 | 0.0 | -2.8 | 11.1 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by   | 17652657.2 | 4786882.7 | 1.5 | 0     | 63 | 14.0 | 500  | 55.4 | 0.0 | -2.8 | 13.9 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by   | 17652657.2 | 4786882.7 | 1.5 | 0     | 63 | 14.0 | 1000 | 55.4 | 0.0 | -2.8 | 16.8 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by   | 17652657.2 | 4786882.7 | 1.5 | 0     | 61 | 14.0 | 2000 | 55.4 | 0.0 | -2.8 | 19.6 | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L01       | 15-Ton Pass-by   | 17652686.0 | 4786860.8 | 1.5 | 0     | 63 | 10.4 | 500  | 56.1 | 0.0 | -2.7 | 19.3 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L01       | 15-Ton Pass-by   | 17652678.4 | 4786879.0 | 1.5 | 0     | 63 | 8.2  | 500  | 56.2 | 0.0 | -2.7 | 14.9 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652661.5 | 4786967.8 | 1.5 | 0     | 57 | 11.1 | 250  | 58.2 | 0.0 | -2.9 | 10.8 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652661.5 | 4786967.8 | 1.5 | 0     | 63 | 11.1 | 500  | 58.2 | 0.0 | -2.9 | 13.7 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652661.5 | 4786967.8 | 1.5 | 0     | 63 | 11.1 | 1000 | 58.2 | 0.0 | -2.9 | 16.9 | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652648.5 | 4786967.2 | 1.5 | 0     | 52 | 11.2 | 125  | 57.9 | 0.0 | -3.0 | 8.1  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652648.5 | 4786967.2 | 1.5 | 0     | 57 | 11.2 | 250  | 57.9 | 0.0 | -3.0 | 10.5 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652648.5 | 4786967.2 | 1.5 | 0     | 63 | 11.2 | 500  | 57.9 | 0.0 | -3.0 | 13.3 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652648.5 | 4786967.2 | 1.5 | 0     | 63 | 11.2 | 1000 | 57.9 | 0.0 | -3.0 | 16.5 | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652641.1 | 4786966.9 | 1.5 | 0     | 63 | 2.3  | 500  | 57.7 | 0.0 | -3.0 | 9.1  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652634.1 | 4786966.5 | 1.5 | 0     | 52 | 10.9 | 125  | 57.5 | 0.0 | -3.0 | 4.4  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652634.1 | 4786966.5 | 1.5 | 0     | 57 | 10.9 | 250  | 57.5 | 0.0 | -3.0 | 5.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652634.1 | 4786966.5 | 1.5 | 0     | 63 | 10.9 | 500  | 57.5 | 0.0 | -3.0 | 5.9  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652634.1 | 4786966.5 | 1.5 | 0     | 63 | 10.9 | 1000 | 57.5 | 0.0 | -3.0 | 7.0  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652634.1 | 4786966.5 | 1.5 | 0     | 61 | 10.9 | 2000 | 57.5 | 0.0 | -3.0 | 8.7  | 2.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652618.4 | 4786965.8 | 1.5 | 0     | 52 | 12.8 | 125  | 57.1 | 0.0 | -3.0 | 8.1  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652618.4 | 4786965.8 | 1.5 | 0     | 57 | 12.8 | 250  | 57.1 | 0.0 | -3.0 | 10.4 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652618.4 | 4786965.8 | 1.5 | 0     | 63 | 12.8 | 500  | 57.1 | 0.0 | -3.0 | 13.0 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652618.4 | 4786965.8 | 1.5 | 0     | 63 | 12.8 | 1000 | 57.1 | 0.0 | -3.0 | 15.9 | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652594.2 | 4786964.7 | 1.5 | 0     | 52 | 14.7 | 125  | 56.6 | 0.0 | -3.0 | 7.8  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652594.2 | 4786964.7 | 1.5 | 0     | 57 | 14.7 | 250  | 56.6 | 0.0 | -3.0 | 7.8  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652594.2 | 4786964.7 | 1.5 | 0     | 63 | 14.7 | 500  | 56.6 | 0.0 | -3.0 | 7.9  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652594.2 | 4786964.7 | 1.5 | 0     | 63 | 14.7 | 1000 | 56.6 | 0.0 | -3.0 | 8.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652594.2 | 4786964.7 | 1.5 | 0     | 61 | 14.7 | 2000 | 56.6 | 0.0 | -3.0 | 8.2  | 1.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652594.2 | 4786964.7 | 1.5 | 0     | 55 | 14.7 | 4000 | 56.6 | 0.0 | -3.0 | 8.6  | 6.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652564.3 | 4786963.3 | 1.5 | 0     | 52 | 14.8 | 125  | 56.1 | 0.0 | -2.8 | 7.6  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652564.3 | 4786963.3 | 1.5 | 0     | 57 | 14.8 | 250  | 56.1 | 0.0 | -2.8 | 7.7  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652564.3 | 4786963.3 | 1.5 | 0     | 63 | 14.8 | 500  | 56.1 | 0.0 | -2.8 | 7.8  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652564.3 | 4786963.3 | 1.5 | 0     | 63 | 14.8 | 1000 | 56.1 | 0.0 | -2.8 | 8.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652564.3 | 4786963.3 | 1.5 | 0     | 61 | 14.8 | 2000 | 56.1 | 0.0 | -2.8 | 8.5  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652564.3 | 4786963.3 | 1.5 | 0     | 55 | 14.8 | 4000 | 56.1 | 0.0 | -2.8 | 9.3  | 5.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652540.1 | 4786962.1 | 1.5 | 0     | 52 | 12.5 | 125  | 55.9 | 0.0 | -2.5 | 6.1  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652540.1 | 4786962.1 | 1.5 | 0     | 57 | 12.5 | 250  | 55.9 | 0.0 | -2.5 | 6.8  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652540.1 | 4786962.1 | 1.5 | 0     | 63 | 12.5 | 500  | 55.9 | 0.0 | -2.5 | 7.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652540.1 | 4786962.1 | 1.5 | 0     | 63 | 12.5 | 1000 | 55.9 | 0.0 | -2.5 | 8.1  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652540.1 | 4786962.1 | 1.5 | 0     | 61 | 12.5 | 2000 | 55.9 | 0.0 | -2.5 | 9.1  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2 | 17652527.0 | 4786961.5 | 1.5 | 0     | 52 | 9.2  | 125  | 55.8 | 0.0 | -2.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652527.0 | 4786961.5 | 1.5 | 0     | 57 | 9.2  | 250  | 55.8 | 0.0 | -2.4 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652527.0 | 4786961.5 | 1.5 | 0     | 63 | 9.2  | 500  | 55.8 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652527.0 | 4786961.5 | 1.5 | 0     | 63 | 9.2  | 1000 | 55.8 | 0.0 | -2.4 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652527.0 | 4786961.5 | 1.5 | 0     | 61 | 9.2  | 2000 | 55.8 | 0.0 | -2.4 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652527.0 | 4786961.5 | 1.5 | 0     | 55 | 9.2  | 4000 | 55.8 | 0.0 | -2.4 | 0.0  | 5.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652591.6 | 4787020.0 | 1.5 | 0     | 52 | 11.2 | 125  | 58.7 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652591.6 | 4787020.0 | 1.5 | 0     | 57 | 11.2 | 250  | 58.7 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652591.6 | 4787020.0 | 1.5 | 0     | 63 | 11.2 | 500  | 58.7 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652591.6 | 4787020.0 | 1.5 | 0     | 63 | 11.2 | 1000 | 58.7 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2 | 17652591.6 | 4787020.0 | 1.5 | 0     | 61 | 11.2 | 2000 | 58.7 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652591.6 | 4787020.0 | 1.5 | 0     | 55 | 11.2 | 4000 | 58.7 | 0.0 | -2.9 | 0.0  | 8.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652607.9 | 4787020.6 | 1.5 | 0     | 52 | 12.9 | 125  | 58.9 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652607.9 | 4787020.6 | 1.5 | 0     | 57 | 12.9 | 250  | 58.9 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652607.9 | 4787020.6 | 1.5 | 0     | 63 | 12.9 | 500  | 58.9 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652607.9 | 4787020.6 | 1.5 | 0     | 63 | 12.9 | 1000 | 58.9 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652607.9 | 4787020.6 | 1.5 | 0     | 61 | 12.9 | 2000 | 58.9 | 0.0 | -2.9 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652607.9 | 4787020.6 | 1.5 | 0     | 55 | 12.9 | 4000 | 58.9 | 0.0 | -2.9 | 0.0  | 8.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652627.3 | 4787021.3 | 1.5 | 0     | 52 | 12.8 | 125  | 59.2 | 0.0 | -3.0 | 6.5  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652627.3 | 4787021.3 | 1.5 | 0     | 57 | 12.8 | 250  | 59.2 | 0.0 | -3.0 | 7.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652627.3 | 4787021.3 | 1.5 | 0     | 63 | 12.8 | 500  | 59.2 | 0.0 | -3.0 | 8.3  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652627.3 | 4787021.3 | 1.5 | 0     | 63 | 12.8 | 1000 | 59.2 | 0.0 | -3.0 | 9.4  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652627.3 | 4787021.3 | 1.5 | 0     | 61 | 12.8 | 2000 | 59.2 | 0.0 | -3.0 | 10.9 | 2.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.2 | 1.5 | 0     | 52 | 11.3 | 125  | 59.3 | 0.0 | -2.9 | 5.8  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.2 | 1.5 | 0     | 57 | 11.3 | 250  | 59.3 | 0.0 | -2.9 | 7.3  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.2 | 1.5 | 0     | 63 | 11.3 | 500  | 59.3 | 0.0 | -2.9 | 9.4  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652691.1 | 4786983.2 | 1.5 | 0     | 63 | 11.3 | 1000 | 59.3 | 0.0 | -2.9 | 11.9 | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652570.0 | 4787043.0 | 1.5 | 0     | 57 | 8.7  | 250  | 59.3 | 0.0 | -2.8 | 7.5  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652570.0 | 4787043.0 | 1.5 | 0     | 63 | 8.7  | 500  | 59.3 | 0.0 | -2.8 | 7.5  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652570.0 | 4787043.0 | 1.5 | 0     | 63 | 8.7  | 1000 | 59.3 | 0.0 | -2.8 | 7.5  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652570.0 | 4787043.0 | 1.5 | 0     | 61 | 8.7  | 2000 | 59.3 | 0.0 | -2.8 | 7.5  | 2.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4787036.9 | 1.5 | 0     | 52 | 8.6  | 125  | 59.1 | 0.0 | -2.8 | 3.3  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4787036.9 | 1.5 | 0     | 57 | 8.6  | 250  | 59.1 | 0.0 | -2.8 | 3.6  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4787036.9 | 1.5 | 0     | 63 | 8.6  | 500  | 59.1 | 0.0 | -2.8 | 4.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4787036.9 | 1.5 | 0     | 63 | 8.6  | 1000 | 59.1 | 0.0 | -2.8 | 4.7  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4787036.9 | 1.5 | 0     | 61 | 8.6  | 2000 | 59.1 | 0.0 | -2.8 | 5.5  | 2.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652580.4 | 4787026.8 | 1.5 | 0     | 52 | 12.2 | 125  | 58.8 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652580.4 | 4787026.8 | 1.5 | 0     | 57 | 12.2 | 250  | 58.8 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652580.4 | 4787026.8 | 1.5 | 0     | 63 | 12.2 | 500  | 58.8 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652580.4 | 4787026.8 | 1.5 | 0     | 63 | 12.2 | 1000 | 58.8 | 0.0 | -2.8 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652580.4 | 4787026.8 | 1.5 | 0     | 61 | 12.2 | 2000 | 58.8 | 0.0 | -2.8 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652580.4 | 4787026.8 | 1.5 | 0     | 55 | 12.2 | 4000 | 58.8 | 0.0 | -2.8 | 0.0  | 8.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652688.3 | 4786975.7 | 1.5 | 0     | 57 | 7.1  | 250  | 59.0 | 0.0 | -2.9 | 7.5  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2              | 17652688.3 | 4786975.7 | 1.5 | 0     | 63 | 7.1  | 500  | 59.0 | 0.0 | -2.9 | 9.7  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652688.3 | 4786975.7 | 1.5 | 0     | 63 | 7.1  | 1000 | 59.0 | 0.0 | -2.9 | 12.2 | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652682.4 | 4786973.5 | 1.5 | 0     | 57 | 8.8  | 250  | 58.8 | 0.0 | -2.9 | 7.3  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652682.4 | 4786973.5 | 1.5 | 0     | 63 | 8.8  | 500  | 58.8 | 0.0 | -2.9 | 9.4  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2              | 17652682.4 | 4786973.5 | 1.5 | 0     | 63 | 8.8  | 1000 | 58.8 | 0.0 | -2.9 | 11.9 | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652673.4 | 4786970.2 | 1.5 | 0     | 57 | 10.7 | 250  | 58.5 | 0.0 | -2.9 | 9.9  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652673.4 | 4786970.2 | 1.5 | 0     | 63 | 10.7 | 500  | 58.5 | 0.0 | -2.9 | 12.7 | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652673.4 | 4786970.2 | 1.5 | 0     | 63 | 10.7 | 1000 | 58.5 | 0.0 | -2.9 | 15.7 | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 71 | 0.0  | 63   | 55.0 | 0.0 | -3.0 | 10.2 | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 55.0 | 0.0 | -2.7 | 12.8 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 55.0 | 0.0 | -2.7 | 15.6 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 55.0 | 0.0 | -2.7 | 18.6 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 55.0 | 0.0 | -2.7 | 21.5 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 55.0 | 0.0 | -2.7 | 23.7 | 1.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 89 | 0.0  | 4000 | 55.0 | 0.0 | -2.7 | 25.3 | 5.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652634.1 | 4786966.5 | 1.5 | 0     | 52 | 10.9 | 500  | 57.5 | 0.0 | -3.0 | 5.9  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652634.1 | 4786966.5 | 1.5 | 0     | 55 | 10.9 | 1000 | 57.5 | 0.0 | -3.0 | 7.0  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2               | 17652594.2 | 4786964.7 | 1.5 | 0     | 52 | 14.7 | 500  | 56.6 | 0.0 | -3.0 | 7.9  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2               | 17652594.2 | 4786964.7 | 1.5 | 0     | 55 | 14.7 | 1000 | 56.6 | 0.0 | -3.0 | 8.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2               | 17652594.2 | 4786964.7 | 1.5 | 0     | 52 | 14.7 | 2000 | 56.6 | 0.0 | -3.0 | 8.2  | 1.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652564.3 | 4786963.3 | 1.5 | 0     | 52 | 14.8 | 500  | 56.1 | 0.0 | -2.8 | 7.8  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652564.3 | 4786963.3 | 1.5 | 0     | 55 | 14.8 | 1000 | 56.1 | 0.0 | -2.8 | 8.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2               | 17652564.3 | 4786963.3 | 1.5 | 0     | 52 | 14.8 | 2000 | 56.1 | 0.0 | -2.8 | 8.5  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652540.1 | 4786962.1 | 1.5 | 0     | 52 | 12.5 | 500  | 55.9 | 0.0 | -2.5 | 7.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652540.1 | 4786962.1 | 1.5 | 0     | 55 | 12.5 | 1000 | 55.9 | 0.0 | -2.5 | 8.1  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652540.1 | 4786962.1 | 1.5 | 0     | 52 | 12.5 | 2000 | 55.9 | 0.0 | -2.5 | 9.1  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652527.0 | 4786961.5 | 1.5 | 0     | 45 | 9.2  | 250  | 55.8 | 0.0 | -2.4 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2               | 17652527.0 | 4786961.5 | 1.5 | 0     | 52 | 9.2  | 500  | 55.8 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2               | 17652527.0 | 4786961.5 | 1.5 | 0     | 55 | 9.2  | 1000 | 55.8 | 0.0 | -2.4 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2               | 17652527.0 | 4786961.5 | 1.5 | 0     | 52 | 9.2  | 2000 | 55.8 | 0.0 | -2.4 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652591.6 | 4787020.0 | 1.5 | 0     | 45 | 11.2 | 250  | 58.7 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652591.6 | 4787020.0 | 1.5 | 0     | 52 | 11.2 | 500  | 58.7 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652591.6 | 4787020.0 | 1.5 | 0     | 55 | 11.2 | 1000 | 58.7 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2               | 17652591.6 | 4787020.0 | 1.5 | 0     | 52 | 11.2 | 2000 | 58.7 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652607.9 | 4787020.6 | 1.5 | 0     | 45 | 12.9 | 250  | 58.9 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652607.9 | 4787020.6 | 1.5 | 0     | 52 | 12.9 | 500  | 58.9 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2               | 17652607.9 | 4787020.6 | 1.5 | 0     | 55 | 12.9 | 1000 | 58.9 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L04       | 5-Ton Pass-by 2               | 17652607.9 | 4787020.6 | 1.5 | 0     | 52 | 12.9 | 2000 | 58.9 | 0.0 | -2.9 | 0.0  | 2.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652627.3 | 4787021.3 | 1.5 | 0     | 55 | 12.8 | 1000 | 59.2 | 0.0 | -3.0 | 9.4  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652573.9 | 4787036.9 | 1.5 | 0     | 55 | 8.6  | 1000 | 59.1 | 0.0 | -2.8 | 4.7  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652580.4 | 4787026.8 | 1.5 | 0     | 45 | 12.2 | 250  | 58.8 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2               | 17652580.4 | 4787026.8 | 1.5 | 0     | 52 | 12.2 | 500  | 58.8 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2               | 17652580.4 | 4787026.8 | 1.5 | 0     | 55 | 12.2 | 1000 | 58.8 | 0.0 | -2.8 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name          | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|----------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| L04       | 5-Ton Pass-by 2      | 17652580.4 | 4787026.8 | 1.5 | 0     | 52 | 12.2 | 2000 | 58.8 | 0.0 | -2.8 | 0.0  | 2.4  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 6  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 62 | 0.0  | 63   | 61.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 70 | 0.0  | 125  | 61.6 | 0.0 | -2.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 6  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 72 | 0.0  | 250  | 61.6 | 0.0 | -2.4 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 3  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 79 | 0.0  | 500  | 61.6 | 0.0 | -2.5 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 10 |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 76 | 0.0  | 1000 | 61.6 | 0.0 | -2.5 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 5  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 75 | 0.0  | 2000 | 61.6 | 0.0 | -2.5 | 0.0  | 3.3  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 0  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 67 | 0.0  | 63   | 55.8 | 0.0 | -3.0 | 6.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 2  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 55.8 | 0.0 | -2.8 | 7.9  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 13 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 55.8 | 0.0 | -2.8 | 10.3 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 15 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 55.8 | 0.0 | -2.8 | 13.1 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 18 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 55.8 | 0.0 | -2.8 | 16.0 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 16 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 55.8 | 0.0 | -2.8 | 18.7 | 1.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 10 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 68 | 0.0  | 63   | 54.6 | 0.0 | -3.0 | 5.8  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 5  |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 54.6 | 0.0 | -2.8 | 7.3  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 16 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0  | 250  | 54.6 | 0.0 | -2.8 | 9.5  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 22 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 500  | 54.6 | 0.0 | -2.8 | 12.2 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 26 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 1000 | 54.6 | 0.0 | -2.8 | 15.0 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 23 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 54.6 | 0.0 | -2.8 | 17.7 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 19 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0  | 4000 | 54.6 | 0.0 | -2.8 | 20.2 | 4.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0  | 63   | 57.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 11 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0  | 125  | 57.5 | 0.0 | -1.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 19 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0  | 250  | 57.5 | 0.0 | -1.8 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 20 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0  | 500  | 57.5 | 0.0 | -2.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 21 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0  | 1000 | 57.5 | 0.0 | -2.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 22 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 85 | 0.0  | 2000 | 57.5 | 0.0 | -2.0 | 0.0  | 2.0  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 16 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 78 | 0.0  | 4000 | 57.5 | 0.0 | -2.0 | 0.0  | 6.9  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 3  |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0  | 125  | 52.8 | 0.0 | -3.0 | 4.3  | 0.1  | 0.0  | 0.0  | 0.0  | -4.5  | 0.0 | 17 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0  | 250  | 52.8 | 0.0 | -3.0 | 4.7  | 0.1  | 0.0  | 0.0  | 0.0  | -8.5  | 0.0 | 16 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0  | 500  | 52.8 | 0.0 | -3.0 | 5.2  | 0.2  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 83 | 0.0  | 1000 | 52.8 | 0.0 | -3.0 | 5.8  | 0.5  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 16 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0  | 2000 | 52.8 | 0.0 | -3.0 | 6.8  | 1.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 9  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0  | 125  | 53.2 | 0.0 | -3.0 | 4.5  | 0.1  | 0.0  | 0.0  | 0.0  | -4.6  | 0.0 | 17 |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0  | 250  | 53.2 | 0.0 | -3.0 | 5.0  | 0.1  | 0.0  | 0.0  | 0.0  | -8.6  | 0.0 | 15 |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0  | 500  | 53.2 | 0.0 | -3.0 | 5.8  | 0.2  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 18 |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 83 | 0.0  | 1000 | 53.2 | 0.0 | -3.0 | 7.0  | 0.5  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 15 |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0  | 2000 | 53.2 | 0.0 | -3.0 | 8.5  | 1.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 7  |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 72 | 0.0  | 250  | 57.6 | 0.0 | -2.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 8  |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 84 | 0.0  | 500  | 57.6 | 0.0 | -2.2 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 18 |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0  | 1000 | 57.6 | 0.0 | -2.2 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 22 |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 87 | 0.0  | 2000 | 57.6 | 0.0 | -2.2 | 0.0  | 2.1  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 18 |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 81 | 0.0  | 4000 | 57.6 | 0.0 | -2.2 | 0.0  | 7.0  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 6  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 67 | 0.0  | 63   | 58.9 | 0.0 | -3.0 | 4.3  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 6  |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 58.9 | 0.0 | -2.8 | 5.1  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 14 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 58.9 | 0.0 | -2.8 | 6.2  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 13 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 87 | 0.0 | 500  | 58.9 | 0.0 | -2.9 | 7.9  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 13 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.9 | 0.0 | -2.9 | 9.9  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 11 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 58.9 | 0.0 | -2.9 | 12.4 | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 3  |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.2 | 0.0 | -3.0 | 4.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 6  |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.2 | 0.0 | -3.0 | 4.5  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 14 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.2 | 0.0 | -3.0 | 5.2  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 14 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.2 | 0.0 | -3.0 | 6.2  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 14 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.2 | 0.0 | -3.0 | 7.6  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 13 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.2 | 0.0 | -3.0 | 9.5  | 2.5  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 5  |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 67 | 0.0 | 63   | 59.3 | 0.0 | -3.0 | 4.1  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 6  |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 59.3 | 0.0 | -3.0 | 4.7  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 14 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 59.3 | 0.0 | -3.0 | 5.5  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 14 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 87 | 0.0 | 500  | 59.3 | 0.0 | -3.0 | 6.7  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 13 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.3 | 0.0 | -3.0 | 8.3  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 13 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.3 | 0.0 | -3.0 | 10.4 | 2.5  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 4  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 67 | 0.0 | 63   | 59.4 | 0.0 | -3.0 | 5.8  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 4  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 59.4 | 0.0 | -2.9 | 7.4  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 11 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 59.4 | 0.0 | -2.9 | 9.7  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 9  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 87 | 0.0 | 500  | 59.4 | 0.0 | -2.9 | 12.5 | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 7  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.4 | 0.0 | -2.9 | 15.3 | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 5  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 67 | 0.0 | 63   | 60.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 9  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 60.3 | 0.0 | -1.4 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 16 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 60.3 | 0.0 | -1.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 60.3 | 0.0 | -2.1 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.3 | 0.0 | -2.1 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.3 | 0.0 | -2.1 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 12 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 67 | 0.0 | 63   | 60.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 60.4 | 0.0 | -1.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 16 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 60.4 | 0.0 | -2.2 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 60.4 | 0.0 | -2.3 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 18 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.4 | 0.0 | -2.3 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.4 | 0.0 | -2.3 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 12 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 67 | 0.0 | 63   | 60.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 60.4 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 60.4 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 18 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 87 | 0.0 | 500  | 60.4 | 0.0 | -2.6 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 19 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.4 | 0.0 | -2.6 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.4 | 0.0 | -2.6 | 0.0  | 2.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 67 | 0.0 | 63   | 60.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 60.4 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 60.4 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 60.4 | 0.0 | -2.5 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.4 | 0.0 | -2.5 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.4 | 0.0 | -2.5 | 0.0  | 2.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 12 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 67 | 0.0 | 63   | 60.6 | 0.0 | -3.0 | 6.5  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 60.6 | 0.0 | -2.9 | 8.5  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 9  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 60.6 | 0.0 | -2.9 | 11.1 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 7  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 87 | 0.0 | 500  | 60.6 | 0.0 | -2.9 | 14.1 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.6 | 0.0 | -2.9 | 17.0 | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 2  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 67 | 0.0 | 63   | 60.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.6 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 60.6 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 18 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.6 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.6 | 0.0 | -2.7 | 0.0  | 2.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 13 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 84 | 0.0 | 500  | 59.8 | 0.0 | -2.9 | 10.2 | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 6  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.8 | 0.0 | -2.9 | 12.8 | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 7  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 87 | 0.0 | 2000 | 59.8 | 0.0 | -2.9 | 15.6 | 2.7  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 0  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 67 | 0.0 | 63   | 60.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 8  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 60.8 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 17 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 60.8 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 17 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 87 | 0.0 | 500  | 60.8 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.8 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 19 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.8 | 0.0 | -2.7 | 0.0  | 3.0  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 12 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 67 | 0.0 | 63   | 60.9 | 0.0 | -3.0 | 6.2  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.9 | 0.0 | -2.9 | 8.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 9  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.9 | 0.0 | -2.9 | 10.5 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 7  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 87 | 0.0 | 500  | 60.9 | 0.0 | -2.9 | 13.4 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.9 | 0.0 | -2.9 | 16.3 | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 3  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 67 | 0.0 | 63   | 61.0 | 0.0 | -3.0 | 6.2  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.0 | 0.0 | -2.9 | 8.1  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 9  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.0 | 0.0 | -2.9 | 10.6 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 7  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 87 | 0.0 | 500  | 61.0 | 0.0 | -2.9 | 13.5 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.0 | 0.0 | -2.9 | 16.4 | 1.2  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 2  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 65 | 0.0 | 63   | 60.5 | 0.0 | -3.0 | 6.3  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 0  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 60.5 | 0.0 | -2.9 | 8.3  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 7  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 83 | 0.0 | 250  | 60.5 | 0.0 | -2.9 | 10.9 | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 6  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 500  | 60.5 | 0.0 | -2.9 | 13.8 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.5 | 0.0 | -2.9 | 16.7 | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 1  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 67 | 0.0 | 63   | 61.2 | 0.0 | -3.0 | 5.8  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.2 | 0.0 | -2.9 | 7.5  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 9  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 61.2 | 0.0 | -2.9 | 9.9  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 7  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 87 | 0.0 | 500  | 61.2 | 0.0 | -2.9 | 12.7 | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 5  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.2 | 0.0 | -2.9 | 15.6 | 1.2  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 3  |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 72 | 0.0 | 250  | 60.4 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 6  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 84 | 0.0 | 500  | 60.4 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 16 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.4 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 87 | 0.0 | 2000 | 60.4 | 0.0 | -2.7 | 0.0  | 2.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 15 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.4 | 0.0 | -2.7 | 0.0  | 9.7  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 1  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 72 | 0.0 | 250  | 60.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 5  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 60.6 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.6 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 87 | 0.0 | 2000 | 60.6 | 0.0 | -2.7 | 0.0  | 2.9  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 15 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.6 | 0.0 | -2.7 | 0.0  | 9.8  | 0.0  | 0.0   | 0.0  | -13.0 | 0.0 | 0  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 62 | 0.0 | 63   | 57.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 6  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 57.5 | 0.0 | -1.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 14 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 57.5 | 0.0 | -2.1 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 16 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 83 | 0.0 | 500  | 57.5 | 0.0 | -2.3 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 17 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 82 | 0.0 | 1000 | 57.5 | 0.0 | -2.3 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 15 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 2000 | 57.5 | 0.0 | -2.3 | 0.0  | 2.0  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 11 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 77 | 0.0 | 4000 | 57.5 | 0.0 | -2.3 | 0.0  | 6.9  | 0.0  | 0.0   | 0.0  | -12.9 | 0.0 | 2  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 72 | 0.0 | 250  | 62.0 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 4  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 84 | 0.0 | 500  | 62.0 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 14 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 62.0 | 0.0 | -2.6 | 0.0  | 1.3  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 17 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 87 | 0.0 | 2000 | 62.0 | 0.0 | -2.6 | 0.0  | 3.4  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 13 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 58.4 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 16 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 250  | 58.4 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 15 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 84 | 0.0 | 500  | 58.4 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 18 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 58.4 | 0.0 | -3.0 | 0.0  | 0.9  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 16 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 2000 | 58.4 | 0.0 | -3.0 | 0.0  | 2.3  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 10 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 67 | 0.0 | 63   | 63.4 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 5  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 63.4 | 0.0 | -2.1 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 14 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 63.4 | 0.0 | -2.4 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 14 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 63.4 | 0.0 | -2.5 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.4 | 0.0 | -2.5 | 0.0  | 1.5  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.4 | 0.0 | -2.5 | 0.0  | 4.0  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 67 | 0.0 | 63   | 63.5 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 5  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 63.5 | 0.0 | -2.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | -4.9  | 0.0 | 13 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 63.5 | 0.0 | -2.3 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | -8.9  | 0.0 | 14 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 63.5 | 0.0 | -2.4 | 0.0  | 0.8  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.5 | 0.0 | -2.4 | 0.0  | 1.5  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.5 | 0.0 | -2.4 | 0.0  | 4.1  | 0.0  | 0.0   | 0.0  | -12.0 | 0.0 | 8  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 74 | 0.0 | 125  | 58.6 | 0.0 | -0.3 | 9.6  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 1  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 59.4 | 0.0 | -2.9 | 4.9  | 0.1  | 0.0  | 0.0   | 0.0  | -4.8  | 0.0 | 10 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 250  | 59.4 | 0.0 | -2.9 | 6.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.8  | 0.0 | 8  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 84 | 0.0 | 500  | 59.4 | 0.0 | -2.9 | 7.5  | 0.5  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 10 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 59.4 | 0.0 | -2.9 | 9.4  | 1.0  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 5  |



Receiver: RP08

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP08          | RP08        | 17652521.05 m | 4786788.18 m | 13.05 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S02       | HVAC RTU                      | 17652778.2 | 4786850.1 | 8.0 | 0     | 74  | 0.0 | 125  | 59.4 | 0.0 | -0.3 | 9.6  | 0.1  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 0  |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 76  | 0.0 | 125  | 60.2 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 14 |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 79  | 0.0 | 250  | 60.2 | 0.0 | -2.6 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 12 |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 84  | 0.0 | 500  | 60.2 | 0.0 | -2.6 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 60.2 | 0.0 | -2.6 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 13 |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 79  | 0.0 | 2000 | 60.2 | 0.0 | -2.6 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 7  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 76  | 0.0 | 125  | 60.6 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 13 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 250  | 60.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 12 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 84  | 0.0 | 500  | 60.6 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 83  | 0.0 | 1000 | 60.6 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 13 |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 2000 | 60.6 | 0.0 | -2.7 | 0.0  | 2.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 6  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 76  | 0.0 | 125  | 60.6 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 13 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 79  | 0.0 | 250  | 60.6 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 12 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 84  | 0.0 | 500  | 60.6 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 16 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 60.6 | 0.0 | -2.7 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 13 |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 79  | 0.0 | 2000 | 60.6 | 0.0 | -2.7 | 0.0  | 2.9  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 6  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 76  | 0.0 | 125  | 62.4 | 0.0 | -1.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 250  | 62.4 | 0.0 | -1.9 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 9  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 84  | 0.0 | 500  | 62.4 | 0.0 | -2.1 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 13 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.4 | 0.0 | -2.1 | 0.0  | 1.4  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.4 | 0.0 | -2.1 | 0.0  | 3.6  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 3  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 76  | 0.0 | 125  | 62.9 | 0.0 | -1.8 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -4.9  | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 250  | 62.9 | 0.0 | -2.3 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.9  | 0.0 | 9  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 84  | 0.0 | 500  | 62.9 | 0.0 | -2.4 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 13 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.9 | 0.0 | -2.4 | 0.0  | 1.4  | 0.0  | 0.0  | 0.0  | -11.0 | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.9 | 0.0 | -2.4 | 0.0  | 3.8  | 0.0  | 0.0  | 0.0  | -12.0 | 0.0 | 3  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 70  | 0.0 | 125  | 58.8 | 0.0 | -2.4 | 7.5  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 2  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 79  | 0.0 | 500  | 58.8 | 0.0 | -2.7 | 12.7 | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 0  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 72  | 0.0 | 63   | 55.0 | 0.0 | -3.0 | 10.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 4  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 55.0 | 0.0 | -2.7 | 12.6 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 16 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 55.0 | 0.0 | -2.7 | 15.4 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 17 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 55.0 | 0.0 | -2.7 | 18.3 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 21 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 55.0 | 0.0 | -2.7 | 21.3 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 20 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 55.0 | 0.0 | -2.7 | 23.6 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 15 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 55.0 | 0.0 | -2.7 | 25.1 | 5.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 5  |



Receiver: RP09

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP09          | RP09        | 17652544.55 m | 4786766.04 m | 1.50 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc  | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L01       | 15-Ton Pass-by                | 17652652.3 | 4786882.7 | 1.5 | 0     | 63 | 11.8 | 500  | 55.0 | 0.0 | -3.4 | 21.5 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652599.1 | 4786964.9 | 1.5 | 0     | 63 | 17.4 | 500  | 57.3 | 0.0 | -4.6 | 24.4 | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652567.7 | 4786963.4 | 1.5 | 0     | 57 | 8.9  | 250  | 57.0 | 0.0 | -4.6 | 13.0 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652567.7 | 4786963.4 | 1.5 | 0     | 63 | 8.9  | 500  | 57.0 | 0.0 | -4.6 | 15.1 | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652567.7 | 4786963.4 | 1.5 | 0     | 63 | 8.9  | 1000 | 57.0 | 0.0 | -4.6 | 17.5 | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652546.0 | 4786962.4 | 1.5 | 0     | 52 | 15.5 | 125  | 56.9 | 0.0 | -4.4 | 10.6 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652546.0 | 4786962.4 | 1.5 | 0     | 57 | 15.5 | 250  | 56.9 | 0.0 | -4.4 | 12.7 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2              | 17652546.0 | 4786962.4 | 1.5 | 0     | 63 | 15.5 | 500  | 56.9 | 0.0 | -4.4 | 15.0 | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2              | 17652546.0 | 4786962.4 | 1.5 | 0     | 63 | 15.5 | 1000 | 56.9 | 0.0 | -4.4 | 17.5 | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2              | 17652546.0 | 4786962.4 | 1.5 | 0     | 61 | 15.5 | 2000 | 56.9 | 0.0 | -4.4 | 20.2 | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652525.6 | 4786961.4 | 1.5 | 0     | 52 | 7.2  | 125  | 56.9 | 0.0 | -3.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2              | 17652525.6 | 4786961.4 | 1.5 | 0     | 57 | 7.2  | 250  | 56.9 | 0.0 | -3.9 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2              | 17652525.6 | 4786961.4 | 1.5 | 0     | 63 | 7.2  | 500  | 56.9 | 0.0 | -3.9 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 17 |
| L02       | 15-Ton Pass-by 2              | 17652525.6 | 4786961.4 | 1.5 | 0     | 63 | 7.2  | 1000 | 56.9 | 0.0 | -3.9 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2              | 17652525.6 | 4786961.4 | 1.5 | 0     | 61 | 7.2  | 2000 | 56.9 | 0.0 | -3.9 | 0.0  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2              | 17652525.6 | 4786961.4 | 1.5 | 0     | 55 | 7.2  | 4000 | 56.9 | 0.0 | -3.9 | 0.0  | 6.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652600.3 | 4787020.4 | 1.5 | 0     | 63 | 14.9 | 500  | 59.3 | 0.0 | -5.0 | 21.4 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652569.3 | 4787044.0 | 1.5 | 0     | 63 | 7.0  | 500  | 59.9 | 0.0 | -5.0 | 11.1 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652569.3 | 4787044.0 | 1.5 | 0     | 63 | 7.0  | 1000 | 59.9 | 0.0 | -5.0 | 12.2 | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652575.8 | 4787034.0 | 1.5 | 0     | 57 | 12.1 | 250  | 59.6 | 0.0 | -5.0 | 10.0 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652575.8 | 4787034.0 | 1.5 | 0     | 63 | 12.1 | 500  | 59.6 | 0.0 | -5.0 | 10.3 | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2              | 17652575.8 | 4787034.0 | 1.5 | 0     | 63 | 12.1 | 1000 | 59.6 | 0.0 | -5.0 | 10.7 | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652575.8 | 4787034.0 | 1.5 | 0     | 61 | 12.1 | 2000 | 59.6 | 0.0 | -5.0 | 11.5 | 2.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 54.7 | 0.0 | -3.6 | 18.5 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 54.7 | 0.0 | -3.6 | 21.5 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 54.7 | 0.0 | -3.6 | 24.4 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 54.7 | 0.0 | -3.6 | 27.3 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 54.7 | 0.0 | -3.6 | 27.9 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2               | 17652546.0 | 4786962.4 | 1.5 | 0     | 55 | 15.5 | 1000 | 56.9 | 0.0 | -4.4 | 17.5 | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652525.6 | 4786961.4 | 1.5 | 0     | 52 | 7.2  | 500  | 56.9 | 0.0 | -3.9 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652525.6 | 4786961.4 | 1.5 | 0     | 55 | 7.2  | 1000 | 56.9 | 0.0 | -3.9 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L04       | 5-Ton Pass-by 2               | 17652525.6 | 4786961.4 | 1.5 | 0     | 52 | 7.2  | 2000 | 56.9 | 0.0 | -3.9 | 0.0  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2               | 17652575.8 | 4787034.0 | 1.5 | 0     | 55 | 12.1 | 1000 | 59.6 | 0.0 | -5.0 | 10.7 | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 55.7 | 0.0 | -4.0 | 14.7 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 55.7 | 0.0 | -4.0 | 18.2 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 55.7 | 0.0 | -4.0 | 21.5 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 55.7 | 0.0 | -4.0 | 24.6 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| S40       | Dirt Loading Cycle            | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 55.7 | 0.0 | -4.0 | 26.5 | 1.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 68 | 0.0  | 63   | 54.6 | 0.0 | -4.5 | 11.4 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 54.6 | 0.0 | -3.8 | 14.2 | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0  | 250  | 54.6 | 0.0 | -3.8 | 17.6 | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 500  | 54.6 | 0.0 | -3.8 | 20.8 | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 19 |
| S41       | Gravel Loading Cycle          | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 1000 | 54.6 | 0.0 | -3.8 | 23.9 | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |



Receiver: RP09

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP09          | RP09        | 17652544.55 m | 4786766.04 m | 1.50 m |

| Source ID | Source Name          | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahou | Cmet | Dc    | RL  | Lr |
|-----------|----------------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0 | 2000 | 54.6 | 0.0 | -3.8 | 25.8 | 1.5  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 11 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0 | 4000 | 54.6 | 0.0 | -3.8 | 27.1 | 4.9  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 3  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0 | 63   | 58.3 | 0.0 | -3.3 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 11 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0 | 125  | 58.3 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 19 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0 | 250  | 58.3 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 20 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0 | 500  | 58.3 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 21 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.3 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -11.1 | 0.0 | 22 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 58.3 | 0.0 | -3.0 | 0.0  | 2.2  | 0.0  | 0.0  | 0.0  | -12.1 | 0.0 | 16 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 78 | 0.0 | 4000 | 58.3 | 0.0 | -3.0 | 0.0  | 7.6  | 0.0  | 0.0  | 0.0  | -13.1 | 0.0 | 2  |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0 | 125  | 53.6 | 0.0 | -2.7 | 7.7  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 12 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0 | 250  | 53.6 | 0.0 | -2.8 | 10.3 | 0.1  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 9  |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0 | 500  | 53.6 | 0.0 | -2.9 | 12.9 | 0.3  | 0.0  | 0.0  | 0.0  | -10.1 | 0.0 | 10 |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 53.6 | 0.0 | -2.9 | 15.7 | 0.5  | 0.0  | 0.0  | 0.0  | -11.1 | 0.0 | 5  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 53.8 | 0.0 | -2.5 | 8.7  | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 11 |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 250  | 53.8 | 0.0 | -2.8 | 11.6 | 0.1  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 7  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0 | 500  | 53.8 | 0.0 | -2.8 | 14.4 | 0.3  | 0.0  | 0.0  | 0.0  | -10.1 | 0.0 | 8  |
| S16       | HVAC RTU             | 17652589.2 | 4786896.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 53.8 | 0.0 | -2.8 | 17.3 | 0.5  | 0.0  | 0.0  | 0.0  | -11.1 | 0.0 | 3  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.1 | 0.0 | -3.5 | 9.2  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 1  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.1 | 0.0 | -3.2 | 11.9 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 7  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.1 | 0.0 | -3.3 | 15.1 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 4  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.1 | 0.0 | -3.4 | 18.3 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 2  |
| S08       | HVAC RTU             | 17652671.6 | 4786985.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.1 | 0.0 | -3.4 | 21.3 | 0.9  | 0.0  | 0.0  | 0.0  | -11.1 | 0.0 | 0  |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 72 | 0.0 | 250  | 58.4 | 0.0 | -3.1 | 7.9  | 0.2  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 0  |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 84 | 0.0 | 500  | 58.4 | 0.0 | -3.2 | 7.9  | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 10 |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 58.4 | 0.0 | -3.2 | 7.9  | 0.9  | 0.0  | 0.0  | 0.0  | -11.1 | 0.0 | 14 |
| S14       | HVAC RTU             | 17652545.1 | 4787000.3 | 5.5 | 0     | 87 | 0.0 | 2000 | 58.4 | 0.0 | -3.2 | 7.9  | 2.3  | 0.0  | 0.0  | 0.0  | -12.1 | 0.0 | 10 |
| S35       | HVAC RTU             | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 59.4 | 0.0 | -2.8 | 13.4 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 5  |
| S35       | HVAC RTU             | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 59.4 | 0.0 | -3.0 | 17.1 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 2  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.4 | 0.0 | -3.6 | 8.5  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 2  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.4 | 0.0 | -3.4 | 11.1 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 8  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.4 | 0.0 | -3.4 | 14.2 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 5  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.4 | 0.0 | -3.4 | 17.2 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 3  |
| S11       | HVAC RTU             | 17652661.7 | 4787001.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.4 | 0.0 | -3.4 | 20.2 | 1.0  | 0.0  | 0.0  | 0.0  | -11.1 | 0.0 | 1  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 67 | 0.0 | 63   | 59.5 | 0.0 | -3.6 | 8.7  | 0.0  | 0.0  | 0.0  | 0.0  | -1.0  | 0.0 | 1  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 59.5 | 0.0 | -3.5 | 11.4 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 7  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 59.5 | 0.0 | -3.5 | 14.5 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 5  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 87 | 0.0 | 500  | 59.5 | 0.0 | -3.5 | 17.6 | 0.5  | 0.0  | 0.0  | 0.0  | -10.0 | 0.0 | 3  |
| S10       | HVAC RTU             | 17652667.8 | 4787001.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.5 | 0.0 | -3.5 | 20.6 | 1.0  | 0.0  | 0.0  | 0.0  | -11.1 | 0.0 | 0  |
| S34       | HVAC RTU             | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 60.4 | 0.0 | -3.4 | 14.2 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 4  |
| S34       | HVAC RTU             | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 60.4 | 0.0 | -3.4 | 17.8 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 0  |
| S26       | HVAC RTU             | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.7 | 0.0 | -3.9 | 14.8 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 3  |
| S26       | HVAC RTU             | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.7 | 0.0 | -3.9 | 18.0 | 0.3  | 0.0  | 0.0  | 0.0  | -9.0  | 0.0 | 0  |
| S05       | HVAC RTU             | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.8 | 0.0 | -3.6 | 14.0 | 0.1  | 0.0  | 0.0  | 0.0  | -5.0  | 0.0 | 4  |



Receiver: RP09

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP09          | RP09        | 17652544.55 m | 4786766.04 m | 1.50 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.8 | 0.0 | -3.6 | 17.6 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 60.9 | 0.0 | -3.6 | 14.1 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 60.9 | 0.0 | -3.6 | 17.7 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 60.9 | 0.0 | -4.0 | 14.5 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 60.9 | 0.0 | -4.0 | 17.6 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 67 | 0.0 | 63   | 61.0 | 0.0 | -4.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.0 | 0.0 | -3.2 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 17 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.0 | 0.0 | -3.2 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 17 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 61.0 | 0.0 | -3.2 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 18 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.0 | 0.0 | -3.2 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.0 | 0.0 | -3.2 | 0.0  | 3.1  | 0.0  | 0.0   | 0.0  | -12.1 | 0.0 | 12 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 60.3 | 0.0 | -3.5 | 14.1 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 67 | 0.0 | 63   | 61.0 | 0.0 | -4.0 | 8.8  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 0  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.0 | 0.0 | -3.8 | 8.5  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 9  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.0 | 0.0 | -3.8 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 9  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 87 | 0.0 | 500  | 61.0 | 0.0 | -3.8 | 8.5  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 10 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.0 | 0.0 | -3.8 | 8.5  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.0 | 0.0 | -3.8 | 8.5  | 3.1  | 0.0  | 0.0   | 0.0  | -12.1 | 0.0 | 4  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 67 | 0.0 | 63   | 61.1 | 0.0 | -4.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.1 | 0.0 | -3.4 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 17 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.1 | 0.0 | -3.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 17 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 61.1 | 0.0 | -3.4 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.1 | 0.0 | -3.4 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.1 | 0.0 | -3.4 | 0.0  | 3.1  | 0.0  | 0.0   | 0.0  | -12.1 | 0.0 | 12 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 67 | 0.0 | 63   | 61.1 | 0.0 | -4.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -1.0  | 0.0 | 9  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 61.1 | 0.0 | -3.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 17 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 61.1 | 0.0 | -3.5 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 18 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 61.1 | 0.0 | -3.5 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 19 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.1 | 0.0 | -3.5 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 19 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.1 | 0.0 | -3.5 | 0.0  | 3.1  | 0.0  | 0.0   | 0.0  | -12.1 | 0.0 | 13 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.1 | 0.0 | -3.6 | 13.8 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 61.1 | 0.0 | -3.6 | 17.4 | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 84 | 0.0 | 500  | 61.0 | 0.0 | -4.0 | 8.7  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.0 | 0.0 | -4.0 | 8.7  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 11 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 87 | 0.0 | 2000 | 61.0 | 0.0 | -4.0 | 8.7  | 3.1  | 0.0  | 0.0   | 0.0  | -12.1 | 0.0 | 6  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 58.3 | 0.0 | -3.0 | 7.8  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 7  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 58.3 | 0.0 | -3.2 | 7.9  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 8  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 83 | 0.0 | 500  | 58.3 | 0.0 | -3.2 | 8.0  | 0.4  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 9  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 82 | 0.0 | 1000 | 58.3 | 0.0 | -3.2 | 8.0  | 0.8  | 0.0  | 0.0   | 0.0  | -11.1 | 0.0 | 7  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 2000 | 58.3 | 0.0 | -3.2 | 8.0  | 2.2  | 0.0  | 0.0   | 0.0  | -12.1 | 0.0 | 3  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 58.8 | 0.0 | -3.0 | 13.5 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 59.6 | 0.0 | -3.5 | 13.8 | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 76 | 0.0 | 125  | 60.9 | 0.0 | -3.7 | 8.5  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 5  |



Receiver: RP09

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 34          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP09          | RP09        | 17652544.55 m | 4786766.04 m | 1.50 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 79  | 0.0 | 250  | 60.9 | 0.0 | -3.7 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 84  | 0.0 | 500  | 60.9 | 0.0 | -3.7 | 8.5  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 8  |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 60.9 | 0.0 | -3.7 | 8.5  | 1.1  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 5  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 76  | 0.0 | 125  | 61.2 | 0.0 | -3.8 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 5  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 250  | 61.2 | 0.0 | -3.8 | 8.6  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 84  | 0.0 | 500  | 61.2 | 0.0 | -3.8 | 8.6  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.2 | 0.0 | -3.8 | 8.6  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 5  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 76  | 0.0 | 125  | 61.2 | 0.0 | -3.9 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 5  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 79  | 0.0 | 250  | 61.2 | 0.0 | -3.9 | 8.6  | 0.3  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 84  | 0.0 | 500  | 61.2 | 0.0 | -3.9 | 8.6  | 0.6  | 0.0  | 0.0   | 0.0  | -10.0 | 0.0 | 7  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.2 | 0.0 | -3.9 | 8.6  | 1.2  | 0.0  | 0.0   | 0.0  | -11.0 | 0.0 | 5  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 76  | 0.0 | 125  | 62.3 | 0.0 | -2.5 | 9.6  | 0.2  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 72  | 0.0 | 63   | 54.7 | 0.0 | -4.5 | 16.0 | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 54.7 | 0.0 | -3.6 | 18.5 | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 11 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 54.7 | 0.0 | -3.6 | 21.4 | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 13 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 54.7 | 0.0 | -3.6 | 24.4 | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 17 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 54.7 | 0.0 | -3.6 | 27.3 | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 15 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 54.7 | 0.0 | -3.6 | 27.9 | 1.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 12 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 54.7 | 0.0 | -3.6 | 28.2 | 5.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 4  |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name    | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|----------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L01       | 15-Ton Pass-by | 17652672.2 | 4786882.7 | 1.5 | 0     | 52 | 9.4  | 125  | 56.9 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652672.2 | 4786882.7 | 1.5 | 0     | 57 | 9.4  | 250  | 56.9 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652672.2 | 4786882.7 | 1.5 | 0     | 63 | 9.4  | 500  | 56.9 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652672.2 | 4786882.7 | 1.5 | 0     | 63 | 9.4  | 1000 | 56.9 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652672.2 | 4786882.7 | 1.5 | 0     | 61 | 9.4  | 2000 | 56.9 | 0.0 | -2.7 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652672.2 | 4786882.7 | 1.5 | 0     | 55 | 9.4  | 4000 | 56.9 | 0.0 | -2.7 | 0.0  | 6.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L01       | 15-Ton Pass-by | 17652663.8 | 4786882.7 | 1.5 | 0     | 52 | 9.2  | 125  | 56.6 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652663.8 | 4786882.7 | 1.5 | 0     | 57 | 9.2  | 250  | 56.6 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652663.8 | 4786882.7 | 1.5 | 0     | 63 | 9.2  | 500  | 56.6 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L01       | 15-Ton Pass-by | 17652663.8 | 4786882.7 | 1.5 | 0     | 63 | 9.2  | 1000 | 56.6 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652663.8 | 4786882.7 | 1.5 | 0     | 61 | 9.2  | 2000 | 56.6 | 0.0 | -2.6 | 0.0  | 1.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L01       | 15-Ton Pass-by | 17652663.8 | 4786882.7 | 1.5 | 0     | 55 | 9.2  | 4000 | 56.6 | 0.0 | -2.6 | 0.0  | 6.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L01       | 15-Ton Pass-by | 17652652.2 | 4786882.7 | 1.5 | 0     | 52 | 11.7 | 125  | 56.2 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652652.2 | 4786882.7 | 1.5 | 0     | 57 | 11.7 | 250  | 56.2 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L01       | 15-Ton Pass-by | 17652652.2 | 4786882.7 | 1.5 | 0     | 63 | 11.7 | 500  | 56.2 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| L01       | 15-Ton Pass-by | 17652652.2 | 4786882.7 | 1.5 | 0     | 63 | 11.7 | 1000 | 56.2 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 20 |
| L01       | 15-Ton Pass-by | 17652652.2 | 4786882.7 | 1.5 | 0     | 61 | 11.7 | 2000 | 56.2 | 0.0 | -2.6 | 0.0  | 1.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by | 17652652.2 | 4786882.7 | 1.5 | 0     | 55 | 11.7 | 4000 | 56.2 | 0.0 | -2.6 | 0.0  | 6.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652686.8 | 4786858.6 | 1.5 | 0     | 52 | 8.0  | 125  | 56.7 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L01       | 15-Ton Pass-by | 17652686.8 | 4786858.6 | 1.5 | 0     | 57 | 8.0  | 250  | 56.7 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652686.8 | 4786858.6 | 1.5 | 0     | 63 | 8.0  | 500  | 56.7 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652686.8 | 4786858.6 | 1.5 | 0     | 63 | 8.0  | 1000 | 56.7 | 0.0 | -2.5 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652686.8 | 4786858.6 | 1.5 | 0     | 61 | 8.0  | 2000 | 56.7 | 0.0 | -2.5 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by | 17652686.8 | 4786858.6 | 1.5 | 0     | 55 | 8.0  | 4000 | 56.7 | 0.0 | -2.5 | 0.0  | 6.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by | 17652685.3 | 4786862.6 | 1.5 | 0     | 52 | 3.3  | 125  | 56.8 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L01       | 15-Ton Pass-by | 17652685.3 | 4786862.6 | 1.5 | 0     | 57 | 3.3  | 250  | 56.8 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L01       | 15-Ton Pass-by | 17652685.3 | 4786862.6 | 1.5 | 0     | 63 | 3.3  | 500  | 56.8 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652685.3 | 4786862.6 | 1.5 | 0     | 63 | 3.3  | 1000 | 56.8 | 0.0 | -2.5 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652685.3 | 4786862.6 | 1.5 | 0     | 61 | 3.3  | 2000 | 56.8 | 0.0 | -2.5 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L01       | 15-Ton Pass-by | 17652684.5 | 4786864.7 | 1.5 | 0     | 52 | 3.9  | 125  | 56.8 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L01       | 15-Ton Pass-by | 17652684.5 | 4786864.7 | 1.5 | 0     | 57 | 3.9  | 250  | 56.8 | 0.0 | -2.5 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L01       | 15-Ton Pass-by | 17652684.5 | 4786864.7 | 1.5 | 0     | 63 | 3.9  | 500  | 56.8 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by | 17652684.5 | 4786864.7 | 1.5 | 0     | 63 | 3.9  | 1000 | 56.8 | 0.0 | -2.5 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by | 17652684.5 | 4786864.7 | 1.5 | 0     | 61 | 3.9  | 2000 | 56.8 | 0.0 | -2.5 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L01       | 15-Ton Pass-by | 17652680.6 | 4786874.6 | 1.5 | 0     | 52 | 4.9  | 125  | 56.9 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L01       | 15-Ton Pass-by | 17652680.6 | 4786874.6 | 1.5 | 0     | 57 | 4.9  | 250  | 56.9 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by | 17652680.6 | 4786874.6 | 1.5 | 0     | 63 | 4.9  | 500  | 56.9 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by | 17652680.6 | 4786874.6 | 1.5 | 0     | 63 | 4.9  | 1000 | 56.9 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by | 17652680.6 | 4786874.6 | 1.5 | 0     | 61 | 4.9  | 2000 | 56.9 | 0.0 | -2.6 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 52 | 7.7  | 125  | 57.0 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 57 | 7.7  | 250  | 57.0 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 63 | 7.7  | 500  | 57.0 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 16 |
| L01       | 15-Ton Pass-by | 17652678.6 | 4786878.6 | 1.5 | 0     | 63 | 7.7  | 1000 | 57.0 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L01       | 15-Ton Pass-by   | 17652678.6 | 4786878.6 | 1.5 | 0     | 61 | 7.7  | 2000 | 57.0 | 0.0 | -2.6 | 0.0  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L01       | 15-Ton Pass-by   | 17652678.6 | 4786878.6 | 1.5 | 0     | 55 | 7.7  | 4000 | 57.0 | 0.0 | -2.6 | 0.0  | 6.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L01       | 15-Ton Pass-by   | 17652677.0 | 4786882.0 | 1.5 | 0     | 57 | 1.9  | 250  | 57.0 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L01       | 15-Ton Pass-by   | 17652677.0 | 4786882.0 | 1.5 | 0     | 63 | 1.9  | 500  | 57.0 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L01       | 15-Ton Pass-by   | 17652677.0 | 4786882.0 | 1.5 | 0     | 63 | 1.9  | 1000 | 57.0 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L01       | 15-Ton Pass-by   | 17652677.0 | 4786882.0 | 1.5 | 0     | 61 | 1.9  | 2000 | 57.0 | 0.0 | -2.7 | 0.0  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L01       | 15-Ton Pass-by   | 17652682.7 | 4786869.5 | 1.5 | 0     | 52 | 8.9  | 125  | 56.9 | 0.0 | -2.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L01       | 15-Ton Pass-by   | 17652682.7 | 4786869.5 | 1.5 | 0     | 57 | 8.9  | 250  | 56.9 | 0.0 | -2.6 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L01       | 15-Ton Pass-by   | 17652682.7 | 4786869.5 | 1.5 | 0     | 63 | 8.9  | 500  | 56.9 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by   | 17652682.7 | 4786869.5 | 1.5 | 0     | 63 | 8.9  | 1000 | 56.9 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 17 |
| L01       | 15-Ton Pass-by   | 17652682.7 | 4786869.5 | 1.5 | 0     | 61 | 8.9  | 2000 | 56.9 | 0.0 | -2.6 | 0.0  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L01       | 15-Ton Pass-by   | 17652682.7 | 4786869.5 | 1.5 | 0     | 55 | 8.9  | 4000 | 56.9 | 0.0 | -2.6 | 0.0  | 6.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652650.5 | 4786967.3 | 1.5 | 0     | 41 | 15.4 | 63   | 59.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652650.5 | 4786967.3 | 1.5 | 0     | 52 | 15.4 | 125  | 59.0 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652650.5 | 4786967.3 | 1.5 | 0     | 57 | 15.4 | 250  | 59.0 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L02       | 15-Ton Pass-by 2 | 17652650.5 | 4786967.3 | 1.5 | 0     | 63 | 15.4 | 500  | 59.0 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 22 |
| L02       | 15-Ton Pass-by 2 | 17652650.5 | 4786967.3 | 1.5 | 0     | 63 | 15.4 | 1000 | 59.0 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 21 |
| L02       | 15-Ton Pass-by 2 | 17652650.5 | 4786967.3 | 1.5 | 0     | 61 | 15.4 | 2000 | 59.0 | 0.0 | -2.9 | 0.0  | 2.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652650.5 | 4786967.3 | 1.5 | 0     | 55 | 15.4 | 4000 | 59.0 | 0.0 | -2.9 | 0.0  | 8.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652631.1 | 4786966.4 | 1.5 | 0     | 52 | 5.9  | 125  | 58.7 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652631.1 | 4786966.4 | 1.5 | 0     | 57 | 5.9  | 250  | 58.7 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652631.1 | 4786966.4 | 1.5 | 0     | 63 | 5.9  | 500  | 58.7 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652631.1 | 4786966.4 | 1.5 | 0     | 63 | 5.9  | 1000 | 58.7 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652631.1 | 4786966.4 | 1.5 | 0     | 61 | 5.9  | 2000 | 58.7 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4786966.2 | 1.5 | 0     | 52 | 7.7  | 125  | 58.6 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4786966.2 | 1.5 | 0     | 57 | 7.7  | 250  | 58.6 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4786966.2 | 1.5 | 0     | 63 | 7.7  | 500  | 58.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4786966.2 | 1.5 | 0     | 63 | 7.7  | 1000 | 58.6 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652626.2 | 4786966.2 | 1.5 | 0     | 61 | 7.7  | 2000 | 58.6 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 52 | 7.0  | 125  | 58.5 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 57 | 7.0  | 250  | 58.5 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 63 | 7.0  | 500  | 58.5 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 63 | 7.0  | 1000 | 58.5 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652620.7 | 4786965.9 | 1.5 | 0     | 61 | 7.0  | 2000 | 58.5 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652612.8 | 4786965.5 | 1.5 | 0     | 57 | 10.4 | 250  | 58.4 | 0.0 | -2.9 | 7.7  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652612.8 | 4786965.5 | 1.5 | 0     | 63 | 10.4 | 500  | 58.4 | 0.0 | -2.9 | 7.7  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652612.8 | 4786965.5 | 1.5 | 0     | 63 | 10.4 | 1000 | 58.4 | 0.0 | -2.9 | 7.7  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652612.8 | 4786965.5 | 1.5 | 0     | 61 | 10.4 | 2000 | 58.4 | 0.0 | -2.9 | 7.7  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652606.4 | 4786965.2 | 1.5 | 0     | 57 | 2.5  | 250  | 58.3 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652606.4 | 4786965.2 | 1.5 | 0     | 63 | 2.5  | 500  | 58.3 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652606.4 | 4786965.2 | 1.5 | 0     | 63 | 2.5  | 1000 | 58.3 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652606.4 | 4786965.2 | 1.5 | 0     | 61 | 2.5  | 2000 | 58.3 | 0.0 | -3.0 | 0.0  | 2.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652601.7 | 4786965.0 | 1.5 | 0     | 52 | 8.9  | 125  | 58.2 | 0.0 | -3.0 | 3.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2 | 17652601.7 | 4786965.0 | 1.5 | 0     | 57 | 8.9  | 250  | 58.2 | 0.0 | -3.0 | 3.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652601.7 | 4786965.0 | 1.5 | 0     | 63 | 8.9  | 500  | 58.2 | 0.0 | -3.0 | 3.1  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652601.7 | 4786965.0 | 1.5 | 0     | 63 | 8.9  | 1000 | 58.2 | 0.0 | -3.0 | 3.2  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652601.7 | 4786965.0 | 1.5 | 0     | 61 | 8.9  | 2000 | 58.2 | 0.0 | -3.0 | 3.4  | 2.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652597.2 | 4786964.8 | 1.5 | 0     | 63 | 0.8  | 500  | 58.1 | 0.0 | -3.0 | 3.4  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652597.2 | 4786964.8 | 1.5 | 0     | 63 | 0.8  | 1000 | 58.1 | 0.0 | -3.0 | 3.8  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652587.3 | 4786964.3 | 1.5 | 0     | 52 | 12.7 | 125  | 58.0 | 0.0 | -3.0 | 7.9  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652587.3 | 4786964.3 | 1.5 | 0     | 57 | 12.7 | 250  | 58.0 | 0.0 | -3.0 | 8.1  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652587.3 | 4786964.3 | 1.5 | 0     | 63 | 12.7 | 500  | 58.0 | 0.0 | -3.0 | 8.4  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652587.3 | 4786964.3 | 1.5 | 0     | 63 | 12.7 | 1000 | 58.0 | 0.0 | -3.0 | 8.9  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652587.3 | 4786964.3 | 1.5 | 0     | 61 | 12.7 | 2000 | 58.0 | 0.0 | -3.0 | 9.8  | 2.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4786963.7 | 1.5 | 0     | 57 | 9.2  | 250  | 57.9 | 0.0 | -3.0 | 8.4  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4786963.7 | 1.5 | 0     | 63 | 9.2  | 500  | 57.9 | 0.0 | -3.0 | 8.9  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4786963.7 | 1.5 | 0     | 63 | 9.2  | 1000 | 57.9 | 0.0 | -3.0 | 9.8  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652573.9 | 4786963.7 | 1.5 | 0     | 61 | 9.2  | 2000 | 57.9 | 0.0 | -3.0 | 11.2 | 2.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652565.1 | 4786963.3 | 1.5 | 0     | 57 | 9.7  | 250  | 57.8 | 0.0 | -3.0 | 8.5  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652565.1 | 4786963.3 | 1.5 | 0     | 63 | 9.7  | 500  | 57.8 | 0.0 | -3.0 | 9.2  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652565.1 | 4786963.3 | 1.5 | 0     | 63 | 9.7  | 1000 | 57.8 | 0.0 | -3.0 | 10.3 | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652565.1 | 4786963.3 | 1.5 | 0     | 61 | 9.7  | 2000 | 57.8 | 0.0 | -3.0 | 11.8 | 2.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652558.6 | 4786963.0 | 1.5 | 0     | 63 | 5.8  | 500  | 57.7 | 0.0 | -2.9 | 11.1 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652544.8 | 4786962.3 | 1.5 | 0     | 52 | 13.8 | 125  | 57.7 | 0.0 | -2.7 | 8.7  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652544.8 | 4786962.3 | 1.5 | 0     | 57 | 13.8 | 250  | 57.7 | 0.0 | -2.7 | 9.7  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652544.8 | 4786962.3 | 1.5 | 0     | 63 | 13.8 | 500  | 57.7 | 0.0 | -2.7 | 11.2 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652544.8 | 4786962.3 | 1.5 | 0     | 63 | 13.8 | 1000 | 57.7 | 0.0 | -2.7 | 13.2 | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652544.8 | 4786962.3 | 1.5 | 0     | 61 | 13.8 | 2000 | 57.7 | 0.0 | -2.7 | 15.5 | 2.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652531.5 | 4786961.7 | 1.5 | 0     | 63 | 4.5  | 500  | 57.6 | 0.0 | -2.6 | 10.4 | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652526.5 | 4786961.5 | 1.5 | 0     | 52 | 8.6  | 125  | 57.6 | 0.0 | -2.6 | 5.3  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652526.5 | 4786961.5 | 1.5 | 0     | 57 | 8.6  | 250  | 57.6 | 0.0 | -2.6 | 6.4  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652526.5 | 4786961.5 | 1.5 | 0     | 63 | 8.6  | 500  | 57.6 | 0.0 | -2.6 | 7.1  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652526.5 | 4786961.5 | 1.5 | 0     | 63 | 8.6  | 1000 | 57.6 | 0.0 | -2.6 | 7.6  | 0.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652526.5 | 4786961.5 | 1.5 | 0     | 61 | 8.6  | 2000 | 57.6 | 0.0 | -2.6 | 8.3  | 2.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652587.8 | 4787019.9 | 1.5 | 0     | 52 | 7.5  | 125  | 59.9 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652587.8 | 4787019.9 | 1.5 | 0     | 57 | 7.5  | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652587.8 | 4787019.9 | 1.5 | 0     | 63 | 7.5  | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652587.8 | 4787019.9 | 1.5 | 0     | 63 | 7.5  | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 12 |
| L02       | 15-Ton Pass-by 2 | 17652587.8 | 4787019.9 | 1.5 | 0     | 61 | 7.5  | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652602.5 | 4787020.4 | 1.5 | 0     | 52 | 13.7 | 125  | 60.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652602.5 | 4787020.4 | 1.5 | 0     | 57 | 13.7 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2 | 17652602.5 | 4787020.4 | 1.5 | 0     | 63 | 13.7 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 19 |
| L02       | 15-Ton Pass-by 2 | 17652602.5 | 4787020.4 | 1.5 | 0     | 63 | 13.7 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2 | 17652602.5 | 4787020.4 | 1.5 | 0     | 61 | 13.7 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652602.5 | 4787020.4 | 1.5 | 0     | 55 | 13.7 | 4000 | 60.0 | 0.0 | -3.0 | 0.0  | 9.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652614.9 | 4787020.9 | 1.5 | 0     | 57 | 1.0  | 250  | 60.1 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name      | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc  | RL  | Lr |
|-----------|------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2 | 17652614.9 | 4787020.9 | 1.5 | 0     | 63 | 1.0  | 500  | 60.1 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652614.9 | 4787020.9 | 1.5 | 0     | 63 | 1.0  | 1000 | 60.1 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652614.9 | 4787020.9 | 1.5 | 0     | 61 | 1.0  | 2000 | 60.1 | 0.0 | -3.0 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652621.5 | 4787021.1 | 1.5 | 0     | 52 | 10.7 | 125  | 60.2 | 0.0 | -3.0 | 5.4  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652621.5 | 4787021.1 | 1.5 | 0     | 57 | 10.7 | 250  | 60.2 | 0.0 | -3.0 | 6.3  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652621.5 | 4787021.1 | 1.5 | 0     | 63 | 10.7 | 500  | 60.2 | 0.0 | -3.0 | 7.3  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652621.5 | 4787021.1 | 1.5 | 0     | 63 | 10.7 | 1000 | 60.2 | 0.0 | -3.0 | 8.4  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652621.5 | 4787021.1 | 1.5 | 0     | 61 | 10.7 | 2000 | 60.2 | 0.0 | -3.0 | 9.8  | 2.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652637.4 | 4787021.7 | 1.5 | 0     | 57 | 13.0 | 250  | 60.4 | 0.0 | -2.9 | 8.1  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652637.4 | 4787021.7 | 1.5 | 0     | 63 | 13.0 | 500  | 60.4 | 0.0 | -2.9 | 8.5  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652637.4 | 4787021.7 | 1.5 | 0     | 63 | 13.0 | 1000 | 60.4 | 0.0 | -2.9 | 9.2  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2 | 17652637.4 | 4787021.7 | 1.5 | 0     | 61 | 13.0 | 2000 | 60.4 | 0.0 | -2.9 | 10.4 | 2.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652649.2 | 4787022.1 | 1.5 | 0     | 63 | 5.6  | 500  | 60.5 | 0.0 | -2.9 | 8.5  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652649.2 | 4787022.1 | 1.5 | 0     | 63 | 5.6  | 1000 | 60.5 | 0.0 | -2.9 | 9.2  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652652.9 | 4787022.3 | 1.5 | 0     | 63 | 5.8  | 500  | 60.6 | 0.0 | -2.9 | 8.5  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652652.9 | 4787022.3 | 1.5 | 0     | 63 | 5.8  | 1000 | 60.6 | 0.0 | -2.9 | 9.2  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652656.9 | 4787022.4 | 1.5 | 0     | 63 | 6.1  | 500  | 60.6 | 0.0 | -2.9 | 8.5  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652656.9 | 4787022.4 | 1.5 | 0     | 63 | 6.1  | 1000 | 60.6 | 0.0 | -2.9 | 9.2  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652674.1 | 4787023.0 | 1.5 | 0     | 52 | 14.8 | 125  | 60.9 | 0.0 | -2.9 | 7.9  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652674.1 | 4787023.0 | 1.5 | 0     | 57 | 14.8 | 250  | 60.9 | 0.0 | -2.9 | 8.1  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652674.1 | 4787023.0 | 1.5 | 0     | 63 | 14.8 | 500  | 60.9 | 0.0 | -2.9 | 8.5  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652674.1 | 4787023.0 | 1.5 | 0     | 63 | 14.8 | 1000 | 60.9 | 0.0 | -2.9 | 9.2  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652674.1 | 4787023.0 | 1.5 | 0     | 61 | 14.8 | 2000 | 60.9 | 0.0 | -2.9 | 10.3 | 3.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652692.3 | 4787004.1 | 1.5 | 0     | 52 | 13.4 | 125  | 60.7 | 0.0 | -2.9 | 5.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2 | 17652692.3 | 4787004.1 | 1.5 | 0     | 57 | 13.4 | 250  | 60.7 | 0.0 | -2.9 | 5.9  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652692.3 | 4787004.1 | 1.5 | 0     | 63 | 13.4 | 500  | 60.7 | 0.0 | -2.9 | 6.7  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652692.3 | 4787004.1 | 1.5 | 0     | 63 | 13.4 | 1000 | 60.7 | 0.0 | -2.9 | 7.5  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L02       | 15-Ton Pass-by 2 | 17652692.3 | 4787004.1 | 1.5 | 0     | 61 | 13.4 | 2000 | 60.7 | 0.0 | -2.9 | 8.4  | 2.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652691.4 | 4786988.1 | 1.5 | 0     | 52 | 10.1 | 125  | 60.2 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652691.4 | 4786988.1 | 1.5 | 0     | 57 | 10.1 | 250  | 60.2 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2 | 17652691.4 | 4786988.1 | 1.5 | 0     | 63 | 10.1 | 500  | 60.2 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 15 |
| L02       | 15-Ton Pass-by 2 | 17652691.4 | 4786988.1 | 1.5 | 0     | 63 | 10.1 | 1000 | 60.2 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2 | 17652691.4 | 4786988.1 | 1.5 | 0     | 61 | 10.1 | 2000 | 60.2 | 0.0 | -2.9 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L02       | 15-Ton Pass-by 2 | 17652691.0 | 4786981.8 | 1.5 | 0     | 57 | 3.9  | 250  | 60.1 | 0.0 | -2.9 | 3.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2 | 17652691.0 | 4786981.8 | 1.5 | 0     | 63 | 3.9  | 500  | 60.1 | 0.0 | -2.9 | 3.1  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652691.0 | 4786981.8 | 1.5 | 0     | 63 | 3.9  | 1000 | 60.1 | 0.0 | -2.9 | 3.2  | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2 | 17652691.0 | 4786981.8 | 1.5 | 0     | 61 | 3.9  | 2000 | 60.1 | 0.0 | -2.9 | 3.4  | 2.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786978.6 | 1.5 | 0     | 57 | 6.1  | 250  | 60.0 | 0.0 | -2.9 | 3.7  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786978.6 | 1.5 | 0     | 63 | 6.1  | 500  | 60.0 | 0.0 | -2.9 | 4.2  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786978.6 | 1.5 | 0     | 63 | 6.1  | 1000 | 60.0 | 0.0 | -2.9 | 4.9  | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2 | 17652690.8 | 4786978.6 | 1.5 | 0     | 61 | 6.1  | 2000 | 60.0 | 0.0 | -2.9 | 5.6  | 2.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2 | 17652569.8 | 4787043.3 | 1.5 | 0     | 57 | 8.4  | 250  | 60.5 | 0.0 | -2.9 | 3.4  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2 | 17652569.8 | 4787043.3 | 1.5 | 0     | 63 | 8.4  | 500  | 60.5 | 0.0 | -2.9 | 3.8  | 0.6  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| L02       | 15-Ton Pass-by 2              | 17652569.8 | 4787043.3 | 1.5 | 0     | 63 | 8.4  | 1000 | 60.5 | 0.0 | -2.9 | 4.4  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652569.8 | 4787043.3 | 1.5 | 0     | 61 | 8.4  | 2000 | 60.5 | 0.0 | -2.9 | 5.1  | 2.9  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652572.4 | 4787039.2 | 1.5 | 0     | 57 | 4.4  | 250  | 60.4 | 0.0 | -2.9 | 3.3  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652572.4 | 4787039.2 | 1.5 | 0     | 63 | 4.4  | 500  | 60.4 | 0.0 | -2.9 | 3.6  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2              | 17652572.4 | 4787039.2 | 1.5 | 0     | 63 | 4.4  | 1000 | 60.4 | 0.0 | -2.9 | 4.0  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652572.4 | 4787039.2 | 1.5 | 0     | 61 | 4.4  | 2000 | 60.4 | 0.0 | -2.9 | 4.7  | 2.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652577.3 | 4787031.7 | 1.5 | 0     | 52 | 11.8 | 125  | 60.2 | 0.0 | -3.0 | 3.1  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652577.3 | 4787031.7 | 1.5 | 0     | 57 | 11.8 | 250  | 60.2 | 0.0 | -3.0 | 3.1  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652577.3 | 4787031.7 | 1.5 | 0     | 63 | 11.8 | 500  | 60.2 | 0.0 | -3.0 | 3.2  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2              | 17652577.3 | 4787031.7 | 1.5 | 0     | 63 | 11.8 | 1000 | 60.2 | 0.0 | -3.0 | 3.4  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2              | 17652577.3 | 4787031.7 | 1.5 | 0     | 61 | 11.8 | 2000 | 60.2 | 0.0 | -3.0 | 3.8  | 2.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2              | 17652582.6 | 4787023.4 | 1.5 | 0     | 57 | 6.6  | 250  | 60.0 | 0.0 | -3.0 | 3.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652582.6 | 4787023.4 | 1.5 | 0     | 63 | 6.6  | 500  | 60.0 | 0.0 | -3.0 | 3.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |
| L02       | 15-Ton Pass-by 2              | 17652582.6 | 4787023.4 | 1.5 | 0     | 63 | 6.6  | 1000 | 60.0 | 0.0 | -3.0 | 3.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652582.6 | 4787023.4 | 1.5 | 0     | 61 | 6.6  | 2000 | 60.0 | 0.0 | -3.0 | 3.0  | 2.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652584.4 | 4787020.6 | 1.5 | 0     | 57 | 3.1  | 250  | 59.9 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| L02       | 15-Ton Pass-by 2              | 17652584.4 | 4787020.6 | 1.5 | 0     | 63 | 3.1  | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652584.4 | 4787020.6 | 1.5 | 0     | 63 | 3.1  | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652584.4 | 4787020.6 | 1.5 | 0     | 61 | 3.1  | 2000 | 59.9 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652688.9 | 4786975.9 | 1.5 | 0     | 57 | 5.7  | 250  | 59.9 | 0.0 | -2.9 | 3.7  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652688.9 | 4786975.9 | 1.5 | 0     | 63 | 5.7  | 500  | 59.9 | 0.0 | -2.9 | 4.2  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 7  |
| L02       | 15-Ton Pass-by 2              | 17652688.9 | 4786975.9 | 1.5 | 0     | 63 | 5.7  | 1000 | 59.9 | 0.0 | -2.9 | 4.9  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652688.9 | 4786975.9 | 1.5 | 0     | 61 | 5.7  | 2000 | 59.9 | 0.0 | -2.9 | 5.7  | 2.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652686.2 | 4786974.9 | 1.5 | 0     | 57 | 3.3  | 250  | 59.8 | 0.0 | -2.9 | 3.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 0  |
| L02       | 15-Ton Pass-by 2              | 17652686.2 | 4786974.9 | 1.5 | 0     | 63 | 3.3  | 500  | 59.8 | 0.0 | -2.9 | 3.1  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 6  |
| L02       | 15-Ton Pass-by 2              | 17652686.2 | 4786974.9 | 1.5 | 0     | 63 | 3.3  | 1000 | 59.8 | 0.0 | -2.9 | 3.2  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 5  |
| L02       | 15-Ton Pass-by 2              | 17652686.2 | 4786974.9 | 1.5 | 0     | 61 | 3.3  | 2000 | 59.8 | 0.0 | -2.9 | 3.5  | 2.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652676.5 | 4786971.3 | 1.5 | 0     | 52 | 12.7 | 125  | 59.6 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 8  |
| L02       | 15-Ton Pass-by 2              | 17652676.5 | 4786971.3 | 1.5 | 0     | 57 | 12.7 | 250  | 59.6 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 13 |
| L02       | 15-Ton Pass-by 2              | 17652676.5 | 4786971.3 | 1.5 | 0     | 63 | 12.7 | 500  | 59.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2              | 17652676.5 | 4786971.3 | 1.5 | 0     | 63 | 12.7 | 1000 | 59.6 | 0.0 | -2.9 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 18 |
| L02       | 15-Ton Pass-by 2              | 17652676.5 | 4786971.3 | 1.5 | 0     | 61 | 12.7 | 2000 | 59.6 | 0.0 | -2.9 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 14 |
| L02       | 15-Ton Pass-by 2              | 17652676.5 | 4786971.3 | 1.5 | 0     | 55 | 12.7 | 4000 | 59.6 | 0.0 | -2.9 | 0.0  | 8.8  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652690.0 | 4787021.8 | 1.5 | 0     | 63 | 5.8  | 500  | 61.0 | 0.0 | -2.9 | 8.2  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| L02       | 15-Ton Pass-by 2              | 17652690.0 | 4787021.8 | 1.5 | 0     | 63 | 5.8  | 1000 | 61.0 | 0.0 | -2.9 | 8.6  | 1.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| L02       | 15-Ton Pass-by 2              | 17652691.9 | 4787017.5 | 1.5 | 0     | 63 | 7.5  | 500  | 61.0 | 0.0 | -2.9 | 7.9  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| L02       | 15-Ton Pass-by 2              | 17652691.9 | 4787017.5 | 1.5 | 0     | 63 | 7.5  | 1000 | 61.0 | 0.0 | -2.9 | 8.2  | 1.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 71 | 0.0  | 63   | 55.9 | 0.0 | -3.0 | 7.8  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 4  |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 84 | 0.0  | 125  | 55.9 | 0.0 | -2.6 | 7.4  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 17 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 91 | 0.0  | 250  | 55.9 | 0.0 | -2.6 | 7.4  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 24 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 500  | 55.9 | 0.0 | -2.6 | 7.4  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 29 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 98 | 0.0  | 1000 | 55.9 | 0.0 | -2.6 | 7.5  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 31 |
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 55.9 | 0.0 | -2.6 | 7.6  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 27 |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc  | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|------|------|-----|-----|----|
| S43       | 5 Ton Aggregate Loading Cycle | 17652654.9 | 4786871.5 | 1.0 | 0     | 89 | 0.0  | 4000 | 55.9 | 0.0 | -2.6 | 7.9  | 5.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 16 |
| L03       | 5-Ton Pass-by                 | 17652672.2 | 4786882.7 | 1.5 | 0     | 47 | 9.4  | 500  | 56.9 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652672.2 | 4786882.7 | 1.5 | 0     | 50 | 9.4  | 1000 | 56.9 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652672.2 | 4786882.7 | 1.5 | 0     | 47 | 9.4  | 2000 | 56.9 | 0.0 | -2.7 | 0.0  | 1.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L03       | 5-Ton Pass-by                 | 17652663.8 | 4786882.7 | 1.5 | 0     | 47 | 9.2  | 500  | 56.6 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L03       | 5-Ton Pass-by                 | 17652663.8 | 4786882.7 | 1.5 | 0     | 50 | 9.2  | 1000 | 56.6 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652663.8 | 4786882.7 | 1.5 | 0     | 47 | 9.2  | 2000 | 56.6 | 0.0 | -2.6 | 0.0  | 1.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L03       | 5-Ton Pass-by                 | 17652652.2 | 4786882.7 | 1.5 | 0     | 47 | 11.7 | 500  | 56.2 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L03       | 5-Ton Pass-by                 | 17652652.2 | 4786882.7 | 1.5 | 0     | 50 | 11.7 | 1000 | 56.2 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L03       | 5-Ton Pass-by                 | 17652652.2 | 4786882.7 | 1.5 | 0     | 47 | 11.7 | 2000 | 56.2 | 0.0 | -2.6 | 0.0  | 1.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L03       | 5-Ton Pass-by                 | 17652686.8 | 4786858.6 | 1.5 | 0     | 47 | 8.0  | 500  | 56.7 | 0.0 | -2.5 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L03       | 5-Ton Pass-by                 | 17652686.8 | 4786858.6 | 1.5 | 0     | 50 | 8.0  | 1000 | 56.7 | 0.0 | -2.5 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L03       | 5-Ton Pass-by                 | 17652680.6 | 4786874.6 | 1.5 | 0     | 50 | 4.9  | 1000 | 56.9 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L03       | 5-Ton Pass-by                 | 17652678.6 | 4786878.6 | 1.5 | 0     | 50 | 7.7  | 1000 | 57.0 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L03       | 5-Ton Pass-by                 | 17652682.7 | 4786869.5 | 1.5 | 0     | 47 | 8.9  | 500  | 56.9 | 0.0 | -2.6 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L03       | 5-Ton Pass-by                 | 17652682.7 | 4786869.5 | 1.5 | 0     | 50 | 8.9  | 1000 | 56.9 | 0.0 | -2.6 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2               | 17652650.5 | 4786967.3 | 1.5 | 0     | 45 | 15.4 | 250  | 59.0 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2               | 17652650.5 | 4786967.3 | 1.5 | 0     | 52 | 15.4 | 500  | 59.0 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2               | 17652650.5 | 4786967.3 | 1.5 | 0     | 55 | 15.4 | 1000 | 59.0 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 14 |
| L04       | 5-Ton Pass-by 2               | 17652650.5 | 4786967.3 | 1.5 | 0     | 52 | 15.4 | 2000 | 59.0 | 0.0 | -2.9 | 0.0  | 2.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 9  |
| L04       | 5-Ton Pass-by 2               | 17652650.5 | 4786967.3 | 1.5 | 0     | 49 | 15.4 | 4000 | 59.0 | 0.0 | -2.9 | 0.0  | 8.2  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652631.1 | 4786966.4 | 1.5 | 0     | 52 | 5.9  | 500  | 58.7 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2               | 17652631.1 | 4786966.4 | 1.5 | 0     | 55 | 5.9  | 1000 | 58.7 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2               | 17652626.2 | 4786966.2 | 1.5 | 0     | 52 | 7.7  | 500  | 58.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652626.2 | 4786966.2 | 1.5 | 0     | 55 | 7.7  | 1000 | 58.6 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652626.2 | 4786966.2 | 1.5 | 0     | 52 | 7.7  | 2000 | 58.6 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652620.7 | 4786965.9 | 1.5 | 0     | 52 | 7.0  | 500  | 58.5 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652620.7 | 4786965.9 | 1.5 | 0     | 55 | 7.0  | 1000 | 58.5 | 0.0 | -2.9 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |
| L04       | 5-Ton Pass-by 2               | 17652620.7 | 4786965.9 | 1.5 | 0     | 52 | 7.0  | 2000 | 58.5 | 0.0 | -2.9 | 0.0  | 2.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2               | 17652612.8 | 4786965.5 | 1.5 | 0     | 55 | 10.4 | 1000 | 58.4 | 0.0 | -2.9 | 7.7  | 0.9  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652606.4 | 4786965.2 | 1.5 | 0     | 55 | 2.5  | 1000 | 58.3 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652601.7 | 4786965.0 | 1.5 | 0     | 52 | 8.9  | 500  | 58.2 | 0.0 | -3.0 | 3.1  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652601.7 | 4786965.0 | 1.5 | 0     | 55 | 8.9  | 1000 | 58.2 | 0.0 | -3.0 | 3.2  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652587.3 | 4786964.3 | 1.5 | 0     | 52 | 12.7 | 500  | 58.0 | 0.0 | -3.0 | 8.4  | 0.4  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652587.3 | 4786964.3 | 1.5 | 0     | 55 | 12.7 | 1000 | 58.0 | 0.0 | -3.0 | 8.9  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 3  |
| L04       | 5-Ton Pass-by 2               | 17652544.8 | 4786962.3 | 1.5 | 0     | 55 | 13.8 | 1000 | 57.7 | 0.0 | -2.7 | 13.2 | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652526.5 | 4786961.5 | 1.5 | 0     | 55 | 8.6  | 1000 | 57.6 | 0.0 | -2.6 | 7.6  | 0.8  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2               | 17652587.8 | 4787019.9 | 1.5 | 0     | 52 | 7.5  | 500  | 59.9 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652587.8 | 4787019.9 | 1.5 | 0     | 55 | 7.5  | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2               | 17652602.5 | 4787020.4 | 1.5 | 0     | 45 | 13.7 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2               | 17652602.5 | 4787020.4 | 1.5 | 0     | 52 | 13.7 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 8  |
| L04       | 5-Ton Pass-by 2               | 17652602.5 | 4787020.4 | 1.5 | 0     | 55 | 13.7 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 11 |
| L04       | 5-Ton Pass-by 2               | 17652602.5 | 4787020.4 | 1.5 | 0     | 52 | 13.7 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | 0.0 | 0.0 | 6  |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name          | X          | Y         | Z   | Refl. | Lw | L/A  | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|----------------------|------------|-----------|-----|-------|----|------|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| L04       | 5-Ton Pass-by 2      | 17652637.4 | 4787021.7 | 1.5 | 0     | 55 | 13.0 | 1000 | 60.4 | 0.0 | -2.9 | 9.2  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652674.1 | 4787023.0 | 1.5 | 0     | 55 | 14.8 | 1000 | 60.9 | 0.0 | -2.9 | 9.2  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652692.3 | 4787004.1 | 1.5 | 0     | 55 | 13.4 | 1000 | 60.7 | 0.0 | -2.9 | 7.5  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652691.4 | 4786988.1 | 1.5 | 0     | 52 | 10.1 | 500  | 60.2 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 4  |
| L04       | 5-Ton Pass-by 2      | 17652691.4 | 4786988.1 | 1.5 | 0     | 55 | 10.1 | 1000 | 60.2 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652691.4 | 4786988.1 | 1.5 | 0     | 52 | 10.1 | 2000 | 60.2 | 0.0 | -2.9 | 0.0  | 2.8  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652569.8 | 4787043.3 | 1.5 | 0     | 55 | 8.4  | 1000 | 60.5 | 0.0 | -2.9 | 4.4  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2      | 17652577.3 | 4787031.7 | 1.5 | 0     | 52 | 11.8 | 500  | 60.2 | 0.0 | -3.0 | 3.2  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 2  |
| L04       | 5-Ton Pass-by 2      | 17652577.3 | 4787031.7 | 1.5 | 0     | 55 | 11.8 | 1000 | 60.2 | 0.0 | -3.0 | 3.4  | 1.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |
| L04       | 5-Ton Pass-by 2      | 17652582.6 | 4787023.4 | 1.5 | 0     | 55 | 6.6  | 1000 | 60.0 | 0.0 | -3.0 | 3.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2      | 17652584.4 | 4787020.6 | 1.5 | 0     | 55 | 3.1  | 1000 | 59.9 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 0  |
| L04       | 5-Ton Pass-by 2      | 17652676.5 | 4786971.3 | 1.5 | 0     | 45 | 12.7 | 250  | 59.6 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 1  |
| L04       | 5-Ton Pass-by 2      | 17652676.5 | 4786971.3 | 1.5 | 0     | 52 | 12.7 | 500  | 59.6 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| L04       | 5-Ton Pass-by 2      | 17652676.5 | 4786971.3 | 1.5 | 0     | 55 | 12.7 | 1000 | 59.6 | 0.0 | -2.9 | 0.0  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 10 |
| L04       | 5-Ton Pass-by 2      | 17652676.5 | 4786971.3 | 1.5 | 0     | 52 | 12.7 | 2000 | 59.6 | 0.0 | -2.9 | 0.0  | 2.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 62 | 0.0  | 63   | 60.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 3  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 70 | 0.0  | 125  | 60.9 | 0.0 | -2.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 7  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 72 | 0.0  | 250  | 60.9 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 4  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 79 | 0.0  | 500  | 60.9 | 0.0 | -2.5 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 10 |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 76 | 0.0  | 1000 | 60.9 | 0.0 | -2.5 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 5  |
| S39       | Cooling Tower        | 17652315.3 | 4786518.2 | 5.5 | 0     | 75 | 0.0  | 2000 | 60.9 | 0.0 | -2.5 | 0.0  | 3.0  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 1  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 67 | 0.0  | 63   | 56.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 7  |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 80 | 0.0  | 125  | 56.8 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 20 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 250  | 56.8 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 24 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 91 | 0.0  | 500  | 56.8 | 0.0 | -2.7 | 0.0  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 30 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 92 | 0.0  | 1000 | 56.8 | 0.0 | -2.7 | 0.0  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 31 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 90 | 0.0  | 2000 | 56.8 | 0.0 | -2.7 | 0.0  | 1.9  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 28 |
| S40       | Dirt Loading Cycle   | 17652658.2 | 4786894.8 | 1.0 | 0     | 85 | 0.0  | 4000 | 56.8 | 0.0 | -2.7 | 0.0  | 6.4  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 18 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 68 | 0.0  | 63   | 55.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 9  |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 81 | 0.0  | 125  | 55.9 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 22 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 90 | 0.0  | 250  | 55.9 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 30 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 500  | 55.9 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 37 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 97 | 0.0  | 1000 | 55.9 | 0.0 | -2.7 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 37 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 96 | 0.0  | 2000 | 55.9 | 0.0 | -2.7 | 0.0  | 1.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 35 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 92 | 0.0  | 4000 | 55.9 | 0.0 | -2.7 | 0.0  | 5.7  | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 27 |
| S41       | Gravel Loading Cycle | 17652634.1 | 4786887.5 | 1.0 | 0     | 85 | 0.0  | 8000 | 55.9 | 0.0 | -2.7 | 0.0  | 20.5 | 0.0  | 0.0   | 0.0  | 0.0   | 0.0 | 5  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 67 | 0.0  | 63   | 59.0 | 0.0 | -3.0 | 4.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 6  |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 80 | 0.0  | 125  | 59.0 | 0.0 | -1.4 | 3.9  | 0.1  | 0.0  | 0.0   | 0.0  | -4.6  | 0.0 | 14 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 84 | 0.0  | 250  | 59.0 | 0.0 | -2.1 | 5.4  | 0.3  | 0.0  | 0.0   | 0.0  | -8.6  | 0.0 | 13 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 87 | 0.0  | 500  | 59.0 | 0.0 | -2.3 | 6.3  | 0.5  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 14 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 89 | 0.0  | 1000 | 59.0 | 0.0 | -2.3 | 6.7  | 0.9  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 14 |
| S15       | HVAC RTU             | 17652538.8 | 4786997.8 | 5.5 | 0     | 85 | 0.0  | 2000 | 59.0 | 0.0 | -2.3 | 6.9  | 2.4  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 7  |
| S17       | HVAC RTU             | 17652582.9 | 4786894.7 | 5.5 | 0     | 76 | 0.0  | 125  | 54.9 | 0.0 | -2.8 | 3.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.4  | 0.0 | 16 |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0 | 250  | 54.9 | 0.0 | -2.9 | 3.1  | 0.2  | 0.0  | 0.0  | 0.0  | -8.4  | 0.0 | 15 |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 84 | 0.0 | 500  | 54.9 | 0.0 | -2.9 | 3.1  | 0.3  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 54.9 | 0.0 | -2.9 | 3.3  | 0.6  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 16 |
| S17       | HVAC RTU    | 17652582.9 | 4786894.7 | 5.5 | 0     | 79 | 0.0 | 2000 | 54.9 | 0.0 | -2.9 | 3.6  | 1.5  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 10 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 67 | 0.0 | 63   | 59.9 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 80 | 0.0 | 125  | 59.9 | 0.0 | -2.7 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 18 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 84 | 0.0 | 250  | 59.9 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 18 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 87 | 0.0 | 500  | 59.9 | 0.0 | -2.8 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.9 | 0.0 | -2.8 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |
| S08       | HVAC RTU    | 17652671.6 | 4786985.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 59.9 | 0.0 | -2.8 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 14 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 72 | 0.0 | 250  | 59.1 | 0.0 | -2.3 | 5.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.6  | 0.0 | 2  |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 84 | 0.0 | 500  | 59.1 | 0.0 | -2.5 | 6.1  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 11 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 59.1 | 0.0 | -2.5 | 6.6  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 14 |
| S14       | HVAC RTU    | 17652545.1 | 4787000.3 | 5.5 | 0     | 87 | 0.0 | 2000 | 59.1 | 0.0 | -2.5 | 6.9  | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 9  |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 76 | 0.0 | 125  | 55.1 | 0.0 | -2.5 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.4  | 0.0 | 19 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 250  | 55.1 | 0.0 | -2.7 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -8.4  | 0.0 | 18 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 84 | 0.0 | 500  | 55.1 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 22 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 55.1 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 19 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 55.1 | 0.0 | -2.8 | 0.0  | 1.6  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 13 |
| S16       | HVAC RTU    | 17652589.2 | 4786896.6 | 5.5 | 0     | 73 | 0.0 | 4000 | 55.1 | 0.0 | -2.8 | 0.0  | 5.3  | 0.0  | 0.0  | 0.0  | -12.9 | 0.0 | 3  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 67 | 0.0 | 63   | 60.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.0 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 18 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.0 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 18 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 87 | 0.0 | 500  | 60.0 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.0 | 0.0 | -3.0 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |
| S26       | HVAC RTU    | 17652295.7 | 4786588.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.0 | 0.0 | -3.0 | 0.0  | 2.7  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 14 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 67 | 0.0 | 63   | 60.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 80 | 0.0 | 125  | 60.1 | 0.0 | -2.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 17 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 84 | 0.0 | 250  | 60.1 | 0.0 | -2.5 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 18 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 87 | 0.0 | 500  | 60.1 | 0.0 | -2.6 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.1 | 0.0 | -2.6 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |
| S35       | HVAC RTU    | 17652724.4 | 4786956.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.1 | 0.0 | -2.6 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 13 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 67 | 0.0 | 63   | 60.1 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 80 | 0.0 | 125  | 60.1 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 18 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 84 | 0.0 | 250  | 60.1 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 18 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 87 | 0.0 | 500  | 60.1 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.1 | 0.0 | -2.9 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |
| S11       | HVAC RTU    | 17652661.7 | 4787001.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.1 | 0.0 | -2.9 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 13 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 67 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 9  |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 18 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 18 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 19 |
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 20 |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S10       | HVAC RTU    | 17652667.8 | 4787001.4 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -2.9 | 0.0  | 2.8  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 13 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 67 | 0.0 | 63   | 60.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 9  |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 80 | 0.0 | 125  | 60.2 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 84 | 0.0 | 250  | 60.2 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 18 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 87 | 0.0 | 500  | 60.2 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 19 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.2 | 0.0 | -3.0 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 20 |
| S27       | HVAC RTU    | 17652296.3 | 4786576.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 60.2 | 0.0 | -3.0 | 0.0  | 2.8  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 13 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 67 | 0.0 | 63   | 61.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 8  |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.0 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 17 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 84 | 0.0 | 250  | 61.0 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 17 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 87 | 0.0 | 500  | 61.0 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 18 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.0 | 0.0 | -2.8 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 19 |
| S34       | HVAC RTU    | 17652772.1 | 4786953.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.0 | 0.0 | -2.8 | 0.0  | 3.1  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 12 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 72 | 0.0 | 250  | 60.3 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 6  |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 84 | 0.0 | 500  | 60.3 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 16 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.3 | 0.0 | -3.0 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 20 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 87 | 0.0 | 2000 | 60.3 | 0.0 | -3.0 | 0.0  | 2.8  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 15 |
| S25       | HVAC RTU    | 17652250.3 | 4786658.2 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.3 | 0.0 | -3.0 | 0.0  | 9.6  | 0.0  | 0.0   | 0.0  | -12.9 | 0.0 | 1  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 72 | 0.0 | 250  | 60.6 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 6  |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 84 | 0.0 | 500  | 60.6 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 16 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 89 | 0.0 | 1000 | 60.6 | 0.0 | -2.8 | 0.0  | 1.1  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 19 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 87 | 0.0 | 2000 | 60.6 | 0.0 | -2.8 | 0.0  | 2.9  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 15 |
| S36       | HVAC RTU    | 17652710.3 | 4786988.4 | 5.5 | 0     | 81 | 0.0 | 4000 | 60.6 | 0.0 | -2.8 | 0.0  | 9.9  | 0.0  | 0.0   | 0.0  | -12.9 | 0.0 | 1  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 67 | 0.0 | 63   | 61.4 | 0.0 | -3.0 | 3.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 4  |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.4 | 0.0 | -1.6 | 2.6  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 13 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.4 | 0.0 | -2.1 | 2.8  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 13 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 87 | 0.0 | 500  | 61.4 | 0.0 | -2.2 | 3.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 14 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.2 | 3.2  | 1.2  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 14 |
| S18       | HVAC RTU    | 17652494.0 | 4787078.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.4 | 0.0 | -2.2 | 3.6  | 3.2  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 7  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 67 | 0.0 | 63   | 61.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 7  |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 80 | 0.0 | 125  | 61.4 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 16 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 84 | 0.0 | 250  | 61.4 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 17 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 87 | 0.0 | 500  | 61.4 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 18 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.8 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 18 |
| S05       | HVAC RTU    | 17652774.7 | 4786972.8 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.4 | 0.0 | -2.8 | 0.0  | 3.2  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 11 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 67 | 0.0 | 63   | 61.5 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | -0.9  | 0.0 | 7  |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 80 | 0.0 | 125  | 61.5 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 16 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 84 | 0.0 | 250  | 61.5 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 17 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 87 | 0.0 | 500  | 61.5 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | -9.9  | 0.0 | 18 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.5 | 0.0 | -2.8 | 0.0  | 1.2  | 0.0  | 0.0   | 0.0  | -10.9 | 0.0 | 18 |
| S06       | HVAC RTU    | 17652777.1 | 4786972.9 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.5 | 0.0 | -2.8 | 0.0  | 3.2  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 11 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.5 | 0.0 | -2.7 | 7.5  | 0.1  | 0.0  | 0.0   | 0.0  | -4.7  | 0.0 | 9  |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.5 | 0.0 | -2.7 | 7.5  | 0.3  | 0.0  | 0.0   | 0.0  | -8.7  | 0.0 | 9  |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 87 | 0.0 | 500  | 61.5 | 0.0 | -2.8 | 7.5  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 10 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.5 | 0.0 | -2.8 | 7.5  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 11 |
| S21       | HVAC RTU    | 17652529.4 | 4787083.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.5 | 0.0 | -2.8 | 7.5  | 3.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 4  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 80 | 0.0 | 125  | 61.5 | 0.0 | -2.2 | 7.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 9  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 84 | 0.0 | 250  | 61.5 | 0.0 | -2.4 | 7.2  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 9  |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 87 | 0.0 | 500  | 61.5 | 0.0 | -2.4 | 7.2  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 10 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.5 | 0.0 | -2.4 | 7.2  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 11 |
| S19       | HVAC RTU    | 17652502.1 | 4787082.3 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.5 | 0.0 | -2.4 | 7.2  | 3.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 4  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 80 | 0.0 | 125  | 61.5 | 0.0 | -2.6 | 7.4  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 9  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 84 | 0.0 | 250  | 61.5 | 0.0 | -2.6 | 7.4  | 0.4  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 9  |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 87 | 0.0 | 500  | 61.5 | 0.0 | -2.6 | 7.4  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 10 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.5 | 0.0 | -2.6 | 7.4  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 11 |
| S20       | HVAC RTU    | 17652511.2 | 4787083.5 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.5 | 0.0 | -2.6 | 7.4  | 3.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 4  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 65 | 0.0 | 63   | 61.0 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 6  |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 78 | 0.0 | 125  | 61.0 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 15 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 83 | 0.0 | 250  | 61.0 | 0.0 | -2.8 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 16 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 500  | 61.0 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 18 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 87 | 0.0 | 1000 | 61.0 | 0.0 | -2.8 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 17 |
| S33       | HVAC RTU    | 17652765.8 | 4786957.2 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.0 | 0.0 | -2.8 | 0.0  | 3.1  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 12 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 67 | 0.0 | 63   | 61.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 7  |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 80 | 0.0 | 125  | 61.7 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 16 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 84 | 0.0 | 250  | 61.7 | 0.0 | -2.8 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 16 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 87 | 0.0 | 500  | 61.7 | 0.0 | -2.8 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 17 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.7 | 0.0 | -2.8 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 18 |
| S07       | HVAC RTU    | 17652774.6 | 4786990.1 | 5.5 | 0     | 85 | 0.0 | 2000 | 61.7 | 0.0 | -2.8 | 0.0  | 3.3  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 11 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 72 | 0.0 | 250  | 61.4 | 0.0 | -2.7 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 5  |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 84 | 0.0 | 500  | 61.4 | 0.0 | -2.8 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 15 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.4 | 0.0 | -2.8 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 18 |
| S28       | HVAC RTU    | 17652287.5 | 4786523.9 | 5.5 | 0     | 87 | 0.0 | 2000 | 61.4 | 0.0 | -2.8 | 0.0  | 3.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 14 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 84 | 0.0 | 500  | 61.5 | 0.0 | -2.9 | 7.7  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 7  |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 89 | 0.0 | 1000 | 61.5 | 0.0 | -2.9 | 7.7  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 11 |
| S24       | HVAC RTU    | 17652560.7 | 4787081.8 | 5.5 | 0     | 87 | 0.0 | 2000 | 61.5 | 0.0 | -2.9 | 7.7  | 3.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 6  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 67 | 0.0 | 63   | 63.3 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 6  |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 80 | 0.0 | 125  | 63.3 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 84 | 0.0 | 250  | 63.3 | 0.0 | -3.0 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 15 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 87 | 0.0 | 500  | 63.3 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.3 | 0.0 | -3.0 | 0.0  | 1.5  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 16 |
| S32       | HVAC RTU    | 17652130.5 | 4786637.7 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.3 | 0.0 | -3.0 | 0.0  | 4.0  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 9  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 67 | 0.0 | 63   | 63.4 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 5  |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 80 | 0.0 | 125  | 63.4 | 0.0 | -2.9 | 0.0  | 0.2  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 84 | 0.0 | 250  | 63.4 | 0.0 | -2.9 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 15 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 87 | 0.0 | 500  | 63.4 | 0.0 | -3.0 | 0.0  | 0.8  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 16 |
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 89 | 0.0 | 1000 | 63.4 | 0.0 | -3.0 | 0.0  | 1.5  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 16 |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name | X          | Y         | Z   | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|-----|-------|----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S31       | HVAC RTU    | 17652128.5 | 4786640.0 | 5.5 | 0     | 85 | 0.0 | 2000 | 63.4 | 0.0 | -3.0 | 0.0  | 4.0  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 9  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 61 | 0.0 | 63   | 58.8 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 4  |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 74 | 0.0 | 125  | 58.8 | 0.0 | -0.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 11 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 79 | 0.0 | 250  | 58.8 | 0.0 | -1.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 13 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 83 | 0.0 | 500  | 58.8 | 0.0 | -1.0 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 15 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 82 | 0.0 | 1000 | 58.8 | 0.0 | -1.0 | 0.0  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 12 |
| S01       | HVAC RTU    | 17652754.0 | 4786849.6 | 8.0 | 0     | 81 | 0.0 | 2000 | 58.8 | 0.0 | -1.0 | 0.0  | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 9  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 62 | 0.0 | 63   | 59.0 | 0.0 | -3.0 | 3.4  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 2  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 75 | 0.0 | 125  | 59.0 | 0.0 | -2.0 | 3.4  | 0.1  | 0.0  | 0.0  | 0.0  | -4.6  | 0.0 | 10 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 250  | 59.0 | 0.0 | -2.5 | 4.4  | 0.3  | 0.0  | 0.0  | 0.0  | -8.6  | 0.0 | 11 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 83 | 0.0 | 500  | 59.0 | 0.0 | -2.6 | 5.5  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 11 |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 82 | 0.0 | 1000 | 59.0 | 0.0 | -2.6 | 6.3  | 0.9  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 8  |
| S13       | HVAC RTU    | 17652551.9 | 4786997.1 | 5.5 | 0     | 80 | 0.0 | 2000 | 59.0 | 0.0 | -2.6 | 6.7  | 2.4  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 3  |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 76 | 0.0 | 125  | 59.5 | 0.0 | -2.8 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 15 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 250  | 59.5 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 14 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 84 | 0.0 | 500  | 59.5 | 0.0 | -2.9 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 17 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 83 | 0.0 | 1000 | 59.5 | 0.0 | -2.9 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 15 |
| S12       | HVAC RTU    | 17652620.9 | 4786998.7 | 5.5 | 0     | 79 | 0.0 | 2000 | 59.5 | 0.0 | -2.9 | 0.0  | 2.6  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 8  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 61 | 0.0 | 63   | 59.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 3  |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 74 | 0.0 | 125  | 59.6 | 0.0 | -0.4 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 10 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 79 | 0.0 | 250  | 59.6 | 0.0 | -1.1 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 12 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 83 | 0.0 | 500  | 59.6 | 0.0 | -1.1 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 14 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 82 | 0.0 | 1000 | 59.6 | 0.0 | -1.1 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 12 |
| S02       | HVAC RTU    | 17652778.2 | 4786850.1 | 8.0 | 0     | 81 | 0.0 | 2000 | 59.6 | 0.0 | -1.1 | 0.0  | 2.6  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 8  |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 76 | 0.0 | 125  | 60.3 | 0.0 | -2.9 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 14 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 250  | 60.3 | 0.0 | -2.9 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 13 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 84 | 0.0 | 500  | 60.3 | 0.0 | -2.9 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 16 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 83 | 0.0 | 1000 | 60.3 | 0.0 | -2.9 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 14 |
| S09       | HVAC RTU    | 17652676.8 | 4786999.6 | 5.5 | 0     | 79 | 0.0 | 2000 | 60.3 | 0.0 | -2.9 | 0.0  | 2.8  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 7  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 61 | 0.0 | 63   | 60.7 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 2  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 74 | 0.0 | 125  | 60.7 | 0.0 | -0.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 9  |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 79 | 0.0 | 250  | 60.7 | 0.0 | -1.1 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 11 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 83 | 0.0 | 500  | 60.7 | 0.0 | -1.1 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 13 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 82 | 0.0 | 1000 | 60.7 | 0.0 | -1.1 | 0.0  | 1.1  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 10 |
| S03       | HVAC RTU    | 17652813.6 | 4786860.2 | 8.0 | 0     | 81 | 0.0 | 2000 | 60.7 | 0.0 | -1.1 | 0.0  | 3.0  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 7  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 61 | 0.0 | 63   | 61.3 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 2  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 74 | 0.0 | 125  | 61.3 | 0.0 | -0.3 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.8  | 0.0 | 8  |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 79 | 0.0 | 250  | 61.3 | 0.0 | -1.0 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.8  | 0.0 | 10 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 83 | 0.0 | 500  | 61.3 | 0.0 | -1.1 | 0.0  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 12 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 82 | 0.0 | 1000 | 61.3 | 0.0 | -1.1 | 0.0  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 10 |
| S04       | HVAC RTU    | 17652837.9 | 4786861.4 | 8.0 | 0     | 81 | 0.0 | 2000 | 61.3 | 0.0 | -1.1 | 0.0  | 3.2  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 6  |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 76 | 0.0 | 125  | 61.4 | 0.0 | -2.7 | 7.5  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 5  |
| S38       | HVAC RTU    | 17652531.6 | 4787077.3 | 5.5 | 0     | 79 | 0.0 | 250  | 61.4 | 0.0 | -2.7 | 7.5  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 4  |



Receiver: RP10

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Environment to Site (External Noise)

Project: Sources

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 45          |

| Receiver Name | Receiver ID | X             | Y            | Z       |
|---------------|-------------|---------------|--------------|---------|
| RP10          | RP10        | 17652529.30 m | 4786748.23 m | 17.65 m |

| Source ID | Source Name                   | X          | Y         | Z   | Refl. | Lw  | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahus | Cmet | Dc    | RL  | Lr |
|-----------|-------------------------------|------------|-----------|-----|-------|-----|-----|------|------|-----|------|------|------|------|------|------|-------|-----|----|
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 84  | 0.0 | 500  | 61.4 | 0.0 | -2.7 | 7.5  | 0.6  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 7  |
| S38       | HVAC RTU                      | 17652531.6 | 4787077.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.4 | 0.0 | -2.7 | 7.5  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 5  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 76  | 0.0 | 125  | 61.7 | 0.0 | -2.8 | 7.5  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 5  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 79  | 0.0 | 250  | 61.7 | 0.0 | -2.8 | 7.5  | 0.4  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 4  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 84  | 0.0 | 500  | 61.7 | 0.0 | -2.8 | 7.5  | 0.7  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 7  |
| S22       | HVAC RTU                      | 17652529.8 | 4787088.9 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.7 | 0.0 | -2.8 | 7.5  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 4  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 76  | 0.0 | 125  | 61.7 | 0.0 | -2.8 | 7.6  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 5  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 79  | 0.0 | 250  | 61.7 | 0.0 | -2.8 | 7.6  | 0.4  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 4  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 84  | 0.0 | 500  | 61.7 | 0.0 | -2.8 | 7.6  | 0.7  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 7  |
| S23       | HVAC RTU                      | 17652540.9 | 4787089.3 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.7 | 0.0 | -2.8 | 7.6  | 1.2  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 4  |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 76  | 0.0 | 125  | 61.7 | 0.0 | -1.0 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 250  | 61.7 | 0.0 | -1.9 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 10 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 84  | 0.0 | 500  | 61.7 | 0.0 | -2.2 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 14 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 83  | 0.0 | 1000 | 61.7 | 0.0 | -2.2 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 11 |
| S29       | HVAC RTU                      | 17652331.9 | 4786466.0 | 5.5 | 0     | 79  | 0.0 | 2000 | 61.7 | 0.0 | -2.2 | 0.0  | 3.3  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 4  |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 76  | 0.0 | 125  | 62.2 | 0.0 | -1.6 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 11 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 250  | 62.2 | 0.0 | -2.3 | 0.0  | 0.4  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 10 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 84  | 0.0 | 500  | 62.2 | 0.0 | -2.4 | 0.0  | 0.7  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 14 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 83  | 0.0 | 1000 | 62.2 | 0.0 | -2.4 | 0.0  | 1.3  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 11 |
| S30       | HVAC RTU                      | 17652300.7 | 4786464.7 | 5.5 | 0     | 79  | 0.0 | 2000 | 62.2 | 0.0 | -2.4 | 0.0  | 3.5  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 4  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 62  | 0.0 | 63   | 59.6 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0  | 0.0  | -0.9  | 0.0 | 5  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 70  | 0.0 | 125  | 59.6 | 0.0 | -2.1 | 0.0  | 0.1  | 0.0  | 0.0  | 0.0  | -4.7  | 0.0 | 8  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 72  | 0.0 | 250  | 59.6 | 0.0 | -2.4 | 0.0  | 0.3  | 0.0  | 0.0  | 0.0  | -8.7  | 0.0 | 5  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 79  | 0.0 | 500  | 59.6 | 0.0 | -2.5 | 0.0  | 0.5  | 0.0  | 0.0  | 0.0  | -9.9  | 0.0 | 12 |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 76  | 0.0 | 1000 | 59.6 | 0.0 | -2.5 | 0.0  | 1.0  | 0.0  | 0.0  | 0.0  | -10.9 | 0.0 | 7  |
| S37       | HVAC RTU                      | 17652713.2 | 4786942.6 | 5.5 | 0     | 75  | 0.0 | 2000 | 59.6 | 0.0 | -2.5 | 0.0  | 2.6  | 0.0  | 0.0  | 0.0  | -11.9 | 0.0 | 3  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 72  | 0.0 | 63   | 56.0 | 0.0 | -3.0 | 4.1  | 0.0  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 9  |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 87  | 0.0 | 125  | 56.0 | 0.0 | -2.6 | 4.6  | 0.1  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 22 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 91  | 0.0 | 250  | 56.0 | 0.0 | -2.6 | 5.4  | 0.2  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 26 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 98  | 0.0 | 500  | 56.0 | 0.0 | -2.6 | 6.1  | 0.3  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 32 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 100 | 0.0 | 1000 | 56.0 | 0.0 | -2.6 | 6.7  | 0.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 33 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 99  | 0.0 | 2000 | 56.0 | 0.0 | -2.6 | 7.2  | 1.7  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 31 |
| S42       | Large Aggregate Loading Cycle | 17652654.9 | 4786872.8 | 1.0 | 0     | 94  | 0.0 | 4000 | 56.0 | 0.0 | -2.6 | 7.6  | 5.8  | 0.0  | 0.0  | 0.0  | 0.0   | 0.0 | 21 |



Project: 1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Subject Site to Environment (Internal Noise Sources)  
Project Number: 25253

| Source ID         | Source Name | Point of Reception RP11 |                              | Point of Reception RP13 |                              | Point of Reception RP12 |                              | Point of Reception RP14 |                              |
|-------------------|-------------|-------------------------|------------------------------|-------------------------|------------------------------|-------------------------|------------------------------|-------------------------|------------------------------|
|                   |             | Distance to POR (m)     | Sound Level at POR (dBA) Day | Distance to POR (m)     | Sound Level at POR (dBA) Day | Distance to POR (m)     | Sound Level at POR (dBA) Day | Distance to POR (m)     | Sound Level at POR (dBA) Day |
| S55               | HVAC RTU    | 73                      | 11                           | 169                     | 8                            | 143                     | 9                            | 105                     | 11                           |
| S54               | HVAC RTU    | 73                      | 11                           | 169                     | 8                            | 143                     | 9                            | 105                     | 11                           |
| S53               | HVAC RTU    | 74                      | 10                           | 168                     | 9                            | 143                     | 9                            | 105                     | 11                           |
| S52               | HVAC RTU    | 74                      | 10                           | 168                     | 9                            | 143                     | 9                            | 106                     | 11                           |
| S51               | HVAC RTU    | 75                      | 10                           | 167                     | 9                            | 143                     | 9                            | 106                     | 11                           |
| S50               | HVAC RTU    | 75                      | 10                           | 167                     | 9                            | 143                     | 9                            | 106                     | 11                           |
| S49               | HVAC RTU    | 75                      | 10                           | 167                     | 9                            | 143                     | 9                            | 106                     | 8                            |
| S48               | HVAC RTU    | 76                      | 10                           | 166                     | 9                            | 143                     | 9                            | 106                     | 8                            |
| S47               | HVAC RTU    | 76                      | 10                           | 166                     | 9                            | 142                     | 9                            | 106                     | 8                            |
| S46               | HVAC RTU    | 77                      | 10                           | 165                     | 9                            | 142                     | 9                            | 106                     | 8                            |
| S45               | HVAC RTU    | 77                      | 10                           | 165                     | 9                            | 142                     | 9                            | 107                     | 7                            |
| S44               | HVAC RTU    | 77                      | 10                           | 164                     | 9                            | 142                     | 10                           | 107                     | 7                            |
| Total Level [dBA] |             |                         | 21                           |                         | 20                           |                         | 20                           |                         | 21                           |



Receiver: RP11

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Subject Site to Environment (Internal

Project: Noise Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 20          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP11          | RP11        | 17652598.91 m | 4786814.73 m | 1.50 m |

| Source ID | Source Name | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.3 | 0.0 | -3.0 | 9.8  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.3 | 0.0 | -3.0 | 11.5 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.3 | 0.0 | -3.0 | 13.6 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 5  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.3 | 0.0 | -3.0 | 16.1 | 0.3  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 4  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.3 | 0.0 | -3.0 | 9.9  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.3 | 0.0 | -3.0 | 11.7 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.3 | 0.0 | -3.0 | 13.8 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 5  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.3 | 0.0 | -3.0 | 16.3 | 0.3  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 3  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.4 | 0.0 | -3.0 | 10.0 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 3  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.4 | 0.0 | -3.0 | 11.8 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.4 | 0.0 | -3.0 | 14.1 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 5  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.4 | 0.0 | -3.0 | 16.6 | 0.3  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 3  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.4 | 0.0 | -3.0 | 10.1 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.4 | 0.0 | -3.0 | 12.0 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.4 | 0.0 | -3.0 | 14.3 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.4 | 0.0 | -3.0 | 16.9 | 0.3  | 0.0  | 0.0   | 0.0  | -11.9 | 0.0 | 3  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.5 | 0.0 | -3.0 | 10.2 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.5 | 0.0 | -3.0 | 12.1 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.5 | 0.0 | -3.0 | 14.3 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.5 | 0.0 | -3.0 | 16.9 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 3  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.5 | 0.0 | -3.0 | 10.2 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.5 | 0.0 | -3.0 | 12.1 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.5 | 0.0 | -3.0 | 14.4 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.5 | 0.0 | -3.0 | 16.9 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 3  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.5 | 0.0 | -3.0 | 10.2 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.5 | 0.0 | -3.0 | 12.1 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.5 | 0.0 | -3.0 | 14.4 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.5 | 0.0 | -3.0 | 16.9 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 2  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.6 | 0.0 | -3.0 | 10.2 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.6 | 0.0 | -3.0 | 12.1 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.6 | 0.0 | -3.0 | 14.4 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.6 | 0.0 | -3.0 | 17.0 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 2  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.6 | 0.0 | -3.0 | 10.2 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.6 | 0.0 | -3.0 | 12.2 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.6 | 0.0 | -3.0 | 14.4 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.6 | 0.0 | -3.0 | 17.0 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 2  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.7 | 0.0 | -3.0 | 10.2 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.7 | 0.0 | -3.0 | 12.2 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.7 | 0.0 | -3.0 | 14.5 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.7 | 0.0 | -3.0 | 17.0 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 2  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.7 | 0.0 | -3.0 | 10.3 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.7 | 0.0 | -3.0 | 12.2 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 2  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.7 | 0.0 | -3.0 | 14.5 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |



Receiver: RP11

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Subject Site to Environment (Internal

Project: Noise Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 20          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP11          | RP11        | 17652598.91 m | 4786814.73 m | 1.50 m |

| Source ID | Source Name | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.7 | 0.0 | -3.0 | 17.1 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 2  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 48.8 | 0.0 | -3.0 | 10.3 | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 48.8 | 0.0 | -3.0 | 12.2 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 2  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 48.8 | 0.0 | -3.0 | 14.5 | 0.1  | 0.0  | 0.0   | 0.0  | -10.6 | 0.0 | 4  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 48.8 | 0.0 | -3.0 | 17.1 | 0.3  | 0.0  | 0.0   | 0.0  | -11.8 | 0.0 | 2  |



Receiver: RP12

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Subject Site to Environment (Internal

Project: Noise Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 19          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP12          | RP12        | 17652489.70 m | 4786928.33 m | 1.50 m |

| Source ID | Source Name | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.1  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.0  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.2 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.1  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.0  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.2 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.2  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.0  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.2 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.2  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.3 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.2  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.3 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.3  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.4 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.2  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.3 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.2  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.3 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.2  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.3 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.1  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.0  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.2 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.2  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.1  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.2 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 54.1 | 0.0 | -3.0 | 8.2  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 54.1 | 0.0 | -3.0 | 9.1  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 4  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 54.1 | 0.0 | -3.0 | 10.2 | 0.5  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 4  |



Receiver: RP13

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Subject Site to Environment (Internal

Project: Noise Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 18          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP13          | RP13        | 17652364.99 m | 4786816.63 m | 1.50 m |

| Source ID | Source Name | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.3 | 0.0 | -3.0 | 8.7  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.3 | 0.0 | -3.0 | 9.8  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.3 | 0.0 | -3.0 | 7.9  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.3 | 0.0 | -3.0 | 8.6  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.3 | 0.0 | -3.0 | 9.6  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.4 | 0.0 | -3.0 | 7.9  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.4 | 0.0 | -3.0 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.4 | 0.0 | -3.0 | 9.5  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.4 | 0.0 | -3.0 | 7.9  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.4 | 0.0 | -3.0 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.4 | 0.0 | -3.0 | 9.4  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.4 | 0.0 | -3.0 | 7.9  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.4 | 0.0 | -3.0 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.4 | 0.0 | -3.0 | 9.4  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.4 | 0.0 | -3.0 | 7.6  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.4 | 0.0 | -3.0 | 8.4  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.4 | 0.0 | -3.0 | 9.3  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.5 | 0.0 | -3.0 | 7.7  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.5 | 0.0 | -3.0 | 8.4  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.5 | 0.0 | -3.0 | 9.4  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.5 | 0.0 | -3.0 | 7.7  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.5 | 0.0 | -3.0 | 8.4  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.5 | 0.0 | -3.0 | 9.4  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.5 | 0.0 | -3.0 | 7.7  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.5 | 0.0 | -3.0 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.5 | 0.0 | -3.0 | 9.4  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 55.5 | 0.0 | -3.0 | 7.7  | 0.2  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.5 | 0.0 | -3.0 | 8.5  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.5 | 0.0 | -3.0 | 9.4  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.5 | 0.0 | -3.0 | 8.7  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.5 | 0.0 | -3.0 | 9.6  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 55.6 | 0.0 | -3.0 | 8.7  | 0.3  | 0.0  | 0.0   | 0.0  | -10.3 | 0.0 | 3  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 55.6 | 0.0 | -3.0 | 9.6  | 0.6  | 0.0  | 0.0   | 0.0  | -11.4 | 0.0 | 3  |



Receiver: RP14

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Subject Site to Environment (Internal

Project: Noise Sources)

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 19          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP14          | RP14        | 17652563.37 m | 4786693.26 m | 1.50 m |

| Source ID | Source Name | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc    | RL  | Lr |
|-----------|-------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-------|-----|----|
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.4 | 0.0 | -3.0 | 7.6  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.4 | 0.0 | -3.0 | 8.4  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 4  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.4 | 0.0 | -3.0 | 9.4  | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 6  |
| S55       | HVAC RTU    | 17652531.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.4 | 0.0 | -3.0 | 10.8 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 6  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.4 | 0.0 | -3.0 | 7.7  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.4 | 0.0 | -3.0 | 8.4  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.4 | 0.0 | -3.0 | 9.4  | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 6  |
| S54       | HVAC RTU    | 17652531.0 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.4 | 0.0 | -3.0 | 10.8 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 6  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 7.8  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 8.6  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 9.7  | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 6  |
| S53       | HVAC RTU    | 17652530.6 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.5 | 0.0 | -3.0 | 11.1 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 5  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 7.8  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 8.7  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 9.8  | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 6  |
| S52       | HVAC RTU    | 17652530.2 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.5 | 0.0 | -3.0 | 11.3 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 5  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 7.9  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 8.7  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 9.8  | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 6  |
| S51       | HVAC RTU    | 17652529.7 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.5 | 0.0 | -3.0 | 11.3 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 5  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 7.9  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 2  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 8.7  | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 3  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 9.8  | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 6  |
| S50       | HVAC RTU    | 17652529.3 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.5 | 0.0 | -3.0 | 11.4 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 5  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 8.8  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 1  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 10.9 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 13.4 | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 2  |
| S49       | HVAC RTU    | 17652528.9 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.5 | 0.0 | -3.0 | 16.1 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 0  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 9.0  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 11.2 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 1  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 13.7 | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 2  |
| S48       | HVAC RTU    | 17652528.4 | 4786792.1 | 18.0 | 0     | 77 | 0.0 | 1000 | 51.5 | 0.0 | -3.0 | 16.4 | 0.4  | 0.0  | 0.0   | 0.0  | -11.6 | 0.0 | 0  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 9.1  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 11.4 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S47       | HVAC RTU    | 17652528.0 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 14.0 | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 2  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 63 | 0.0 | 125  | 51.5 | 0.0 | -3.0 | 9.3  | 0.0  | 0.0  | 0.0   | 0.0  | -5.0  | 0.0 | 0  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 69 | 0.0 | 250  | 51.5 | 0.0 | -3.0 | 11.7 | 0.1  | 0.0  | 0.0   | 0.0  | -9.0  | 0.0 | 0  |
| S46       | HVAC RTU    | 17652527.6 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.5 | 0.0 | -3.0 | 14.3 | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 1  |
| S45       | HVAC RTU    | 17652527.1 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.6 | 0.0 | -3.0 | 14.6 | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 1  |
| S44       | HVAC RTU    | 17652526.7 | 4786792.1 | 18.0 | 0     | 75 | 0.0 | 500  | 51.6 | 0.0 | -3.0 | 15.0 | 0.2  | 0.0  | 0.0   | 0.0  | -10.4 | 0.0 | 1  |



Project: 1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Emergency Generator Testing and Maintenance  
Project Number: 25253

| Source ID         | Source Name         | Point of Reception RP11 |                              | Point of Reception RP13 |                              | Point of Reception RP12 |                              | Point of Reception RP14 |                              |
|-------------------|---------------------|-------------------------|------------------------------|-------------------------|------------------------------|-------------------------|------------------------------|-------------------------|------------------------------|
|                   |                     | Distance to POR (m)     | Sound Level at POR (dBA) Day | Distance to POR (m)     | Sound Level at POR (dBA) Day | Distance to POR (m)     | Sound Level at POR (dBA) Day | Distance to POR (m)     | Sound Level at POR (dBA) Day |
| S56               | Emergency Generator | 77                      | 37                           | 167                     | 38                           | 145                     | 39                           | 104                     | 38                           |
| Total Level [dBA] |                     |                         | 37                           |                         | 38                           |                         | 39                           |                         | 38                           |



Receiver: RP11

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Emergency Generator Testing and

Project: Maintenance

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 37          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP11          | RP11        | 17652598.91 m | 4786814.73 m | 1.50 m |

| Source ID | Source Name         | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|---------------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 55 | 0.0 | 32   | 48.7 | 0.0 | -3.0 | 7.8  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 1  |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 74 | 0.0 | 63   | 48.7 | 0.0 | -3.0 | 7.8  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 81 | 0.0 | 125  | 48.7 | 0.0 | -3.0 | 7.8  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 28 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 76 | 0.0 | 250  | 48.7 | 0.0 | -3.0 | 7.8  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 23 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 89 | 0.0 | 500  | 48.7 | 0.0 | -3.0 | 7.8  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 35 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 79 | 0.0 | 1000 | 48.7 | 0.0 | -3.0 | 7.9  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 26 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 75 | 0.0 | 2000 | 48.7 | 0.0 | -3.0 | 7.9  | 0.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 20 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 67 | 0.0 | 4000 | 48.7 | 0.0 | -3.0 | 8.1  | 2.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |



Receiver: RP12

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Emergency Generator Testing and

Project: Maintenance

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 39          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP12          | RP12        | 17652489.70 m | 4786928.33 m | 1.50 m |

| Source ID | Source Name         | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|---------------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 55 | 0.0 | 32   | 54.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 74 | 0.0 | 63   | 54.2 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 23 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 81 | 0.0 | 125  | 54.2 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 30 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 76 | 0.0 | 250  | 54.2 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 25 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 89 | 0.0 | 500  | 54.2 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 37 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 79 | 0.0 | 1000 | 54.2 | 0.0 | -3.0 | 0.0  | 0.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 28 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 75 | 0.0 | 2000 | 54.2 | 0.0 | -3.0 | 0.0  | 1.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 22 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 67 | 0.0 | 4000 | 54.2 | 0.0 | -3.0 | 0.0  | 4.7  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 11 |



Receiver: RP13

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Emergency Generator Testing and

Project: Maintenance

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 38          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP13          | RP13        | 17652364.99 m | 4786816.63 m | 1.50 m |

| Source ID | Source Name         | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|---------------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 55 | 0.0 | 32   | 55.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 2  |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 74 | 0.0 | 63   | 55.4 | 0.0 | -3.0 | 0.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 22 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 81 | 0.0 | 125  | 55.4 | 0.0 | -3.0 | 0.0  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 29 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 76 | 0.0 | 250  | 55.4 | 0.0 | -3.0 | 0.0  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 24 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 89 | 0.0 | 500  | 55.4 | 0.0 | -3.0 | 0.0  | 0.3  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 36 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 79 | 0.0 | 1000 | 55.4 | 0.0 | -3.0 | 0.0  | 0.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 26 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 75 | 0.0 | 2000 | 55.4 | 0.0 | -3.0 | 0.0  | 1.6  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 67 | 0.0 | 4000 | 55.4 | 0.0 | -3.0 | 0.0  | 5.5  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 9  |



Receiver: RP14

1544 & 1546 Four Mile Creek Rd, Niagara-on-the-Lake - Emergency Generator Testing and

Project: Maintenance

Project Number: 25253

| Time Period | Total (dBA) |
|-------------|-------------|
| Day         | 38          |

| Receiver Name | Receiver ID | X             | Y            | Z      |
|---------------|-------------|---------------|--------------|--------|
| RP14          | RP14        | 17652563.37 m | 4786693.26 m | 1.50 m |

| Source ID | Source Name         | X          | Y         | Z    | Refl. | Lw | L/A | Freq | Adiv | K0  | Agr  | Abar | Aatm | Afol | Ahous | Cmet | Dc  | RL  | Lr |
|-----------|---------------------|------------|-----------|------|-------|----|-----|------|------|-----|------|------|------|------|-------|------|-----|-----|----|
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 55 | 0.0 | 32   | 51.4 | 0.0 | -3.0 | 3.0  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 3  |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 74 | 0.0 | 63   | 51.4 | 0.0 | -3.0 | 3.1  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 23 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 81 | 0.0 | 125  | 51.4 | 0.0 | -3.0 | 3.1  | 0.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 30 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 76 | 0.0 | 250  | 51.4 | 0.0 | -3.0 | 3.2  | 0.1  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 25 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 89 | 0.0 | 500  | 51.4 | 0.0 | -3.0 | 3.4  | 0.2  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 37 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 79 | 0.0 | 1000 | 51.4 | 0.0 | -3.0 | 3.8  | 0.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 27 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 75 | 0.0 | 2000 | 51.4 | 0.0 | -3.0 | 4.5  | 1.0  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 21 |
| S56       | Emergency Generator | 17652528.7 | 4786790.1 | 19.5 | 0     | 67 | 0.0 | 4000 | 51.4 | 0.0 | -3.0 | 5.4  | 3.4  | 0.0  | 0.0   | 0.0  | 0.0 | 0.0 | 10 |



