

**PROPOSED NIAGARA HISTORICAL
SOCIETY MUSEUM ADDITION
43 CASTLEREAGH STREET, NIAGARA-ON-THE-LAKE**

**FUNCTIONAL SERVICING DESIGN BRIEF
PROPOSED WATER AND SANITARY SERVICES**

REV 2 – March 23, 2026

PREPARED BY:



HALLEX PROJECT # 251023

HALLEX NIAGARA
4999 VICTORIA AVENUE,
NIAGARA FALLS, ON L2E 4C9

HALLEX HAMILTON
745 SOUTH SERVICE ROAD, UNIT 205
STONE CREEK, ON L8E 5

INTRODUCTION

The proposed Niagara Historical Society Museum Addition will take place in two recently merged properties: the Niagara-on-the-Lake Museum at 43 Castlereagh Street and a former residential property at 25 Castlereagh Street, known as the Museum Annex. This development is located at the northwest corner of the Davy Street and Castlereagh Street intersection in the Town of Niagara-on-the-Lake, ON.

The existing site at 43 Castlereagh Street currently consists of a 3-storey memorial hall building, a 2-storey high school building with an existing 1 storey link joining the existing buildings. The existing site at 25 Castlereagh Street currently consists of a 2-storey museum annex.

The existing buildings are to remain, and the 2-storey addition is proposed behind the existing memorial hall building. The purpose of the service assessment is to determine the functional sizing of the proposed sanitary and water services in addition to the post-development flows from the site to determine the impact on the existing municipal infrastructure.

SANITARY

The existing site at 43 Castlereagh Street is currently serviced with a sanitary sewer connection from the existing 250mm diameter municipal sanitary sewer at Castlereagh Street to the building, however the size of the existing sanitary lateral is unknown.

The existing site at 25 Castlereagh Street is currently serviced with a sanitary sewer connection, however, the size and location of the existing connection is unknown.

Given the site is to be partially redeveloped for the proposed Niagara Historical Society Museum Addition, all existing sanitary laterals at 25 and 43 Castlereagh Street are to be located, capped, and abandoned at the main in accordance with municipal standards. A new sanitary lateral shall be proposed from the building to the existing 250mm municipal sanitary sewer at Castlereagh Street.

The building development is currently in the concept phase; therefore, the following assumptions based on the architectural drawings are made in carrying out the calculations:

- The plumbing fixtures and the number of plumbing fixtures indicated in Exhibit #1 include a combination of the existing plumbing fixtures and those proposed for the new addition and existing buildings. The proposed fixtures are preliminary and may not represent the final building plumbing design.

The wastewater generation for the subject development is determined to be 9,670 L/day using Table 8.2.1.3.B. of the Ontario Building Code. The peak drainage rate for the proposed development is determined to be 231.1 L/min based on the fixtures and fixture units shown in Exhibit #1 attached. Table 7.4.10.5 in the Ontario Building Code is used to determine probable peak drainage rates for the total fixture units.

Based on the above, Hallex recommends a minimum 150mm sanitary sewer @ 2.0% to be installed to convey sanitary flows from the proposed and existing buildings to the existing 250mm municipal sanitary sewer at Castlereagh Street.

WATER

The existing site at 43 Castlereagh Street is currently serviced with a 19mm water service connection from the existing 250mm diameter municipal watermain at Castlereagh Street to the building.

The existing site at 25 Castlereagh Street is currently serviced with a 19mm water service connection from the existing 250mm diameter municipal watermain at Castlereagh Street to the building.

Given the site is to be partially redeveloped for the proposed Niagara Historical Society Museum Addition, and a new fire suppression system is required, all existing water services at 25 and 43 Castlereagh Street are to be located, capped, and abandoned at the main. Therefore, a new water service shall be proposed from the building to the existing 250mm municipal watermain at Castlereagh Street.

The building development is currently in the concept phase; therefore, the following assumptions based on the architectural drawings are made in carrying out the calculations:

- The plumbing fixtures and the number of plumbing fixtures indicated in Exhibit #2 are preliminary and may not represent the final building plumbing design.
- The proposed building addition is assumed to be of non-combustible construction and will have sprinklers and hose cabinets installed throughout the building as per applicable standards.

The domestic water demand for the proposed development is determined to be 228.2 L/min based on the fixtures and fixture units shown in Exhibit #2 attached. Table 7.4.10.5 in the Ontario Building Code is used to determine water demands for the total fixture units. Extrapolation of Table 7.4.10.5 in the Ontario Building Code using the recommended flow rate for 9,000 fixture units and 10,000 fixture units was used to determine water demands for the total fixture units.

Using the calculations provided in the Fire Underwriters Survey – 2020 Water Supply for Public Fire Protection, the minimum water supply flow rate for fire protection is determined to be 7,000 L/min for the building based on the above assumptions as shown in Exhibit #3, attached. There are 2 existing municipal fire hydrants located near the site. The first is located approximately 26.5m west of the property on the north side of Castlereagh Street. The second is approximately 22.7m south of the property on the west side of Davy Street.

Based on the above, Hallex recommends a minimum 150mm water service to be installed to provide water supply to the proposed development from the existing 250mm municipal watermain at Castlereagh Street. The water service is to be extended to the mechanical room of the proposed building and is to be installed with a water meter and backflow preventer, as per applicable standards, prior to branching into domestic and fire services, inside the building.

CONCLUSION

We trust this letter meets your approval. Please contact the undersigned should you have any questions or comments.

Yours truly,
HALLEX ENGINEERING LTD





Jim Halucha, P.Eng
Civil/Structural Engineer


A handwritten signature in cursive script that reads 'Anthony Infurna'.

Anthony Infurna, C.E.T., rcsi
Project Manager

LEGEND



XMH




DAVY STREET

CASTLEREAGH STREET

XMH

XMH



4999 Victoria Avenue
Niagara Falls, ON L2E 4C9
Tel: 905-357-4015 Fax: 905-353-1105

Do not scale drawings. Report any discrepancies to Hallex Civil Engineering Ltd. before proceeding. This drawing must be signed and sealed by the Engineer prior to use in construction or submission for building permit. All construction shall be in accordance with latest edition of the Ontario Building Code and all applicable Ontario regulations. No part of this drawing including details, calculations or schedules may be reproduced in any form, either in part or whole, without the prior written consent of Hallex Civil Engineering Ltd.

PROJECT:
NIAGARA HISTORICAL SOCIETY
MUSEUM ADDITION. NOTL, ON

SHEET TITLE:
POST-DEVELOPMENT SANITARY
CATCHMENT AREA PLAN

SCALE: 1:500

DATE: 2026/02/23

DRAWN BY: MA

DESIGNED BY: MA

CHECKED BY: AI

JOB NUMBER: 251023

ISSUED FOR: APPROVAL

DWG **REV.**

CSK3 **1**



**Niagara Historical Society Museum Addition
Exhibit #1 - Wastewater Generation Rate & Peak Drainage Rate**

2026-03-23
Job: 251023

WASTEWATER GENERATION ASSESSMENT

Occupancy	# of Units	Development Statistics	Volume (Table 8.2.1.3. A / B)	Total Daily Volume	Notes
Warehouse Water Closets	1	5 WCs	950 L/WC	4750 L/day	* Basements and Upper Floors considered "Warehouse" space
Warehouse Loading Bays	1	0 bay	150 L/bay	0 L/day	
Store Water Closets	1	4 WCs	1230 L/WC	4920 L/day	* Main Floors considered "Stores" space.
Total =				9670 L/day	

Therefore the total calculated sanitary flow from the site is determined to be 9670 L/day.

MAXIMUM PROBABLE DRAINAGE RATE

Fixture	# of Units	# of Plumbing Fixtures	Fixture Units (Table 7.4.9.3.)	Total Sanitary Fixture Units
Sink (washup)	1	15 fixtures	3 FUs	45 FUs
Water closet w/ flush tank (public)	1	9 fixtures	4 FUs	36 FUs
Urinal (other public washout)	1	2 fixtures	3 FUs	6 FUs
Dishwasher (domestic)	1	2 fixtures	1 FUs	2 FUs
Total =				89.0 FUs
Total Flow =				231.1 L/min

Therefore the total calculated peak drainage rate is determined to be 231.1L/min.



**Niagara Historical Society Museum Addition
Exhibit #2 - Water Demand**

2026-03-23
Job: 251023

DOMESTIC WATER SUPPLY

Fixture	# of Units	# of Plumbing Fixtures	Fixture Units (Table 7.6.3.2.A.)	Total Water Fixture Units
Sink (washup)	1	15 fixtures	2 FUs	30 FUs
Water closet w/ flush tank (public)	1	9 fixtures	5 FUs	45 FUs
Urinal (other public washout)	1	2 fixtures	4 FUs	8 FUs
Dishwasher (domestic)	1	2 fixtures	1.4 FUs	2.8 FUs
Total =				85.8 FUs
Total Flow =				228.2 L/min

Therefore the maximum domestic water demand is determined to be 228.2 L/min.

